

ADDENDUM NO. 2
RECHE CANYON ROAD AND OTHER ROADS
WORK ORDER: H15172
AREA: COLTON
ROAD NO.: VARIOUS LOCATIONS

~~**BIDS OPEN 10:00 AM, THURSDAY, DECEMBER 5, 2024**~~
BIDS OPEN 10:00 AM, THURSDAY, DECEMBER 19, 2024

By Email via ePro System

The bid opening will be publicly viewable via goto.com, details are available in the Notice to Bidders pages of the Project Special Provisions.

Amend the Project Special Provisions as follows:

1. NOTICE TO BIDDERS

- a. On page NB-1, Replace the bid opening date “**10:00 A.M., THURSDAY, DECEMBER 5, 2024**”
With:

10:00 A.M., THURSDAY, DECEMBER 19, 2024

2. DIVISION II – GENERAL CONSTRUCTION

- a. **Delete** Section 10-1.14, **Asphalt Binder**, second paragraph (page no. SP-76) and **Replace**
with:

Asphalt binder for Asphalt Rubber Seal Coat shall be PG 64-16 (unless changed by the Engineer).

3. QUESTIONS AND ANSWERS

Question 1: The asphalt binder type, PG 64-28, specified for the asphalt rubber seal coat is not the correct binder type for this application. Both Caltrans and the Greenbook specifies either PG 70-10 or PG 64-16. To my 40 years of experience a PG 64-28 has NEVER been used when production Asphalt Seal Coats.

Answer: The asphalt binder type, PG 64-28, specified for the asphalt rubber seal coat has been amended to PG 64-16 in this Addendum No. 2.

Question 2: Per Special Provisions Section 10-1.14, it states “shall conform to the provisions in Section 37-2.05B”. This Section does not allow traffic to be placed on the SAMI and requires the Contractor to pave over the SAMI in the same shift that it is placed. Will that be required on this contract?

Answer: Yes, the requirements on no traffic on SAMI and surface course over SAMI must be done in the same shift shall apply in this project.

The addition of these requirements shall be considered in concert with existing documents in preparation of bids. **THE BIDDER'S CERTIFICATION FOR THIS ADDENDUM NO. 2 SHALL BE SIGNED BY THE SAME PERSON WHO SIGNS THE PROPOSAL AND SHALL BE SUBMITTED WITH THE PROPOSAL. ANY proposal not accompanied by a signed BIDDER'S CERTIFICATION (below) acknowledging receipt of this Addendum No. 2 will NOT be accepted.**

Noel Castillo, Director
Department of Public Works

By: 
Andy Silao, P.E., Chief
Contracts Division

AS:mb

BIDDER'S CERTIFICATION:

By my signature hereunder, I acknowledge receipt of Addendum No. 2 and I fully understand the intent and detail of Addendum No. 2, which I have considered in my preparation of the attached proposal.

Bidder's Signature

Date

Note: The page containing the executed BIDDER'S CERTIFICATION (just this page), must be included with the proposal.