

Seismic

Site Soil Class: D - Default (see Section 11.4.3)

Results:

S_s :	1.563	S_{D1} :	N/A
S_1 :	0.6	T_L :	12
F_a :	1.2	PGA :	0.634
F_v :	N/A	PGA_M :	0.761
S_{MS} :	1.875	F_{PGA} :	1.2
S_{M1} :	N/A	I_e :	1
S_{DS} :	1.25	C_v :	1.413

Ground motion hazard analysis may be required. See ASCE/SEI 7-16 Section 11.4.8.

Data Accessed: Wed May 19 2021

Date Source: [USGS Seismic Design Maps](#)

The ASCE 7 Hazard Tool is provided for your convenience, for informational purposes only, and is provided “as is” and without warranties of any kind. The location data included herein has been obtained from information developed, produced, and maintained by third party providers; or has been extrapolated from maps incorporated in the ASCE 7 standard. While ASCE has made every effort to use data obtained from reliable sources or methodologies, ASCE does not make any representations or warranties as to the accuracy, completeness, reliability, currency, or quality of any data provided herein. Any third-party links provided by this Tool should not be construed as an endorsement, affiliation, relationship, or sponsorship of such third-party content by or from ASCE.

ASCE does not intend, nor should anyone interpret, the results provided by this Tool to replace the sound judgment of a competent professional, having knowledge and experience in the appropriate field(s) of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the contents of this Tool or the ASCE 7 standard.

In using this Tool, you expressly assume all risks associated with your use. Under no circumstances shall ASCE or its officers, directors, employees, members, affiliates, or agents be liable to you or any other person for any direct, indirect, special, incidental, or consequential damages arising from or related to your use of, or reliance on, the Tool or any information obtained therein. To the fullest extent permitted by law, you agree to release and hold harmless ASCE from any and all liability of any nature arising out of or resulting from any use of data provided by the ASCE 7 Hazard Tool.

NOT FOR PUBLICATION

EQUIPMENT ANCHORAGE

NOT FOR BID

SEISMIC DESIGN LOAD - EQUIVALENT LATERAL FORCE PROCEDURE

Structure: 3,000 Gallon, Metal Storage Tank (Non-Buiding Structure)

Structure Seismic Design Criteria

(ASCE - Chapter 11)

Risk Category of Structure:	II	Table 1.5-1
Short-Period Spectral Response Acceleration, S_s :	1.563	Per ASCE 7 Hazard Tool
Long-Period Spectral Response Acceleration, S_1 :	0.600	Per ASCE 7 Hazard Tool
Structural height, h_n :	6.33	ft
Seismically isolated or dampened structure?	No	11.4.8 Item 1
Site-specific ground motion analysis provided?	No	11.4.8
Analytical procedure (Limit per Table 12.6-1)	ELF	Equivalent Lateral Force 12.8
Structural irregularities per 12.3.2?	No	12.8.1.3 - Item 1
Exceed 5 story above base/grade including mezzanines?	No	12.8.1.3 - Item 2

Site Class

11.4.3 & 11.4.4

Soil Site Class:

D - Default

No Geotech Report, $F_a = 1.2$ Min, per 11.4.4

Site Coefficients & Spectral Response Acceleration Parameters

11.4.4

	Table 11.4-1 & 11.4-2	11.4.8 Exceptions	Site-specific analysis per Geotech Report
Site Coefficient, F_a :	1.20	N/A	0.00
Site Coefficient, F_v :	N/A	1.70	0.00

$S_{MS} = F_a * S_s$:	1.876	Equation 11.4-1
$S_{M1} = F_v * S_1$:	1.020	Equation 11.4-2
$S_{DS} = 2/3 * S_{MS}$:	1.250	Equation 11.4-3
S_{DS} for calculation of C_s & E_v only (Max 1.0 or 70% S_{DS}):	1.250	12.8.1.3
$S_{D1} = 2/3 * S_{M1}$:	0.680	Equation 11.4-4
$T_S = S_{D1} / S_{DS}$:	0.544	11.4.6
Seismic Design Category (SDC):	D	11.6 & Table 11.6-1 & 2

Seismic Equivalent Lateral Force Procedure

Section 12.8

Importance Factor, I_e :

1.00 Table 1.5-2

Response Modification Factor, R : Table 15.4-2

3.00 Horizontal, Saddle-Supported Welded Steel Vessels

Overstrength Amplification factor, Ω_o :

2.0 Table 15.4-2

Approximate Period Values: Table 12.8-2:

C_t : 0.02 All other systems

x :

0.75

Approximate Fundamental Period, $T_a = C_t (h_n)^x$:

0.08 s

Equation 12.8-7

Long Period Transition Period, T_L :

12

Figure 22 (14-17)

	www.ISEngineers.com	Sheet:	Seismic ELF Analysis
		Date:	5/25/2021
		Project ID:	21-7178
		Version:	2019 CBC / ASCE 7-16

Seismic Response Coefficient, Cs:

$C_s = S_{DS} / (R / I_e)$: 0.417 *Equation 12.8-2*

Maximum Cs: MAX

$C_s = S_{D1} / T_a (R / I_e)$: $T \leq T_L$ 2.839 *Equation 12.8-3*

$C_s = S_{D1} T_L / T_a^2 (R / I_e)$: $T > T_L$ 426.639 *Equation 12.8-4*

Minimum Cs: MIN

$C_s = 0.044 S_{DS} I_e$: ≥ 0.03 0.055 *Equation 15.4-1*

$C_s = 0.8 S_1 / (R / I_e)$: for $S_1 \geq 0.6$ 0.160 *Equation 15.4-2*

Seismic Base Shear, $V = C_s W$: 0.417 W *Equation 12.8-1*

Structure - Horizontal Seismic Load Effect, Eh

Redundancy Factor, ρ : 1.00 *Section 12.3.4.2*

(Strength Level) $1.0E_h = \rho Q_e$: 0.417 W *Equation 12.4-3*

(ASD Level) $0.7E_h = \rho Q_e$: 0.292 W *Equation 12.4-3*

Vertical Distribution of Seismic Forces



$F_x = C_{vx} V$ Lateral seismic force at any level *Equation 12.8-11*

$C_{vx} = w_x h_x^k / \sum w_i h_i^k$ Vertical distribution factor *Equation 12.8-12*

Structural period Factor, k: 1.00

NOTE: ALL RIGHTS RESERVED. THIS DRAWING MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF HIGHLAND TANK. HIGHLAND TANK SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE AND LOCATION OF FITTINGS, ACCESSORIES, AND DIMENSIONS SHOWN ON THIS DRAWING. TOUCH UP OF FINISHED PAINT IS REQUIRED BY INSTALLATION CONTRACTOR. TOUCH UP PAINT SHIPPED WITH TANK.

SHIPPING LUGS AS NEEDED



DESIGN DATA	
CAPACITY	- 3,000 GALLONS
TYPE	- FIRE PROTECTION TANK (FPT)
NO. REQ.	-
OPERATING PRESSURE	- ATMOSPHERIC
SPECIFIC GRAVITY	= 1.0
TANK MATERIAL	- MILD CARBON STEEL
THICKNESS - HEADS	7 GA
THICKNESS - SHELL	7 GA
CONSTRUCTION	- LAP WELD INSIDE AND OUTSIDE
TANK TEST	- 5 PSIG
INT. FINISH	- SSPC SP10 BLAST, HighDRO-LINER PLUS FOR NFPA 22 APPLICATIONS
EXT. FINISH	- SSPC SP6 BLAST, WHITE URETHANE PAINT
LABEL	- NONE

LEGEND	
A	FLANGE WITH INTERNAL ANTI-VORTEX PLATE PER NFPA 22
B	FLANGE - VENT
C	24" X 1/2" PLATE TIGHT BOLT MANWAY WITH 1/2" THICK NEO-CORK GASKET
D	4" FNPT CONNECTION
E	STD HTM EXTERNAL LADDER & PLATFORM ASSEMBLY - PAINTED SAFETY YELLOW AND SHIPPED LOOSE FOR INSTALLATION ON SITE BY CONTRACTOR
F	HTM STD INTERNAL LADDER
G	FLANGE WITH INTERNAL 90° ELBOW SHOWN - OVERFLOW
H	FB-3"x 1/4"x3" WITH 5/8" HOLE ON CL (GROUNDING LUG)

NOTES: THIS IS A PRELIMINARY SHOP DRAWINGS AND DOES NOT SHOW ALL COMPONENTS. CONTRACTOR IS TO COORDINATE FINAL DESIGN WITH COMPLETE SYSTEM ALONG WITH SUMP PUMP SYSTEM. REQUIRED TANK FEATURES:

- (1) DRAIN OUTLET.
- (2) SADDLES, 6" HIGH MIN.
- (3) SADDLES WELDED TO TANK AND PAINT FINISH TO MATCH TANK.
- (4) TANK INSULATION.
- (5) FLOAT SENSOR WITH CONTROL PANELS.
- (6) LEAK SENSOR WITH CONTROL PANELS.
- (7) INLET PIPE (FROM SUMP PUMP).
- (8) OUTLET PIPE (FOR PUMPING OUT).

Highland Tank
 UNLESS NOTED, TOLERANCES ARE +/- 1"
HighDRO® WATER STORAGE TANK
 3000 GAL 64" SINGLE-WALL ABOVEGROUND HORIZONTAL FOR FIRE PROTECTION WITH BOTTOM DRAIN
 CUSTOMER:
 PROJECT:
 QUOTE NO: _____
 SCALE: 3/8" = 12" DATE: xx/xx/xx DWG. BY: XXX DWG. NO: 03000AHSWHDFTB064
 CHK'D BY: _____

Storage Tank Cut Sheet per Detail 12/A1.4 per the Architectural Plans

STORAGE TANK:
 - SEISMIC LOADS:
 $T_g = 0.08 \text{ sec.}$
 $V_1 = 0.3 S_{DS} W_{FE} = 10,850 \# (\text{Min}) \quad \text{EQ. 15.4-5}$
 - $S_{DS} = 1.25$,
 - $W_1 = 3,900 \# (\text{TANK})$
 - $W_2 = (3,000 \text{ gal})(8.35 \# / 199) = 25,050 \# (\text{FLUID WEIGHT})$
 - $F_E = 1.0$
 $V_2 = C_s W_T = 12,072 \# (\text{CONTROLS}) \quad \text{OK}$
 $C_s = 0.417 \quad (\text{Per EXCEL})$
 $W_T = 28,950 \#$
 $F_p = 12,072 \# (1.0E)$

- WIND LOADS
 Ch. 29, OTHER STRUCTURES

$$F = q_z G C_F A_f = \boxed{2510 \#} \text{ (SEISMIC CONTROL)}$$

$$q_z = 0.00256 K_z K_{zt} K_d K_e V^2 = 19.64 \text{ psf}$$

$K_z = 0.85$, EXPOSURE C, RISK CATEGORY II, $h < 15'$

$K_{zt} = 1.0$

$K_d = 1.0$, ROUND, CHIMNEYS, TANKS, AND SEMILAR STRUCTURES

$K_e = 1.0$


$V = 95 \text{ mph}$

$G = 0.85$

$C_F = 1.32$, $h = 6.33'$, $D = 5.33'$, $h/D = 1.19$

$A_f = L \times H = 18' \times 6.33' = 113.9 \text{ ft}^2$

- GLOBAL LOAD ANALYSIS:



$$M_{\text{exp}} = M_o - M_r = 0$$

$$M_o = F_p \times \bar{y} =$$

$$M_{o2} = F_p \times \bar{x} = 0.2 S_{DS} W_p d / 2$$

$$M_{r1} = T_1 \times d_1 = 0.350 T_2 d_1$$

$$M_{r2} = T_2 \times d_2 =$$

$$M_{r3} = W_p \times \bar{x} = W_p d / 2$$

$$\bar{x} = d/2, \quad F_p = 0.2 S_{DS} W_p, \quad W_p = 28,950 \#, \quad \bar{y} = 38"$$

$$T_1/d_1 = T_2/d_2, \quad T_1 = d_1 T_2 / d_2, \quad d_1 = 18", \quad d_2 = 43", \quad \bar{x} = 29"$$

ISOLATE FOR T2 $S_{DS} = 1.25$

$$F_p \bar{y} + 0.2 S_{DS} W_p d / 2 - 0.350 T_2 d_1 - T_2 d_2 - W_p d / 2 = 0$$

$$- T_2 (0.350 d_1 + d_2)$$

$$m = T/d$$

$$m_1 = T_1/d_1$$

$$m_2 = T_2/d_2$$

$$m_1 = m_2$$

$$T_2 = \frac{F_p \bar{y} + 0.2 S_{DS} W_p d / 2 - W_p d / 2}{(0.350 d_1 + d_2)} = \frac{F_p \bar{y} + 0.2 S_{DS} W_p \bar{x} - W_p \bar{x}}{48.25} = -3,542 \#, \text{ no uplift}$$

$$\frac{T_1}{d_1} = \frac{T_2}{d_2}$$

LOAD COMBOS: TENSION $F_p \bar{y} = 458,742 \#-in (1.0F)$, $0.25 S_{ps} W_p \bar{x} = 209,888 \#-in (1.0F)$, $W_p \bar{x} = 839,550 \#-in (1.0D)$

1) $0.6D + 0.7E_H + 0.7EV:$	$T_2 = -740 \#$, $T_1 = -259 \#$, no uplift, $n=2$	$T_{anchor} = 0$
2) $0.9D + E_H + EV:$	$T_2 = -1,802 \#$, $T_1 = -631 \#$, no uplift, $n=2$	$T_{anchor} = 0$
3) $0.6D + 0.7RE_H + 0.7EV:$	$T_2 = 8,918 \#$, $T_1 = 2,070 \#$, uplift, $n=2$	$T_{anchor} = 2,958 \#$
4) $0.9D + RE_H + EV:$	$T_2 = 7,705 \#$, $T_1 = 2,697 \#$, uplift, $n=2$	$T_{anchor} = 3,853 \#$

LOAD COMBOS: SHEAR

1) $0.6D + 0.7E_H + 0.7EV:$	$V = 8,450 \#$, $n = 4$ anchors, $V_{anchor} = 2,113 \# / anchor$
2) $0.9D + E_H + EV:$	$V = 12,072 \#$, $n = 4$, $V_{anchor} = 3,018 \# / anchor$
3) $0.6D + 0.7RE_H + 0.7EV:$	$V = 16,901 \#$, $n = 4$, $V_{anchor} = 4,225 \# / anchor$
4) $0.9D + RE_H + EV:$	$V = 24,144 \#$, $n = 4$, $V_{anchor} = 6,036 \# / anchor$

ANCHORAGE DESIGN:
 - USE OVERSTRENGTH REACTIONS FOR DESIGN.

$V_{anchor} = 6,036 \# / anchor (RE)$
 $T_{anchor} = 3,853 \# / anchor (RE)$



Company:	Innovative Structural Engr.	Date:	5/21/2021
Engineer:	SK	Page:	1/6
Project:	21-7178		
Address:	27369 Via Industria, Temecula, CA 92590		
Phone:	(951) 600-0032		
E-mail:	scott@iseengineers.com		

1. Project information

Customer company:
 Customer contact name:
 Customer e-mail:
 Comment:

Project description: Equipment Anchorage & Handrail Connections
 Location: Storage Tank Containment
 Fastening description: CIP Concrete Anchor

2. Input Data & Anchor Parameters

General

Design method: ACI 318-14
 Units: Imperial units

Anchor Information:

Anchor type: Cast-in-place
 Material: F1554 Grade 36
 Diameter (inch): 1.000
 Effective Embedment depth, h_{ef} (inch): 6.000
 Anchor category: -
 Anchor ductility: Yes
 h_{min} (inch): 7.75
 C_{min} (inch): 6.00
 S_{min} (inch): 6.00

Base Material

Concrete: Normal-weight
 Concrete thickness, h (inch): 20.00
 State: Cracked
 Compressive strength, f'_c (psi): 2500
 $\Psi_{c,v}$: 1.0
 Reinforcement condition: B tension, B shear
 Supplemental reinforcement: Not applicable
 Reinforcement provided at corners: No
 Ignore concrete breakout in tension: No
 Ignore concrete breakout in shear: No
 Ignore 6do requirement: No
 Build-up grout pad: No

Recommended Anchor

Anchor Name: Heavy Hex Bolt - 1"Ø Heavy Hex Bolt, F1554 Gr. 36



NOT FOR BUILD

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.

Simpson Strong-Tie Company Inc. 5956 W. Las Positas Boulevard Pleasanton, CA 94588 Phone: 925.560.9000 Fax: 925.847.3871 www.strongtie.com



Anchor Designer™
Software
Version 2.7.6990.0

Company:	Innovative Structural Engr.	Date:	5/21/2021
Engineer:	SK	Page:	2/6
Project:	21-7178		
Address:	27369 Via Industria, Temecula, CA 92590		
Phone:	(951) 600-0032		
E-mail:	scott@iseengineers.com		

Load and Geometry

Load factor source: ACI 318 Section 5.3

Load combination: not set

Seismic design: Yes

Anchors subjected to sustained tension: Not applicable

Ductility section for tension: 17.2.3.4.3 (d) is satisfied

Ductility section for shear: 17.2.3.5.3 (c) is satisfied

Ω_0 factor: not set

Apply entire shear load at front row: No

Anchors only resisting wind and/or seismic loads: Yes


Strength level loads:

N_{ua} [lb]: 3853

V_{uax} [lb]: 6036

V_{uay} [lb]: 0

<Figure 1>



Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.

Simpson Strong-Tie Company Inc. 5956 W. Las Positas Boulevard Pleasanton, CA 94588 Phone: 925.560.9000 Fax: 925.847.3871 www.strongtie.com



Company:	Innovative Structural Engr.	Date:	5/21/2021
Engineer:	SK	Page:	3/6
Project:	21-7178		
Address:	27369 Via Industria, Temecula, CA 92590		
Phone:	(951) 600-0032		
E-mail:	scott@iseengineers.com		

<Figure 2>



NOT FOR

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.

Simpson Strong-Tie Company Inc. 5956 W. Las Positas Boulevard Pleasanton, CA 94588 Phone: 925.560.9000 Fax: 925.847.3871 www.strongtie.com



Company:	Innovative Structural Engr.	Date:	5/21/2021
Engineer:	SK	Page:	4/6
Project:	21-7178		
Address:	27369 Via Industria, Temecula, CA 92590		
Phone:	(951) 600-0032		
E-mail:	scott@iseengineers.com		

3. Resulting Anchor Forces

Anchor	Tension load, N _{ua} (lb)	Shear load x, V _{uax} (lb)	Shear load y, V _{uay} (lb)	Shear load combined, $\sqrt{(V_{uax})^2 + (V_{uay})^2}$ (lb)
1	3853.0	6036.0	0.0	6036.0
Sum	3853.0	6036.0	0.0	6036.0

Maximum concrete compression strain (%): 0.00
 Maximum concrete compression stress (psi): 0
 Resultant tension force (lb): 3853
 Resultant compression force (lb): 0
 Eccentricity of resultant tension forces in x-axis, e'_{Nx} (inch): 0.00
 Eccentricity of resultant tension forces in y-axis, e'_{Ny} (inch): 0.00
 Eccentricity of resultant shear forces in x-axis, e'_{Vx} (inch): 0.00
 Eccentricity of resultant shear forces in y-axis, e'_{Vy} (inch): 0.00

4. Steel Strength of Anchor in Tension (Sec. 17.4.1)

N _{sa} (lb)	φ	φN _{sa} (lb)
35150	0.75	26363

5. Concrete Breakout Strength of Anchor in Tension (Sec. 17.4.2)

$$N_b = k_c \lambda_a \sqrt{f_c} h_{ef}^{1.5} \text{ (Eq. 17.4.2.2a)}$$

k _c	λ _a	f _c (psi)	h _{ef} (in)	N _b (lb)
24.0	1.00	2500	6.000	17636

$$0.75 \phi N_{cb} = 0.75 \phi (A_{Nc} / A_{Nco}) \Psi_{ed,N} \Psi_{c,N} \Psi_{cp,N} N_b \text{ (Sec. 17.3.1 \& Eq. 17.4.2.1a)}$$

A _{Nc} (in ²)	A _{Nco} (in ²)	c _{a,min} (in)	Ψ _{ed,N}	Ψ _{c,N}	Ψ _{cp,N}	N _b (lb)	φ	0.75 φN _{cb} (lb)
324.00	324.00	9.00	1.000	1.00	1.000	17636	0.70	9259

6. Pullout Strength of Anchor in Tension (Sec. 17.4.3)

$$0.75 \phi N_{pn} = 0.75 \phi \Psi_{c,P} N_p = 0.75 \phi \Psi_{c,P} 8 A_{brg} f_c \text{ (Sec. 17.3.1, Eq. 17.4.3.1 \& 17.4.3.4)}$$

Ψ _{c,P}	A _{brg} (in ²)	f _c (psi)	φ	0.75 φN _{pn} (lb)
1.0	1.50	2500	0.70	15761

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.

Simpson Strong-Tie Company Inc. 5956 W. Las Positas Boulevard Pleasanton, CA 94588 Phone: 925.560.9000 Fax: 925.847.3871 www.strongtie.com



Company:	Innovative Structural Engr.	Date:	5/21/2021
Engineer:	SK	Page:	5/6
Project:	21-7178		
Address:	27369 Via Industria, Temecula, CA 92590		
Phone:	(951) 600-0032		
E-mail:	scott@iseengineers.com		

8. Steel Strength of Anchor in Shear (Sec. 17.5.1)

V_{sa} (lb)	ϕ_{grout}	ϕ	$\phi_{grout}\phi V_{sa}$ (lb)
21090	1.0	0.65	13709

9. Concrete Breakout Strength of Anchor in Shear (Sec. 17.5.2)

Shear perpendicular to edge in x-direction:

$$V_{bx} = \min[7(l_e / d_a)^{0.2} \sqrt{d_a \lambda_a} \sqrt{f_c} c_{a1}^{1.5}; 9 \lambda_a \sqrt{f_c} c_{a1}^{1.5}] \text{ (Eq. 17.5.2.2a \& Eq. 17.5.2.2b)}$$

l_e (in)	d_a (in)	λ_a	f_c (psi)	c_{a1} (in)	V_{bx} (lb)
6.00	1.000	1.00	2500	9.00	12150

$$\phi V_{cbx} = \phi (A_{Vc} / A_{Vco}) \Psi_{ed,V} \Psi_{c,V} \Psi_{h,V} V_{bx} \text{ (Sec. 17.3.1 \& Eq. 17.5.2.1a)}$$

A_{Vc} (in ²)	A_{Vco} (in ²)	$\Psi_{ed,V}$	$\Psi_{c,V}$	$\Psi_{h,V}$	V_{bx} (lb)	ϕ	ϕV_{cbx} (lb)
364.50	364.50	1.000	1.000	1.000	12150	0.70	8505

Shear parallel to edge in x-direction:

$$V_{by} = \min[7(l_e / d_a)^{0.2} \sqrt{d_a \lambda_a} \sqrt{f_c} c_{a1}^{1.5}; 9 \lambda_a \sqrt{f_c} c_{a1}^{1.5}] \text{ (Eq. 17.5.2.2a \& Eq. 17.5.2.2b)}$$

l_e (in)	d_a (in)	λ_a	f_c (psi)	c_{a1} (in)	V_{by} (lb)
6.00	1.000	1.00	2500	13.33	21909

$$\phi V_{cbx} = \phi (2)(A_{Vc} / A_{Vco}) \Psi_{ed,V} \Psi_{c,V} \Psi_{h,V} V_{by} \text{ (Sec. 17.3.1, 17.5.2.1(c) \& Eq. 17.5.2.1a)}$$

A_{Vc} (in ²)	A_{Vco} (in ²)	$\Psi_{ed,V}$	$\Psi_{c,V}$	$\Psi_{h,V}$	V_{by} (lb)	ϕ	ϕV_{cbx} (lb)
360.00	800.00	1.000	1.000	1.000	21909	0.70	13803

10. Concrete Pryout Strength of Anchor in Shear (Sec. 17.5.3)

$$\phi V_{cp} = \phi k_{cp} N_{cb} = \phi k_{cp} (A_{Nc} / A_{Nco}) \Psi_{ed,N} \Psi_{c,N} \Psi_{cp,NNb} \text{ (Sec. 17.3.1 \& Eq. 17.5.3.1a)}$$

k_{cp}	A_{Nc} (in ²)	A_{Nco} (in ²)	$\Psi_{ed,N}$	$\Psi_{c,N}$	$\Psi_{cp,NNb}$	N_b (lb)	ϕ	ϕV_{cp} (lb)
2.0	324.00	324.00	1.000	1.000	1.000	17636	0.70	24691

11. Results

Interaction of Tensile and Shear Forces (Sec. R17.6)

Tension	Factored Load, N_{ua} (lb)	Design Strength, ϕN_n (lb)	Ratio	Status	
Steel	3853	26363	0.15	Pass	
Concrete breakout	3853	9259	0.42	Pass (Governs)	
Pullout	3853	15761	0.24	Pass	
Shear	Factored Load, V_{ua} (lb)	Design Strength, ϕV_n (lb)	Ratio	Status	
Steel	6036	13709	0.44	Pass	
T Concrete breakout x+	6036	8505	0.71	Pass (Governs)	
 Concrete breakout y-	6036	13803	0.44	Pass (Governs)	
Pryout	6036	24691	0.24	Pass	
Interaction check	$(N_{ua}/\phi N_{ua})^{5/3}$	$(V_{ua}/\phi V_{ua})^{5/3}$	Combined Ratio	Permissible	Status
Sec. R17.6	0.23	0.56	79.7%	1.0	Pass

1"Ø Heavy Hex Bolt, F1554 Gr. 36 with hef = 6.000 inch meets the selected design criteria.

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.

Simpson Strong-Tie Company Inc. 5956 W. Las Positas Boulevard Pleasanton, CA 94588 Phone: 925.560.9000 Fax: 925.847.3871 www.strongtie.com



Anchor Designer™
Software
Version 2.7.6990.0

Company:	Innovative Structural Engr.	Date:	5/21/2021
Engineer:	SK	Page:	6/6
Project:	21-7178		
Address:	27369 Via Industria, Temecula, CA 92590		
Phone:	(951) 600-0032		
E-mail:	scott@iseengineers.com		

12. Warnings

- Per designer input, ductility requirements for tension have been determined to be satisfied – designer to verify.
- Per designer input, ductility requirements for shear have been determined to be satisfied – designer to verify.
- Designer must exercise own judgement to determine if this design is suitable.

NOT FOR BID


Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.

Simpson Strong-Tie Company Inc. 5956 W. Las Positas Boulevard Pleasanton, CA 94588 Phone: 925.560.9000 Fax: 925.847.3871 www.strongtie.com


Sheet:	E-Mech Anchorage
Date:	5/25/2021
#	21-7178
Version	2019 CBC

ASCE CHAPTER 13.3 SEISMIC DESIGN REQUIREMENTS FOR NONSTRUCTURAL COMPONENTS

OPEN



ENCLOSED



Weights and dimensions

Model	Open				Enclosed			
	Dim "A" mm (in.)	Dim "B" mm (in.)	Dim "C" mm (in.)	Dry wt.* kg (lbs)	Dim "A" mm (in.)	Dim "B" mm (in.)	Dim "C" mm (in.)	Dry wt.* kg (lbs)
C90 D5	2268 (90)	1094 (44)	1576 (63)	1244 (2737)	3151 (125)	1142 (45)	1714 (68)	1944 (4277)
C110 D5	2268 (90)	1094 (44)	1576 (63)	1244 (2737)	3151 (125)	1142 (45)	1714 (68)	1944 (4277)
C150 D5	2537 (99.9)	1090 (42.9)	1846 (72.7)	1635 (3604.6)	3460 (136.2)	1090 (42.9)	2387 (94)	2390 (5269)
C170 D5	2537 (99.9)	1090 (42.9)	1846 (72.7)	1635 (3604.6)	3460 (136.2)	1090 (42.9)	2387 (94)	2390 (5269)
C90 D6	2268 (90)	1094 (44)	1576 (63)	1244 (2737)	3151 (125)	1142 (45)	1714 (68)	1944 (4277)
C100 D6	2268 (90)	1094 (44)	1576 (63)	1244 (2737)	3151 (125)	1142 (45)	1714 (68)	1944 (4277)
C135 D6	2537 (99.9)	1090 (42.9)	1846 (72.7)	1635 (3604.6)	3460 (136.2)	1090 (42.9)	2387 (94)	2390 (5269)

* Note: Weights represent a set with standard features. See outline drawings for weights of other configurations.

6BTA C100 D6 Diesel Generator manufactured by Cummins

Unit Properties

Total Component operating weight

Dimensions

- Unit Length (Depth) $\geq b$
- Unit Width
- Unit Height
- Unit Center of Gravity
- Curb Height
- Eccentricity Along L
- Eccentricity Along W

$W_p = 4277$ lbs

$L = 125$ in.

$W = 45$ in.


$H = 68$ in.

$h_{cg} = 34$ in.

$C_h = 0$ in.

$Ecc_L = 0$ in.

$Ecc_W = 0$ in.



Anchor Layout

of anchors along Width

$N_{anchors, w} = 2$ minimum

of anchors along Length

$N_{anchors, l} = 2$ minimum

Shared Corner Anchors?

= Yes *Add Orthogonal Effect Increase of 30% per ASCE 7-16 Section 12.5.3.1*

Total # of anchors

$N_{anchors, Total} = 4$

Seismic Criteria

Short Period Spectral Response Acceleration

$S_{DS} = 1.250$

Redundancy Factor

$\rho = 1.0$ nonstructural component

Component Importance Factor

$I_p = 1$

Component Amplification Factor

$a_p = 1$

Response Modification Factor

$R_p = 2.5$

Height to point of attachment with respect to the base

$z = 0$ ft.

Average roof height of structure with respect to the base

$h = 5.67$ ft.

Component/Roof Height Ratio

$z/h = 0$ ($z/h = 1.0$ for rooftop equipment)

Component Mounted on Vibration Isolator?

No

Apply Omega Strength Factor?

Yes

Omega Over Strength Factor

$\Omega_o = 2$

Effect of horizontal seismic forces, w/overstrength

$E_{mh} = \Omega Q_E$ not required for $F_{p(v)}$

Geotech Report

ASCE 7-16 Section 13.3.1.1

ASCE 7-16 Section 13.1.3

ASCE 7-16 Table 13.5-1 or 13.6-1

ASCE 7-16 Table 13.5-1 or 13.6-1

ASCE Table 13.5-1 or 13.6-1

ASCE Table 13.5-1 or 13.6-1

ASCE 7-16 Section 12.4.3