



SAN BERNARDINO COUNTY

DEPARTMENT OF PUBLIC WORKS
SPECIAL DISTRICTS

ADDENDUM NO. 1

TO THE BIDDING REQUIREMENTS, CONTRACT DOCUMENTS, GENERAL CONDITIONS,
SPECIAL CONDITIONS, AND TECHNICAL SPECIFICATIONS FOR THE

CAMP SWITZERLAND LIFT STATION PROJECT

LAKE GREGORY REGIONAL PARK

CRESTLINE, CALIFORNIA

PROJECT NO.: 30.30.0181

August 22, 2024

The Contract Documents for the above referenced project are hereby amended in the following manner and the following manner only:

- I. All provisions of this Addendum No. 1 are hereby incorporated into the Contract Documents, and Bidders shall account for all provisions pursuant to this Addendum No. 1 in submitting their bid proposals. **Each Bidder shall include a dated and signed copy of this Addendum with their sealed bid proposal.**

1. ITEM NO. 1: SECTION A – BIDDING REQUIREMENTS

Contractors are advised of the following change as it appears within Section A., Bidding Requirements, of the Specifications:

1. Under Instructions to Bidders, 3. SUBMITTING THE BID PROPOSAL:

Contractors are advised to replace the section that begins “C. Opening of Bids:” with the following:

Opening of Bids: Bids will be publicly opened in person and/or via virtual link at the Department’s Administrative Office, 222 W. Hospitality Lane, 2nd Floor, San Bernardino, California, 92415. Due to the Covid-19 pandemic and to ensure compliance with social distancing requirements, the bid opening will also be conducted virtually via Microsoft Teams. Bids (both paper and ePro) shall be opened and read aloud at the place and time set in the Advertisement for Bids.

The Microsoft Teams Webinar Meeting is as follows:

To pre-register : <https://events.gcc.teams.microsoft.com/event/9014c810-0c5c-4b08-802d-b52da4eacd17@31399e53-6a93-49aa-8cae-c929f9d4a91d>

[Join the meeting now](#)

Meeting ID: 212 128 078 528

Passcode: TTe3fn

2. ITEM NO. 2: SECTION A – BIDDING REQUIREMENTS

- A. Contractors are advised of the following change as it appears within Section A., Bidding Requirements, BID PROPOSAL of the Specifications
- Contractor are advised under Itemized Bid Proposal: Itemized Bid Schedule, Item 5 and 12 have been deleted, Item 43 and 44 have been added and Item 8, 9, 10, 13, 14, 29, 42 have been updated. Contractors shall replace ITEMIZED BID PROPOSAL, Page 23 THRU 28 in its entirety.

3. ITEM NO. 3: SECTION F – TECHNICAL SPECIFICATIONS

Contractors are advised of the following change as it appears within Section F, Technical Specifications of the Specifications

- A. Contractors are advised that Section F, Technical Specifications section of the bid package issued on August 8, 2024 (as amended) shall be replaced with:

Camp Switzerland Lift Station Project - Section F – Technical Specifications (Rev. 1).

4. ITEM NO. 4: SECTION G – CONTRACT DRAWNGS

Contractors are advised of the following change as it appears within Section G, Contract Drawings of the Specifications

- B. Contractors are advised that Section G, Contract Drawings section of the bid package issued on August 8, 2024 (as amended) shall be replaced with:

Camp Switzerland Lift Station Project - Section G - Contract Drawings (Rev. 1).

Below are questions and answers submitted prior to Pre-Bid Meeting:

Question: 1. Is there an Engineer's Estimate/Construction Cost for this project?

Answer: There is no engineer estimate at this time.

Question: 2. Can I get a copy of any addenda that have been released to date?

Answer: Addendum No. 1 is the first addendum released for the project. All Addendums will be released on ePro.

Question: 3. Can I get a copy of the planholders list?

Answer: The Sign-In Sheet for the Mandatory Pre-Bid Meeting will be released on ePro shortly after conducting the meeting.

ISSUE DATE: August 22, 2024

Date Acknowledged by Bidder: _____

By: _____
Deanna Lestina, Project Manager
Department of Public Works - Special Districts
Project Management Division

By: _____
Bidders Company Name

Bidders Signature

Enclosures:

- Camp Switzerland Lift Station, Section A – Bidding Requirements, BID PROPOSAL
- Camp Switzerland Lift Station, Section F – Technical Specifications (Rev 1)
- Camp Switzerland Lift Station, Section G – Contract Drawings (Rev 1)

BID PROPOSAL

PROJECT: CAMP SWITZERLAND LIFT STATION PROJECT

LOCATION: 24558 Lake Drive, Crestline, California

OWNER: SAN BERNARDINO COUNTY

BID OPENING DATE: 9/5/2024 @ 10:00 AM

MANDATORY PRE-BID MEETING DATE: 8/27/2024 @ 10:00 AM

**BID OPENING LOCATION: Department of Public Works – Special District
222 Hospitality Lane, Second Floor
San Bernardino, CA, 92415-0450**

San Bernardino County (“County”)

In compliance with the Bid Documents, the undersigned has carefully examined the drawings and other documents on file with the Clerk of the Board, for the **CAMP SWITZERLAND LIFT STATION PROJECT** at 24558 Lake Drive, Crestline, California, and fully understands the scope and meaning of the bid documents and has attended the **Mandatory Pre-bid meeting**. The undersigned has also examined the site of the proposed work and is familiar with the local conditions at the place where the work is to be done.

ITEMIZED BID SHEET


In the blanks provided, fill in the unit prices at which you propose to accomplish the work including all labor, materials, tools, apparatus, facilities, transportation, equipment, methods and procedures necessary to fully complete the work. Prices are inclusive of all applicable taxes, fees, bonds, insurance and required compensation pursuant to the laws of the State of California and San Bernardino County.

When discrepancies occur between words and figures, the words shall govern. When discrepancies occur between itemized bid and total bid, the detailed item shall govern. In the case of a discrepancy between the written bid or numerical bid set forth on the bid proposal, and the numerical bid set forth in the ePro system, the information on the bid proposal shall prevail. Bidders are advised that they must include a proportional amount of overhead, profit, etc. within these bid amounts.

CONTRACTOR: _____

ITEMIZED BID PROPOSAL

ITEMIZED BID SCHEDULE:

ITEM	DESCRIPTION	SPEC PAGE	Construction Note	QTY	UNIT	UNIT COST	TOTAL EXTENSION
1	Mobilization/demobilization, permits, insurance, bonds, survey and project conditions	01 01 00 01 71 13		1	LS		
2	Clearing and Grubbing	01 01 00		1	LS		
3	Erosion Control	01 01 00	Sheet 8	1	LS		
4	Soil Export	01 01 00 31 23 16		1	LS		
5	Furnish and install granular backfill for the lift station		44				
6	Furnish and install ¾-inch crushed rock	01 01 00	50, 63	1,400	SF		
7	Furnish 6-foot diameter pre-package fiberglass lift station with valve vault, 4" vent – mushroom style, wet well hatch with fall protection, valve vault hatch and piping kit	01 01 00 22 14 23	1, 3, 4, 19, 20, 33, 41, 42, 47	1	LS		
8	Install 6-foot diameter pre-package fiberglass lift station with valve vault, 4" vent – mushroom style, wet well hatch with fall protection, valve vault hatch and piping kit. Installation shall include foundation and backfill.	01 01 00 22 14 23	1, 3, 4, 19, 20, 33, 41, 42, 44, 47	1	LS		
9	Furnish and install FLYGT Concertor submersible pumps or approved equal and electrical hook for pump power manufacturer cable	01 01 00 22 14 23	2, Elec 8	2	EA		
10	Furnish and install 60" x 60" Jenson Precast valve vault for force main discharge or approved equal, valve vault hatch with fall protection for force main discharge & 4" stainless steel gooseneck vault vent with stainless steel screen	01 01 00 22 14 23	29, 31, 56	1	LS		

11	Furnish and install 10-foot diameter Jensen Precast emergency storage manhole or approved equal and construct grout structure base at 2% towards outlet	01 01 00 22 14 23	15, 39	1	LS		
12	Furnish and install 5-foot diameter sewer discharge manhole including the patching of surrounding pavement for the installation of the manhole.	01 01 00 03 30 00	30, 62	1	LS	_____	
13	Furnish and install 4-inch HDPE DR-13.5 sewer force main with butt-fusion bonded bends and deflection and its appurtenances	01 01 00 22 14 23 33 41 00	24, 25, 26, 27, 35, 40, 53, 59	1,100	LF		
14	Furnish and install 4-inch DIP Yard Piping and its appurtenances, including fittings and wye connection	01 01 00	8, 17, 54, 65	1	LS		
15	Furnish and install 8-inch SDR-35, PVC gravity sewer pipe and its appurtenances	01 01 00 33 41 00	38	16	LF		
16	Furnish and install 12-inch SDR-35, PVC gravity sewer pipe and its appurtenances	01 01 00 33 41 00	14	10	LF		
17	Furnish and install miscellaneous pipe spools, fittings and valves	01 01 00 22 14 23 33 41 00 05 50 00	6, 7, 9, 11, 12, 35, 36, 54	1	LS		
18	Furnish/fabricate pipe support		10, 55	1	LS		
19	Furnish and install sewer bypass with flange nipple adapter and 4" Dixon Cam and Groove Type D Coupler, Female NPT part #400-D-AL with Dash Plug and T-Handle 400-DP-Alpha or approved equal and all appurtenances		11, 13, 21, 23 28, 37	1	LS		
20	Furnish and install 4" sch 10, 316 stainless steel pipe and fittings		5, 58	1	LS		
21	Furnish and install 3" sch 80 PVC valve vault drain with p-trap		57	1	LS		
22	Furnish and install equipment foundations including steel reinforcing concrete placement, concrete curing, expansion joint and all work necessary to complete the installation of the foundations	01 01 00 03 30 00	34, 48, 49, 64	1	LS		
23	Furnish and install pipe penetration		32, 52	1	LS		
24	Furnish and install combination sewer air vacuum assembly with enclosure	01 01 00	22, 51	4	EA		

25	Furnish and install 12" A-Lok boot connector or approved equal		60	1	LS		
26	Furnish and install 12" Inserta-Tee type fitting or approved equal		61	1	LS		
27	Furnish and install epoxy coating	01 01 00 33 05 14	16	1	LS		
28	Make service connection to SCE utility transformer	01 01 00 25 05 34 26 05 00	Sheet 13, Elec 1	1	LS		
29	Furnish lift station electrical control panel	01 01 00 22 14 23 25 05 34 26 05 00	Sheet 13, Elec 5	1	LS		
30	Install lift station electrical control panel and Unistrut type mounting rack for the mounting of the panel. Make final connections from in field pumps to panel, as well as control cable to appropriate terminal for level control, pump high temp. & pump leak.	01 01 00 22 14 23 25 05 34 26 05 00	Sheet 14, Elec 2, 5	1	LS		
31	Furnish and install SCADA system with back-up battery station and ground rod	01 01 00 22 14 23 26 05 00	45, 46, Elec 4, 7, 8, 9, 10, 11, 12, 13 Sheet 13, 20	1	LS		
32	Furnish and install electrical conduit and wire	01 01 00 25 05 34 26 05 00	Sheet 16	1,300	LF		
33	Furnish and install electrical junction boxes	01 01 00 26 05 00	Sheet 13, Elec 14	1	LS		
34	Furnish and install chain link fence and swing gate	01 01 00	Sheet 3	1	LS		
35	Furnish and install hose bib assembly	01 01 00	Sheet 3	1	LS		
36	Furnish and install shade structure and two LED strip fixtures in wet rated enclosure and connect to wall mounted 120V, 20A wet rated witch for canopy lighting.	01 01 00 05 50 00	Sheet 9, Elec 6	1	LS		
37	Furnish and install site lighting	01 01 00 26 56 00	Sheet 11, Elec 12, 15	1	LS		
38	Restore project site including but not limited to salvaging existing materials, landscape removal and replacement, hardscape replacement, irrigation repair/replacement	01 01 00		1	LS		

	and public and/or private property damage repair/replacement						
39	Furnish, install, operate and maintain temporary sewer bypass pumping	01 01 00 22 14 24		1	LS		
40	Pump station start-up and commissioning	26 05 00		1	LS		
41	Furnish and conduct testing for sewer force main and sewer gravity main including but not limited to air test, hydrostatic testing and deflection testing.	33 01 32		1	LS		
42	Dewatering of excavations and trenches			1	LS		
43	Rechannel of existing 4' diameter manhole and pipe penetration for pipe connection to manhole		30, 32	1	LS		
44	Furnish and install 6-inch DIP Yard Piping and its appurtenances, including bends and 4" x 6" reducer		67, 68, 69	1	LS		
TOTAL BASE BID							\$

The undersigned hereby agrees to furnish all materials, labor, tools, equipment, apparatus, facilities, and transportation necessary to complete all work in strict conformity with the drawings and specifications, and to execute the contract to the satisfaction of the County, at the following cost(s):

Total Base Bid of Items 1-44.....\$_____ (Dollars)

The above-mentioned TOTAL BASE BID includes applicable California state sales tax, bonds, fees, insurance and all other costs required to perform all the work described in the project drawings and specifications.

ADDITIVE BID SCHEDULE No. 1: ANTENNA TOWER							
ITEM	DESCRIPTION	SPEC PAGE	Construction Note	QTY	UNIT	UNIT COST	TOTAL EXTENSION
1	Furnish and install antenna tower		Elec 16 Sheet 17, 18	1	LS		
2	Furnish and install radio panel with Unistrut type mounting rack and enclosure with cradlepoint radio, ethernet/fiber converter		Elec 17 Sheet 14	1	LS		

	and appropriate overcurrent protective devices & all required electrical connections, wire, conduit & trenching.						
	TOTAL ADDITIVE BID No. 1						\$

Total Additive Bid No. 1 - Items 1 – 2: \$ _____ (Dollars)

The above-mentioned ADDITIVE BID No. 1 includes applicable California state sales tax, bonds, fees, insurance and all other costs required to perform all the work described in the project drawings and specifications.

The quantities listed in the Itemized Bid Proposal are only an estimate for each of the items. The actual quantities encountered may be different and compensation will be based on the unit prices established above. In case of discrepancies between the “Unit Cost” and the “Total Extension”, the “Unit Cost” shall prevail.

The District requires bids to include prices for items that may be added to, or deducted from, the scope of work in the contract for which the bid is being submitted. Pursuant to Public Contract Code Section 20103.8(b), for the purpose of determining the lowest bid price, the District shall determine the low bid to be the lowest total of the bid prices on the Total Base Bid plus Additive Bid No. 1 (Total Base Bid + Additive No. 1).

Total Base Bid + Additive Bid No. 1: \$ _____ (Dollars)

If awarded, the contract shall be awarded to the lowest responsive, responsible bidder. This Section does not preclude the District from adding to or deducting any of the additive or deductive items after the lowest responsible bidder has been determined. **Failure to provide a cost for the additive or deductive bid items shall render the bid non-responsive.**