

ADDENDUM NO. 1

South San Bernardino Area ADA Ramps and Storm Drain Installation

November 12, 2025

Page 1 of 4

ADDENDUM NO. 1

SOUTH SAN BERNARDINO AREA ADA RAMPS AND STORM DRAIN INSTALLATION

WORK ORDER: H15031

AREA: SAN BERNARDINO

ROAD NO.: 561600-030, 646300-010, 876050-010, 261000-010, 656050-010 & 561600-020

BIDS OPEN 10:00 AM, THURSDAY, NOVEMBER 13, 2025

BIDS OPEN 11:00 AM, THURSDAY, NOVEMBER 20, 2025

By Email via ePro System

The bid opening will be publicly viewable via goto.com, details are available in the Notice to Bidders pages of the Project Special Provisions.

Amend the Plan Set as follows:

Delete Plan Set Sheets 2-8 and replace with **ATTACHMENT A** "Addendum No. 1 Plan Set Sheets 2-8"

Amend the Project Special Provisions as follows:

1. DIVISION II GENERAL CONSTRUCTION

a. Under **Section 10-1.25 ASPHALT CONCRETE (RAP Optional) (2023 CALTRANS STANDARD SPECIFICATIONS)**, replace the first paragraph under "Replace **Reserved** in Section 39-2.02B(3) "Asphalt Binder" with:", With:

The grade of asphalt binder for Type A HMA must be 1/2-inch and 3/4-inch, Aggregate Gradation, PG 64-28 PM.

b. Under **Section 10-1.25 ASPHALT CONCRETE (RAP Optional) (2023 CALTRANS STANDARD SPECIFICATIONS)**, replace the paragraph under "Replace **Not Used** in Section 39-2.02D "Payment" with:", With:

Quantities of asphalt concrete with/without RAP, will be paid for at the contract unit price per ton for **Asphalt Concrete (Type A, 1/2-inch Aggregate Gradation, PG 64-28 PM)**; and **Asphalt Concrete (Type A, 3/4-inch Aggregate Gradation, PG 64-28 PM)** shall include full compensation for furnishing all labor, materials, tools, equipment and incidentals, and for doing all the work involved in constructing asphalt concrete complete in place, as shown on the plans, and as specified in the Standard Specifications, these special provisions, and as directed by the Engineer.

c. Under **Section 10-1.34 REINFORCED CONCRETE PIPE**, replace the last paragraph that begins "The contract unit price paid per linear foot for 24" RCP (Class IV, D-1500); and 36" RCP (Class IV, D-1500) shall include ..." With:

Full compensation for furnishing all labor, materials, tools, equipment, and incidentals for doing all the work involved in constructing reinforced concrete pipe (RCP), complete in place, including excavation, structure excavation, backfill, structure backfill, disposal of excess excavated material and incidentals

ADDENDUM NO. 1

South San Bernardino Area ADA Ramps and Storm Drain Installation

November 12, 2025

Page 2 of 4

as shown on the plans, shall be considered as included in the prices paid per linear foot for **24" RCP (Class IV, D-1500)** and **36" RCP (Class IV, D-1500)** and no separate payments will be made therefor.

d. Delete Section 10-1.36 STRUCTURE BACKFILL

e. Add Section 10-1.47 TRENCH / EXCAVATION SAFETY:

10-1.47 TRENCH / EXCAVATION SAFETY

This work, Trench/Excavation Safety, shall consist of furnishing, implementing, maintaining and removing protective measures for excavation(s) in excess of five feet, that adequately provide protection from hazards of caving ground, conforming to the provisions in 7-1.02K(6)(b), "Excavation Safety," of the Standard Specifications; Section 6707 of the Labor Code; Section 832 of the Civil Code; Article 6, Subchapter 4, Chapter 4, Title 8 of the California Code Regulations {Construction Safety Orders}; and these Special Provisions.

Unless otherwise certified in writing by a registered civil or structural engineer, all soil type, except bedrock, for the purposes of designing trench/excavation safety measures shall be considered to be Type C. Contractor shall be solely responsible for damages resulting from its failure to prevent collapse or failure of excavations under all load conditions encountered during construction.

The stability of temporary excavations is a function of several factors, including the total time the excavation is exposed, moisture condition, soil type and consistency, and contractor's operations. The Contractor is responsible for excavation safety. As a guideline, temporary construction excavations greater than 3 feet but less 10 feet deep should be planned with slopes no steeper than 1.5H : 1V (Horizontal to Vertical). For steeper temporary construction slopes or deeper excavations, the Contractor shall submit an unexpired shoring plan designed and stamped by a California licensed Professional Civil or Structural Engineer.

Contractor's attention is directed to Section 4-1.05, "Changes and Extra Work", of the Standard Specifications. Provisions in this section pertaining to "Increases" shall not apply to increases in trench/excavation safety measures due to changes in the types of soil or other conditions upon which are based designs of such measures, except as provided in Section 4-1.05B, "Work-Character Changes."

Unless otherwise specified, Contractor shall obtain, at no additional cost to the Department, such licenses, permits, or approvals as may be required from adjacent property owners, and/or owners of easement rights overlying Contractor's work site(s), relating to trench/excavation safety and protection of said owner's property, equipment, or existing facilities from damage arising from caving ground in vicinity of Contractor's excavation(s).

Requirements in Section 7-1.02K(6), "Occupational Safety and Health Standards" of the Standard Specifications to submit a Trench Excavation Safety Plan 5 days (or 3 weeks for an engineered plan) before the Contractor intends to begin excavation shall be considered to be amended to comply with any conditions for necessary permits, licenses, or approvals that exceed said requirements, at no additional cost to the Department.

Entities from which licenses, permits, or approvals shall be obtained for this project are:

- State Department of Industrial Relations, Division of Occupational Safety [Project specific or annual excavation permit].

ADDENDUM NO. 1

South San Bernardino Area ADA Ramps and Storm Drain Installation

November 12, 2025

Page 3 of 4

Reflectors shall be affixed to shoring on all sides facing traffic.

Open trenches or holes will be inspected a minimum of three times per day immediately prior to backfilling.

Payments for meeting the requirements of this section will be based upon lump sum item price(s) shown in the Engineer's Estimate. At the Engineer's sole discretion, linear measure of excavations, volume measure of excavations, or related working days will be used to determine progress and final payments when adequate methods addressed in the Contractor's Trench/Excavation Safety plan have been accomplished and maintained.

Payment for **Trench / Excavation Safety** shall be made at the contract lump sum price and shall include full compensation for furnishing all labor, materials, tools, equipment and incidentals, required to do all the work, including, but not limited to, investigating soil and other conditions, designing, providing, installing and maintaining adequate sheet piling, shoring, bracing, lagging, cribbing, piling, shielding, benching and sloping, to maintain safe working conditions in and around any otherwise unsupported excavation five (5) feet or greater in depth, necessary for workers protection in the course of constructing the work in accordance with the plans, Standard Specifications and these Special Provisions and in accordance with the Contractor's selected methods of construction and no other compensation will be allowed therefor.

Amend the Proposal Pages as follows:

- 1. Delete Proposal Pages P-4 and P-5 and replace with attached ATTACHMENT B "Addendum No. 1 Revised Proposal Pages P-4 and P-5"**

Make the following information available for bidders:

Attachments:

ATTACHMENT A: Addendum No. 1 Plan Set Sheets 2-8

ATTACHMENT B: Addendum No. 1 Revised Proposal Pages P-4 and P-5

ADDENDUM NO. 1

South San Bernardino Area ADA Ramps and Storm Drain Installation

November 12, 2025

Page 4 of 4

The addition of these requirements shall be considered in concert with existing documents in preparation of bids.

THE BIDDER'S CERTIFICATION FOR THIS ADDENDUM NO. 1 SHALL BE SIGNED BY THE SAME PERSON WHO SIGNS THE PROPOSAL AND SHALL BE SUBMITTED WITH THE PROPOSAL. ANY proposal not accompanied by a signed BIDDER'S CERTIFICATION (below) acknowledging receipt of this Addendum No. 1 will NOT be accepted.

NOEL CASTILLO, Director
Department of Public Works



By:

Andy Silao, P.E., Chief
Contracts Division

AS:mb

BIDDER'S CERTIFICATION:

By my signature hereunder, I acknowledge receipt of Addendum No. 1 and I fully understand the intent and detail of Addendum No. 1, which I have considered in my preparation of the attached proposal.

Bidder's Signature

Date

Note: The page containing the executed BIDDER'S CERTIFICATION (just this page), must be included with the proposal.