



SAN BERNARDINO COUNTY
DEPARTMENT OF PUBLIC WORKS
SPECIAL DISTRICTS

ADDENDUM NO. 1

TO THE BIDDING REQUIREMENTS, CONTRACT DOCUMENTS, GENERAL CONDITIONS,
SPECIAL CONDITIONS, AND TECHNICAL SPECIFICATIONS FOR THE
BIG BEAR ALPINE ZOO SHADE STRUCTURES PROJECT
PROJECT NO.: 30.30.0175

September 6, 2024

The Contract Documents for the above referenced project are hereby amended in the following manner and the following manner only:

- I. All provisions of this Addendum No. 1 are hereby incorporated into the Contract Documents, and Bidders shall account for all provisions pursuant to this Addendum No. 1 in submitting their bid proposals. **Each Bidder shall include a dated and signed copy of this Addendum with their sealed bid proposal.**

1. SECTION E – SPECIAL CONDITIONS

Contractors are advised of the following change as it appears within Section E., Special Conditions of the Specifications

- A. Contractors are advised that Section G, Contract Drawings section of the bid package issued on August 15, 2024 (as amended) shall be replaced with:

Section G, Contract Drawings:

SMC1420-CUS

SMC1435-CUS

SCT1474-CUS 8-30-24 - Revised 090524

2. PROJECT SUMMARY OF QUESTIONS AND ANSWERS

- A. **All the plans do not have a foundation detail except the last one with the curved shelter. It shows a 4" concrete slab over the foundations and bolts. Are the other foundations going to be the same?**

The column/footing detail on all other shade structures will be the same. The detail is provided for bidding purposes only and the final size of the footing will be determined by the engineer. There will be no 4" slab over the foundation, please disregard.

- B. **At the job walk there was no talk about concrete slabs how long and wide would they be.**

There will be no 4" slab over the foundation, please disregard.

- C. **Is this structure rated for the snow load requirements needed for this area?**

Yes, snow and wind load will be taken into consideration when stamped engineered drawings and calculations are being completed by engineers at Scenic Shelter.

3. BID OPENING INFORMATION

The following is the information for the **BIG BEAR ALPINE ZOO SHADE STRUCTURES** bid opening. Prompt attendance is required. Allow adequate time to login to the meeting prior to 3:00 PM PST:

Microsoft Teams [Need help?](#)

[Join the meeting now](#)

Meeting ID: 258 776 488 583

Passcode: R8KSkR

Dial in by phone

[+1 661-568-6806,,243733144#](#) United States, Santa Clara

[Find a local number](#)

Phone conference ID: 243 733 144#

For organizers: [Meeting options](#) | [Reset dial-in PIN](#)

The above items modify the informal bid documents in the manner prescribed and in that manner only. All other contract items will remain as originally intended. Contractor will sign/date this addendum and submit with their bid as acknowledgement of receiving and complying with this addendum.

ISSUE DATE: September 6, 2024

Date Acknowledged by Bidder: _____

By: _____

Chuck Hernandez, Project Manager
Department of Public Works - Special Districts
Project Management Division

By: _____

Bidders Company Name

Bidders Signature