

ADDENDUM NO. 1

TO THE BID DOCUMENTS FOR THE
APPLE VALLEY AIRPORT WASH RACK

AT
21600 CORWIN ROAD, IN APPLE VALLEY

The following changes and/or additions shall be made to the plans and/or specifications. All other requirements of the contract documents shall remain the same. The Bidder shall acknowledge receipt of the addendum by inserting its number and date in the Bid Proposal.

Changes to Bid Drawings:

Replace sheet CG 101 with Revised attached sheet.

Pre-Proposal Questions and Answers:

Q1: Sheet CG101 key notes #8 and #9 mention a Jensen vertical flow clarifier and piping but location and size are not specified. Please provide clarification.

A1: There was an error in the printing of sheet CG101, please see revised sheet for clarity and location.

Q2: Please provide clarification on connection for water piping (detail #5).

A2: There was an error in the printing of sheet CG101, please see revised sheet for water pipe callout location.

Q3: Keynote #13 on sheet CG101 calls for new sewer manhole to be constructed. Please provide elevations sewer and new pipe.

A3: Per plans the invert elevation of the new to existing sewer line connection is at 2982.25'. Manhole top of grade is 2989.37'. Depth = 7.12'.

Q4: Please provide depth of new catch basin (keynote #14).

A4: Per plans the invert elevation of the new storm line is at 2985.17'. CB top of grade is 2988.50'. Depth = 3.33'. Per detail A3/CG502 add 2', so at a min. depth = 5.33', not including lining.

Q5: Please provide specifications for items called on keynotes #15,17,18 and 20.

A5: Keynotes #17 and #20 are per Liberty utility specification. Project specifications were provided for keynote #15 and #18.

Q6: There are no Bid Bond forms provided in the bid documents. Is a surety form acceptable?

A6: Surety form or any other bid forms are acceptable.

Replacement and Additional Attached Documents

1. Replacement of Documents

The following attached document(s) shall be replaced in their entirety from versions on the original Bid Package.

- CG101 – Wash Rack Grading Plan

End of Addendum No. 1



Don Day, Director
Project and Facilities Management Department

MM:CB

San Bernardino County
Project and Facilities Management Department
385 N Arrowhead Avenue, Third Floor
San Bernardino, CA 92415-0184
www.sbcounty.gov/ae

DATE: March 12, 2024