



SAN BERNARDINO COUNTY
DEPARTMENT OF PUBLIC WORKS
SPECIAL DISTRICTS



ADDENDUM NO. 2

**TO THE BIDDING REQUIREMENTS, CONTRACT DOCUMENTS, GENERAL CONDITIONS,
SPECIAL CONDITIONS, AND TECHNICAL SPECIFICATIONS FOR THE**

**BIG BEAR RANCH COURT REMOVAL/RENOVATION PROJECT
BIG BEAR SPORTS PARK**

PROJECT NO.: 30.30.0107

April 11, 2022

The Contract Documents for the above referenced project are hereby amended in the following manner and the following manner only:

I. GENERAL

All provisions of this Addendum No. 2 are hereby incorporated into the Contract documents, and Bidders shall account for all provisions pursuant to this Addendum No. 2 in submitting their bid proposals. **Each Bidder shall include a dated and signed copy of this Addendum with their sealed bid proposal.**

1. ITEM NO. 1: CONCRETE SPECS:

Contractors are advised of the following change/addition to Section A., Bid Proposal of the specifications:

- A. The new concrete slab for east court will be 4" thick 2500 psi pea gravel pump mix with 5% air. The change is from 5" to 4" slab from Addendum 1.
- B. Steel reinforcement bars should conform to standard specifications, the bars should be No. 3 in both directions 16" on center. The change is from #5 rebar to #3 rebar.

The above items modify the bid documents in the manner prescribed and, in that manner, only. All other contract items will remain as originally intended. Contractor will sign/date this addendum and submit with their bid as acknowledgement of receiving and complying with this addendum.

ISSUE DATE: April 11, 2022

Date Acknowledged by Bidder: _____

By: _____

Charles Brammer, Project Manager
Department of Public Works - Special Districts
Project Management Division

By: _____

Bidders Company Name

Bidders Signature