



February 21, 2019

# STRUCTURAL DESIGN CALCULATIONS

## **Arrowhead Regional Medical Center Ambulatory Clinic**

Spire Job #: 19SHA11  
400 North Pepper Avenue  
Colton, CA 92324

TI-2019-00049

**County of San Bernardino  
BUILDING AND SAFETY**

THESE PLANS AND DETAILS ARE

**APPROVED**

THE APPROVAL OF THESE PLANS SHALL NOT  
BE CONSTRUED TO BE A PERMIT FOR ANY  
VIOLATION OF ANY CODE OR ORDINANCE OF  
THIS COUNTY

By Eric Rodriguez

Date 06/13/2019

THESE PLANS SHALL BE ON THE JOB FOR  
ALL REQUESTED INSPECTIONS

## **Project Description:**

Provide structural engineering services for the anchorage of miscellaneous equipment on the 2nd Floor of an existing 3-story building.



02.21.19

--- REVIEWED ---  
This review is intended only to verify conformity to the 2016 edition of the California Building Standards. It does not relieve Contractor and Applicant of responsibility for requirements of Project drawings and specifications. No responsibility is assumed for fabrication or construction techniques, correctness of quantities or dimensions, or coordination of work with other trades. Outstanding errors in documents shall not be validated and all codes and laws must be complied with.

Digitally signed by  
Eric Rodriguez, SE  
DN: cn=Eric  
Rodriguez, SE, o=NV5,  
Inc., ou=Energy,  
email=eric.  
rodriguez@nv5.com,  
c=US

Reason: Reviewed for  
Code Compliance.  
Date: 2019.06.12  
09:20:55 -07'00'



Sheet:

|          |                                |                |   |
|----------|--------------------------------|----------------|---|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |                | 1 |
| Calc By: | ISG                            | Date: 02/21/19 |   |

## Table of Contents

### General:

|                                                              | <i>Sheet</i> |
|--------------------------------------------------------------|--------------|
| Table of Contents                                            | 1            |
| USGS Design Maps Summary Report                              | 2            |
| Non-Structural Component Seismic Design - Height Ratio (z/h) | 3            |
| Anchorage to Topside of Concrete - Hilti KB-TZ (ESR-1917)    | 4            |

### Equipment Anchorage:

|                                                          |       |
|----------------------------------------------------------|-------|
| Suspended Ceiling Equipment - Single Procedure Light     | 5-6   |
| Wall Mounted Monitor - 29" TV on Peerless Bracket SA730P | 7-8   |
| Wall Mounted Monitor - 40" TV on Peerless Bracket AT640  | 9-10  |
| Floor Mounted Equipment - Refrigerator (GE)              | 11-12 |
| Floor Mounted Equipment - Warming Cabinet (Steris)       | 13-14 |
| Wall Mounted Monitor - TV on Ergotron Bracket            | 15-16 |
| Suspended Ceiling Equipment - EF-1 & RF-1                | 17-18 |
| Typical Suspended Single Pipe and Conduit Support        | 1     |
| Typical Suspended Pipe and Conduit Trapeze Support       | 20    |
| Typical Wall-Mounted Pipe and Conduit Support            | 21-22 |
| Typical Wall-Mounted Equipment Anchorage                 | 23-24 |
| Typical Unistrut Wall-Mounted Equipment Anchorage        | 25-26 |

### Appendix A: EASE Calcs (Reference Equipment Info)

A1-A15

|          |                                |       |          |   |
|----------|--------------------------------|-------|----------|---|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 2 |
| Calc By: | ISG                            | Date: | 02/21/19 |   |



## Arrowhead Regional Ambulatory Clinic

400 N Pepper Ave, Colton, CA 92324, USA

Latitude, Longitude: 34.0740531, -117.35105900000002



Date

2/13/2019, 4:21:21 PM

Design Code Reference Document

ASCE7-10


Risk Category

II


Site Class

D - Stiff Soil

| Type     | Value | Description                                    |
|----------|-------|------------------------------------------------|
| $S_S$    | 2.02  | $MCE_R$ ground motion. (for 0.2 second period) |
| $S_1$    | 0.905 | $MCE_R$ ground motion. (for 1.0s period)       |
| $S_{MS}$ | 2.02  | Site-modified spectral acceleration value      |
| $S_{M1}$ | 1.358 | Site-modified spectral acceleration value      |
| $S_{DS}$ | 1.347 | Numeric seismic design value at 0.2 second SA  |
| $S_{D1}$ | 0.905 | Numeric seismic design value at 1.0 second SA  |



| Type      | Value | Description                                                                               |
|-----------|-------|-------------------------------------------------------------------------------------------|
| SDC       | F     | Seismic design category                                                                   |
| $F_a$     | 1     | Site amplification factor at 0.2 second                                                   |
| $F_v$     | 1.5   | Site amplification factor at 1.0 second                                                   |
| PGA       | 0.784 | $MCE_G$ peak ground acceleration                                                          |
| $F_{PGA}$ | 1     | Site amplification factor at PGA                                                          |
| $PGA_M$   | 0.784 | Site modified peak ground acceleration                                                    |
| $T_L$     | 8     | Long-period transition period in seconds                                                  |
| $S_{sRT}$ | 2.779 | Probabilistic risk-targeted ground motion. (0.2 second)                                   |
| $S_{sUH}$ | 2.693 | Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration  |
| $S_{sD}$  | 2.02  | Factored deterministic acceleration value. (0.2 second)                                   |
| $S_{1RT}$ | 1.139 | Probabilistic risk-targeted ground motion. (1.0 second)                                   |
| $S_{1UH}$ | 1.154 | Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration. |
| $S_{1D}$  | 0.905 | Factored deterministic acceleration value. (1.0 second)                                   |
| $PGAd$    | 0.784 | Factored deterministic acceleration value. (Peak Ground Acceleration)                     |
| $C_{RS}$  | 1.032 | Mapped value of the risk coefficient at short periods                                     |
| Type      | Value | Description                                                                               |
| $C_{R1}$  | 0.987 | Mapped value of the risk coefficient at a period of 1 s                                   |




|          |                                |       |          |   |
|----------|--------------------------------|-------|----------|---|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 3 |
| Calc By: | ISG                            | Date: | 02/21/19 |   |

## Non-Structural Component Seismic Design - Height Ratio (z/h)

|                      |           |
|----------------------|-----------|
| $n_{top}$ =          | 3         |
| Level <sub>1</sub> = | 2nd Floor |
| Level <sub>0</sub> = | 1st Floor |
| Bsmt. =              | No        |
| Floor =              | 2nd Floor |
| Susp. =              | Yes       |
| Roof =               | No        |

Top floor number  
 First level above grade floor name?  
 Ground level floor name?  
 Basement?  
 What floor is the project on?  
 Suspended equipment?  
 Rooftop equipment?



|          |                                |       |          |   |
|----------|--------------------------------|-------|----------|---|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 4 |
| Calc By: | ISG                            | Date: | 02/21/19 |   |

## Anchorage to Topside of Concrete - Hilti KB-TZ (ESR-1917)

|                      |                |  |  |  |                 |                                                                                         |
|----------------------|----------------|--|--|--|-----------------|-----------------------------------------------------------------------------------------|
| Mark =               | 1              |  |  |  |                 |                                                                                         |
| Conc =               | NWC            |  |  |  |                 |                                                                                         |
| Metal deck =         | Yes            |  |  |  |                 |                                                                                         |
| $f'_c$ =             | 4,000          |  |  |  | psi             | Concrete compressive strength                                                           |
| Anchor =             | CS 3/8 (1 1/2) |  |  |  |                 | Hilti KB-TZ anchor                                                                      |
| Steel Type =         | Carbon         |  |  |  |                 | Carbon steel or Stainless steel                                                         |
| $d_o$ =              | 3/8            |  |  |  | in              | Anchor O.D.                                                                             |
| $h_{ef}$ =           | 1 1/2          |  |  |  | in              | Effective min anchor embedment                                                          |
| $h$ =                | 2 3/4          |  |  |  | in              | Concrete thickness                                                                      |
| $h_{min}$ =          | 2 1/4          |  |  |  | in              | Min member thickness                                                                    |
| $\phi_s$ =           | 0.75           |  |  |  |                 | Seismic reduction per ACI Ch. 17                                                        |
| $\lambda$ =          | 1.0            |  |  |  |                 | LWC reduction per ACI Ch. 17                                                            |
| $k_{cr}$ =           | 17             |  |  |  |                 | Effectiveness factor                                                                    |
| $k_{cp}$ =           | 1              |  |  |  |                 | Coefficient for pryout strength                                                         |
| $N_{p,eq}$ =         | NA             |  |  |  | Lbs             | Adjusted by $(f'_c/2500)^{0.5}$                                                         |
| $N_{p,cr}$ =         | NA             |  |  |  | Lbs             | Adjusted by $(f'_c/2500)^{0.5}$                                                         |
| $N_b$ =              | 1,975          |  |  |  | Lbs             | $= k_{cr} \cdot (f'_c)^{0.5} \cdot h_{ef}^{1.5}$                                        |
| $s_{min}$ =          | 8              |  |  |  | in              | Min anchor spacing                                                                      |
| $c_{min}$ =          | 16             |  |  |  | in              | Min. edge distance                                                                      |
| $A_n$ =              | 20             |  |  |  | in <sup>2</sup> | $= 3h_{ef} \cdot (\min(1.5h_{ef}, s/2) + \min(1.5h_{ef}, c))$                           |
| $A_{no}$ =           | 20             |  |  |  | in <sup>2</sup> | $= 9 \cdot h_{ef}^2$                                                                    |
| $N_{sa}$ =           | 6,500          |  |  |  | lbs             | Steel strength in tension                                                               |
| $V_{sa}$ =           | 2,180          |  |  |  | lbs             | Steel strength in shear                                                                 |
| $\phi P_{n,conc}$ =  | 815            |  |  |  | Lbs             | $= \phi_s \lambda \phi_{t,conc} \cdot \min(N_{p,eq}, N_{p,cr}, N_b) \cdot (A_n/A_{no})$ |
| $\phi V_{n,conc}$ =  | 1,383          |  |  |  | Lbs             | $= \lambda \phi_{v,conc} \cdot k_{cp} \cdot N_b \cdot (A_n/A_{no})$                     |
| $\phi P_{n,steel}$ = | 4,875          |  |  |  | Lbs             | $= \phi_{t,steel} \cdot N_{sa}$                                                         |
| $\phi V_{n,steel}$ = | 1,417          |  |  |  | Lbs             | $= \phi_{v,steel} \cdot V_{sa}$                                                         |
| $\phi_{t,conc}$ =    | 0.55           |  |  |  |                 |                                                                                         |
| $\phi_{v,conc}$ =    | 0.70           |  |  |  |                 |                                                                                         |
| $\phi_{t,steel}$ =   | 0.75           |  |  |  |                 |                                                                                         |
| $\phi_{v,steel}$ =   | 0.65           |  |  |  |                 |                                                                                         |

|          |                                |       |          |   |
|----------|--------------------------------|-------|----------|---|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 5 |
| Calc By: | ISG                            | Date: | 02/21/19 |   |

## Suspended Ceiling Equipment - Single Procedure Light

### DETAIL 1/S301

Design = City  
 $S_{DS} = 1.35$  See USGS Sheet  
 $I_p = 1.0$  ASCE 7 Table 11.5-1


$$F_{pv} = 0.27 W_p (ult) = 0.2 S_{DS} W_p$$

$$F_{ph} (MIN) = 0.41 W_p (ult) = 0.3 S_{DS} I_p W_p$$

|                |      |                 |
|----------------|------|-----------------|
| Mark           | 1    |                 |
| $a_p$          | 2.5  |                 |
| $R_p$          | 2.5  |                 |
| $\Omega_o$     | 2.5  |                 |
| $z/h$          | 0.67 |                 |
| $F_{ph}$       | 1.26 |                 |
| $W_p$          | 47   | Lbs             |
| CG             | 30.2 | in              |
| B              | 24.0 | in              |
| D              | 12.0 | in (min)        |
| S              | 17.0 | in              |
| $n_{RODS}$     | 4    |                 |
| $L_{BOLT}$     | 3.0  | in (max)        |
| BC             | 8.0  | in              |
| $I_{xx, RODS}$ | 144  | in <sup>2</sup> |
| $I_{yy, RODS}$ | 144  | in <sup>2</sup> |
| $I_{zz, RODS}$ | 288  | in <sup>2</sup> |
| $F_{ph}$       | 59   | Lbs (ULT)       |
| $F_{pv}$       | 13   | Lbs (ULT)       |

ASCE 7 Table 13.5-1  
ASCE 7 Table 13.5-1  
ASCE 7 Table 13.5-1  
 $z$  = height of attachment,  $h$  = roof height

$$F_{ph} = \frac{0.4 S_{DS} a_p}{(R_p/I_p)} \left( 1 + 2 \frac{z}{h} \right) W_p$$



### Vertical Hanger Rod Design (See Unistrut Catalog, page 70)

|                  |       |           |
|------------------|-------|-----------|
| $M_{yy}$         | 2,812 | Lbs (ASD) |
| Diameter         | 1/2   | in        |
| $s_{clip}$       | 12    | in oc     |
| %                | 100%  |           |
| T                | 110   | Lbs (ASD) |
| T'               | 3,750 | Lbs (ASD) |
| DCR <sub>T</sub> | 0.03  | < 1.0 OK  |
| C                | 88    | Lbs (ASD) |
| C'               | 3,750 | Lbs (ASD) |
| DCR <sub>C</sub> | 0.02  | < 1.0 OK  |

$$M_{yy} = 0.7 F_{ph} (CG + L_{bolt}) + (W_p + 0.7 F_{pv}) B$$

Rod diameter

Spacing of stiffener cradle clips

Percentage of tensile capacity for compression

Rod Tension

$$T = \frac{(W_p + 0.7 F_{pv})}{n_{RODS}} + \frac{M_{yy} (D/2)}{I_{yy, RODS}} - \frac{0.7 F_{ph}}{2}$$

Rod Tensile Capacity

Rod Compression

$$C = \frac{(0.7 F_{pv} - 0.9 W_p)}{n_{RODS}} + \frac{M_{yy} (D/2)}{I_{yy, RODS}} - \frac{0.7 F_{ph}}{2}$$

Rod Compressive Capacity

### Vertical Hanger Anchorage (Hilti KB-TZ, ICC ESR-1917)

|                      |         |                 |
|----------------------|---------|-----------------|
| $M_{uyy}$            | 6,583   | Lb-in (ULT)     |
| $\alpha$             | 0.75    |                 |
| Stl Deck             | Below   |                 |
| $h_{conc}$           | 4 3/4   | in              |
| $f'_c$               | 4,000   | psi             |
| Conc                 | NWC     |                 |
| $\lambda$            | 1.00    |                 |
| Steel                | Carbon  |                 |
| Dia                  | 1/2     | in              |
| $h_{ef}$             | 2       | in              |
| $h_{min}$            | 4       | in              |
| s                    | 12.0    | in              |
| $s_{min}$            | 2.75    | in              |
| $A_{no}$             | 36.0    | in <sup>2</sup> |
| $A_n$                | 36.0    | in <sup>2</sup> |
| $A_{se}$             | 0.101   | in <sup>2</sup> |
| $F_u$                | 106,000 | psi             |
| $k_{cr}$             | 17      |                 |
| $k_{cp}$             | 1.0     |                 |
| $N_{p,cr}$           | 1,847   | Lbs             |
| $N_b$                | 3,041   | Lbs             |
| $\Omega_o \cdot P_u$ | 217     | Lbs (ULT)       |
| $\phi P_{n,conc}$    | 900     | Lbs (ULT)       |
| $\phi P_{n,steel}$   | 8,030   | Lbs (ULT)       |
| DCR <sub>p</sub>     | 0.24    | < 1.0 OK        |
| DCR <sub>p</sub>     | 0.03    | < 1.0 OK        |


$$M_{uyy} = \Omega_o F_{ph} (CG + L_{bolt}) + (1.2 W_p + F_{pv}) B$$

Seismic reduction per ACI Ch. 17

Concrete thickness  
Concrete strength (2,500 psi min)

|                  |      |
|------------------|------|
| $\phi_{t,conc}$  | 0.65 |
| $\phi_{v,conc}$  | 0.70 |
| $\phi_{t,steel}$ | 0.75 |
| $\phi_{v,steel}$ | 0.65 |

Reduction for LWC  
Carbon or stainless  
Anchor diameter  
Effective embedment  
Minimum concrete thickness  
Anchor spacing  
Minimum anchor spacing  
 $= 9 \cdot h_{ef}^2$   
 $A_n = \min[(3 \cdot h_{ef})(1.5 \cdot h_{ef} + s/2), A_{no}]$   
(assuming no close edges)  
Anchor effective area  
Anchor tensile strength



Concrete breakout strength

Tension Demand

$$= 0.75 \cdot \lambda \cdot \phi_{t,conc} \cdot \min(N_b, N_{p,cr}) (A_n/A_{no})$$

$$= \phi_{t,steel} \cdot A_{se} \cdot f_u$$

$$= \Omega_o P_u / \phi P_{n,conc}$$

$$= \Omega_o P_u / \phi P_{n,steel}$$

$$N_b = k_{cr} \cdot (f'_c)^{0.5} \cdot h_{ef}^{1.5}$$

$$P_u = \frac{(1.2 W_p + F_{pv})}{n_{RODS}} + \frac{M_{uyy} (S/2)}{I_{yy, RODS}} - \frac{\Omega_o \cdot F_{ph}}{2}$$

|          |                                |       |          |   |
|----------|--------------------------------|-------|----------|---|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 6 |
| Calc By: | ISG                            | Date: | 02/21/19 |   |

## DETAIL

## Suspended Ceiling Equipment - Single Procedure Light

1/S301

Bracing Design (Unistrut P1000, Lmax = 9'-6", rmin = 0.577, KL/r = 198, load applied at slotted face, 4 total)

|                   |       |             |                                                                                        |
|-------------------|-------|-------------|----------------------------------------------------------------------------------------|
| M <sub>zz</sub> = | 998   | Lb-in (ASD) | M <sub>zz</sub> = 0.7 · F <sub>ph</sub> · B                                            |
| C =               | 59    | Lbs (ASD)   | $C = \left( \frac{0.7 F_{ph}}{2} + \frac{M_{zz} (D/2)}{I_{zz, RODS}} \right) \sqrt{2}$ |
| C' =              | 1,380 | Lbs (ASD)   | Brace compression capacity, based on 10'-0" length                                     |
| DCR =             | 0.04  | < 1.0 OK    | Unistrut Catalog, pg 20                                                                |

Brace Anchorage (Same anchor parameters as vertical anchor)


|                                   |       |           |                |                                                                                        |
|-----------------------------------|-------|-----------|----------------|----------------------------------------------------------------------------------------|
| Ω <sub>o</sub> · P <sub>u</sub> = | 148   | Lbs (ULT) | Tension Demand | $P_u = V_u = \frac{\Omega_o F_{ph}}{2} + \frac{\Omega_o F_{ph} B (D/2)}{I_{zz, RODS}}$ |
| Ω <sub>o</sub> · V <sub>u</sub> = | 148   | Lbs (ULT) | Shear Demand   |                                                                                        |
| V <sub>s</sub> =                  | 3,000 | Lbs       |                |                                                                                        |
| φV <sub>n, conc</sub> =           | 2,129 | Lbs (ULT) |                | $= \lambda \phi_{v, conc} \cdot k_{cp} \cdot N_b (A_n/A_{no})$                         |
| φV <sub>n, steel</sub> =          | 1,950 | Lbs (ULT) |                | $= \phi_{v, steel} \cdot V_{seis}$                                                     |
| DCR <sub>p</sub> =                | 0.16  | < 1.0 OK  |                | $= \Omega_o P_u / \phi P_{n, conc}$                                                    |
| DCR <sub>v</sub> =                | 0.07  | < 1.0 OK  |                | $= \Omega_o V_u / \phi V_{n, conc}$                                                    |
| DCR <sub>p</sub> =                | 0.02  | < 1.0 OK  |                | $= \Omega_o P_u / \phi P_{n, steel}$                                                   |
| DCR <sub>v</sub> =                | 0.08  | < 1.0 OK  |                | $= \Omega_o V_u / \phi V_{n, steel}$                                                   |
| DCR =                             | 0.06  | < 1.0 OK  |                | $(DCR_{p, max})^{5/3} + (DCR_{v, max})^{5/3} \leq 1.0$                                 |

Bolt/Rod Design (Between Mounting Plates):

|                          |        |                 |  |                                                                                                                                                     |
|--------------------------|--------|-----------------|--|-----------------------------------------------------------------------------------------------------------------------------------------------------|
| Type =                   | A325-X |                 |  | Bolt diameter                                                                                                                                       |
| Diameter d =             | 3/8    | in              |  | Number of bolts                                                                                                                                     |
| n <sub>BOLTS</sub> =     | 3      |                 |  | Bolt Area                                                                                                                                           |
| A <sub>BOLT</sub> =      | 0.110  | in <sup>2</sup> |  | $S_{BOLT} = \pi \cdot (d/2)^2 / 4$                                                                                                                  |
| S <sub>BOLT</sub> =      | 0.005  | in <sup>3</sup> |  |                                                                                                                                                     |
| I <sub>yy, BOLTS</sub> = | 24.0   | in <sup>2</sup> |  |                                                                                                                                                     |
| I <sub>zz, BOLTS</sub> = | 48.0   | in <sup>2</sup> |  |                                                                                                                                                     |
| x =                      | 4.0    | in              |  | Max distance from center of bolt circle - XX axis                                                                                                   |
| y =                      | 3.5    | in              |  | Max distance from center of bolt circle - YY axis                                                                                                   |
| M <sub>zz</sub> =        | 998    | Lb-in (ASD)     |  | $M_{zz} = 0.7 \cdot F_{ph} \cdot B$                                                                                                                 |
| M <sub>yy</sub> =        | 2,812  | Lb-in (ASD)     |  | $M_{yy} = 0.7 F_{ph} (CG + L_{bolt}) + (W_p + 0.7 F_{pv}) B$                                                                                        |
| V =                      | 121    | Lbs (ASD)       |  | $V = \sqrt{\left( \frac{0.7 \cdot F_{ph}}{n_{BOLTS}} + \frac{M_{zz} x}{I_{zz, BOLTS}} \right)^2 + \left( \frac{M_{yy} y}{I_{zz, BOLTS}} \right)^2}$ |
| M <sub>BOLT</sub> =      | 181    | Lb-in (ASD)     |  | $M_{BOLT} = V \cdot (L_{BOLT} / 2)$                                                                                                                 |
| T =                      | 487    | Lbs (ASD)       |  | $T = (M_{yy} \cdot x) / I_{yy, BOLTS} + (W_p + 0.7 F_{pv}) / n_{bolts}$                                                                             |
| f <sub>t</sub> =         | 39.4   | ksi             |  | $f_t = M_{BOLT} / S_{BOLT} + T / A_{BOLT}$                                                                                                          |
| f <sub>v</sub> =         | 1.1    | ksi             |  | $f_v = V / A_{BOLT}$                                                                                                                                |
| F <sub>u</sub> =         | 150    | ksi             |  |                                                                                                                                                     |
| F <sub>t</sub> =         | 56.3   | ksi             |  | $F_t = F_{nt} / \Omega$ (AISC 13 Ed., Pg. 7-23)                                                                                                     |
| F <sub>v</sub> =         | 30.0   | ksi             |  | $F_v = F_{nv} / \Omega$ (AISC 13 Ed., Pg. 7-22)                                                                                                     |
| DCR =                    | 0.74   | < 1.0 OK        |  | $f_t / F_t + f_v / F_v < 1.0$                                                                                                                       |

Mounting Plate Design:

|                          |       |                 |                                                                                                  |
|--------------------------|-------|-----------------|--------------------------------------------------------------------------------------------------|
| t =                      | 1/4   | in (min)        | Plate thickness                                                                                  |
| b =                      | 3.0   | in              | b = 12 t                                                                                         |
| Z =                      | 0.05  | in <sup>3</sup> | Z = b · t <sup>2</sup> / 4                                                                       |
| I <sub>yy, BOLTS</sub> = | 24    | in <sup>2</sup> |                                                                                                  |
| M <sub>yy</sub> =        | 2,595 | Lb-in (ASD)     | $M_{yy} = 0.7 F_{ph} \cdot CG + (W_p + 0.7 F_{pv}) \cdot B$                                      |
| T =                      | 325   | Lbs             | $T = M_{yy} \cdot (BC \cdot 2^{1/2}) / (2 \cdot I_{yy, BOLTS}) + (W_p + 0.7 F_{pv}) / n_{BOLTS}$ |
| C =                      | 287   | Lbs             | $C = M_{yy} \cdot (BC \cdot 2^{1/2}) / (2 \cdot I_{yy, BOLTS}) - (W_p + 0.7 F_{pv}) / n_{BOLTS}$ |
| M =                      | 0.34  | k-in (ASD)      | $M = T \cdot (D - BC / 2) - C \cdot [(D - BC) / (2D)] \cdot (D - BC) / 2$                        |
| M <sub>n</sub> / Ω =     | 1.01  | k-in (ASD)      | $M_n / \Omega = F_y \cdot Z / \Omega$ $F_y = 36$ ksi                                             |
| DCR =                    | 0.33  | < 1.0 OK        |                                                                                                  |



|          |                                |   |
|----------|--------------------------------|---|
| Job:     | 18SHA11 ARMC Ambulatory Clinic | 7 |
| Calc By: | ISG                            |   |
| Date:    | 02/21/19                       |   |

## DETAIL


**Wall Mounted Monitor - 29" TV on Peerless Bracket SA730P**
**3/S301**

## GENERAL INPUT

OPM: 0212-13

(ASD)

|            |               |                                              |
|------------|---------------|----------------------------------------------|
| Design =   | City          |                                              |
| $W_p$ =    | 29 Lbs (max)  | Equip weight (including bracket)             |
| $H$ =      | 6.5 in (min)  | Vert distance between anchors                |
| $B$ =      | 1.6 in (min)  | Distance between anchors and edge of bracket |
| $D$ =      | 23.2 in (max) | Distance to centroid                         |
|            | Equip         | Wall                                         |
| $a_p$ =    | 1.0           | 1.0                                          |
| $R_p$ =    | 1.5           | 2.5                                          |
| $S_{DS}$ = | 1.35          | See USGS sheet                               |
| $I_p$ =    | 1.00          | ASCE 7 Table 1.5-2                           |
| $z_1/h$ =  | 0.33          | 2nd Floor                                    |
| $z_2/h$ =  | 0.67          | 3rd Floor                                    |



## SEISMIC FORCES

|                |      |            |
|----------------|------|------------|
| $F_{ph,min}$ = | 0.28 | $W_p$      |
| $F_{ph,1}$ =   | 0.42 | 0.25 $W_p$ |
| $F_{ph,2}$ =   | 0.59 | 0.35 $W_p$ |
| $F_{ph}$ =     | 0.50 | 0.32 $W_p$ |
| $F_{pv}$ =     | 0.19 | $W_p$      |
| $F_{ph}$ =     | 14   | lbs        |
| $F_{pv}$ =     | 6    | lbs        |

$$F_{ph,min} = 0.7 \cdot 0.3 S_{DS} \cdot I_p \cdot W_p$$

$$F_{ph} = 0.7 \cdot \frac{0.4 S_{DS} a_p}{R_p / I_p} \left( 1 + 2 \frac{z}{h} \right) W_p$$

$$F_{pv} = 0.7 \cdot 0.2 S_{DS} \cdot W_p$$

## FRONT-TO-BACK

|       |     |     |                                                        |
|-------|-----|-----|--------------------------------------------------------|
| $V$ = | 34  | Lbs | $= W_p + F_{pv}$                                       |
| $P$ = | 129 | Lbs | $= [(W_p + F_{pv}) \cdot CG + F_{ph} \cdot (H/2)] / H$ |

## SIDE-TO-SIDE

|       |     |     |                                                           |
|-------|-----|-----|-----------------------------------------------------------|
| $V$ = | 37  | Lbs | $= [(W_p + F_{pv})^2 + F_{ph}^2]^{0.5}$                   |
| $P$ = | 336 | Lbs | $= [(W_p + F_{pv}) \cdot CG] / H + (F_{ph} \cdot CG) / B$ |

## Screws into Backing Plate

|        |                   |
|--------|-------------------|
| SMS =  | 1/4" $\phi$ (min) |
| $V$ =  | 18 Lbs/screw      |
| $P$ =  | 336 Lbs/screw     |
| $V'$ = | 613 Lbs           |
| $P'$ = | 261 Lbs           |
| DCR =  | 1.32 (NG)         |

|              |       |                                                              |
|--------------|-------|--------------------------------------------------------------|
| $n_{wall}$ = | 2     | No. of screws into backing (min)                             |
| Metal =      | 16 ga | backing                                                      |
|              |       | Shear demand (in-plane)                                      |
|              |       | Pull-out                                                     |
|              |       | Screw shear capacity per SSMA allowable loads table, p.60    |
|              |       | Screw pull-out capacity per SSMA allowable loads table, p.60 |
|              |       | $DCR = V/V' + P/P' \leq 1.0$                                 |

## A307 Bolts at Bracket to Backing

|         |              |                                             |
|---------|--------------|---------------------------------------------|
| Metal = | 16 ga        | backing                                     |
| $d$ =   | 1/4 in (min) | Bolt diameter                               |
| $m_f$ = | 0.75         | Modification factor per AISI Table E3.3.1-2 |
| $C$ =   | 3.0          | Bearing factor per AISI Table E3.3.1-1      |
| $P$ =   | 168          | Lbs/bolt                                    |
| $V$ =   | 18           | Lbs/bolt                                    |
| $P'$ =  | 573          | Lbs                                         |
| $V'$ =  | 509          | Lbs                                         |
| DCR =   | 0.33         | $\leq 1.0$ (OK)                             |

|             |        |                                                      |
|-------------|--------|------------------------------------------------------|
| $n_{bkg}$ = | 2      | No. of bolts into backing                            |
| $t$ =       | 0.0566 | in Backing thickness                                 |
|             |        | $(F_u = 45 \text{ ksi}, \Omega = 2.5)$               |
|             |        | $= [m_f \cdot C \cdot d \cdot t \cdot F_u] / \Omega$ |
|             |        | $= [4.2(t^3 \cdot d)^{1/2} \cdot F_u] / \Omega$      |
|             |        | $= \max[P_{F-B}/P', (P_{S-S}/P' + 1)$                |

PLAN



|          |                                |       |          |   |
|----------|--------------------------------|-------|----------|---|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 8 |
| Calc By: | ISG                            | Date: | 02/21/19 |   |

## DETAIL

## Wall Mounted Monitor - 29" TV on Peerless Bracket SA730P

## 3/S301

**Screws into Metal Studs**

|       |      |       |
|-------|------|-------|
| SMS = | #10  | (min) |
| V =   | 3    | Lbs   |
| P =   | 56   | Lbs   |
| V' =  | 613  | Lbs   |
| P' =  | 261  | Lbs   |
| DCR = | 0.22 | (OK)  |

 $n_{wall} = 12$  No. of screws into metal studs  
Metal = 16 ga studs (min)

Shear demand (in-plane)

Pull-out

Screw shear capacity per SSMA allowable loads table, p.60

Screw pull-out capacity per SSMA allowable loads table, p.60

**STUD DESIGN**

|                 |                       |
|-----------------|-----------------------|
| $n_{stud} =$    | 2                     |
| $H_{partial} =$ | 4.0 ft                |
| $W_{p,wall} =$  | 8.0 psf               |
| $s_{stud} =$    | 16 in                 |
| $F_{ph} =$      | 5.0 psf               |
| $w_{wall} =$    | 6.7 plf/stud          |
| $M =$           | 0.6 kip-in            |
| $R_{TOP} =$     | 29 lbs                |
| $R_{BOT} =$     | 29 lbs                |
| Stud =          | 400S125-54 (min)      |
| $S_e =$         | 0.361 in <sup>3</sup> |
| $I_e =$         | 0.830 in <sup>4</sup> |
| $M' =$          | 10.8 kip-in           |
| $\Delta =$      | 0.00 in (L/16146)     |

Number of studs engaged



Height of stud (maximum)

Unit wt of partition wall

Stud spacing

 $= \text{Max}[(F_{ph})(W_{p,wall}), 5\text{psf min}]$ 
 $= F_{ph} \cdot (s_{stud}/12)$ 

Max Moment (per stud)

 $= w_{wall} \cdot H_{stud}/2 + F_{ph} + (W_p + F_{pv}) \cdot (D/12)/H_{stud}$ 
 $= w_{wall} \cdot H_{stud}/2 + F_{ph} + (W_p + F_{pv}) \cdot (D/12)/H_{stud}$ 

**Stud Wall Top & Bot Track Connections (ASD)**

-Connected to a top and bottom track with 2- #10 SMS. Loads are minimal therefore ok by inspection.

-See A7/S601 for additional information.

|          |                                |       |          |   |
|----------|--------------------------------|-------|----------|---|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 9 |
| Calc By: | ISG                            | Date: | 02/21/19 |   |

## DETAIL

## Wall Mounted Monitor - 42" TV on Peerless Bracket ST640

## 4/S301

## GENERAL INPUT

OPM: 0211-13

(ASD)

|            |       |                                            |
|------------|-------|--------------------------------------------|
| Design =   | City  |                                            |
| $W_p$ =    | 50    | Lbs (max) Equip weight (including bracket) |
| $H$ =      | 5.0   | in (min) Vert distance between anchors     |
| $B$ =      | 16.0  | in (min) Horiz distance between anchors    |
| $D$ =      | 6.0   | in Distance to centroid                    |
|            | Equip | Wall                                       |
| $a_p$ =    | 1.0   | 1.0 ASCE 7 Tables 13.5-1                   |
| $R_p$ =    | 1.5   | 2.5 and 13.6-1                             |
| $S_{DS}$ = | 1.35  | See USGS sheet                             |
| $I_p$ =    | 1.00  | ASCE 7 Table 1.5-2                         |
| $z_1/h$ =  | 0.33  | 2nd Floor                                  |
| $z_2/h$ =  | 0.67  | 3rd Floor                                  |



## SEISMIC FORCES

|                |      |            |
|----------------|------|------------|
| $F_{ph,min}$ = | 0.28 | $W_p$      |
| $F_{ph,1}$ =   | 0.42 | 0.25 $W_p$ |
| $F_{ph,2}$ =   | 0.59 | 0.35 $W_p$ |
| $F_{ph}$ =     | 0.50 | 0.32 $W_p$ |
| $F_{pv}$ =     | 0.19 | $W_p$      |
| $F_{ph}$ =     | 25   | lbs        |
| $F_{pv}$ =     | 10   | lbs        |

$$F_{ph,min} = 0.7 \cdot 0.3 S_{DS} \cdot I_p \cdot W_p$$

$$F_{ph} = 0.7 \cdot \frac{0.4 S_{DS} a_p}{R_p / I_p} \left( 1 + 2 \frac{z}{h} \right) W_p$$

$$F_{pv} = 0.7 \cdot 0.2 S_{DS} \cdot W_p$$



## FRONT-TO-BACK

|       |    |     |                                                      |
|-------|----|-----|------------------------------------------------------|
| $V$ = | 60 | Lbs | = $W_p + F_{pv}$                                     |
| $P$ = | 84 | Lbs | = $[(W_p + F_{pv}) \cdot CG + F_{ph} \cdot (H/2)]/H$ |

## SIDE-TO-SIDE

|       |    |     |                                                       |
|-------|----|-----|-------------------------------------------------------|
| $V$ = | 65 | Lbs | = $[(W_p + F_{pv})^2 + F_{ph}^2]^{0.5}$               |
| $P$ = | 81 | Lbs | = $[(W_p + F_{pv}) \cdot CG]/H + (F_{ph} \cdot CG)/B$ |

## Screws into Backing Plate

|       |       |           |
|-------|-------|-----------|
| SMS = | 1/4"φ | (min)     |
| V =   | 16    | Lbs/screw |
| P =   | 42    | Lbs/screw |
| V' =  | 613   | Lbs       |
| P' =  | 261   | Lbs       |
| DCR = | 0.19  | (OK)      |

|              |       |                                                              |
|--------------|-------|--------------------------------------------------------------|
| $n_{wall}$ = | 4     | No. of screws into backing (min)                             |
| Metal =      | 16 ga | backing                                                      |
|              |       | Shear demand (in-plane)                                      |
|              |       | Pull-out                                                     |
|              |       | Screw shear capacity per SSMA allowable loads table, p.60    |
|              |       | Screw pull-out capacity per SSMA allowable loads table, p.60 |
|              |       | DCR = $V/V' + P/P' \leq 1.0$                                 |

## Screws into Metal Studs

|       |      |       |
|-------|------|-------|
| SMS = | #10  | (min) |
| V =   | 4    | Lbs   |
| P =   | 9    | Lbs   |
| V' =  | 613  | Lbs   |
| P' =  | 261  | Lbs   |
| DCR = | 0.04 | (OK)  |

|              |       |                                                              |
|--------------|-------|--------------------------------------------------------------|
| $n_{wall}$ = | 18    | No. of screws into metal studs                               |
| Metal =      | 16 ga | studs (min)                                                  |
|              |       | Shear demand (in-plane)                                      |
|              |       | Pull-out                                                     |
|              |       | Screw shear capacity per SSMA allowable loads table, p.60    |
|              |       | Screw pull-out capacity per SSMA allowable loads table, p.60 |

|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 10 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |


## DETAIL

## Wall Mounted Monitor - 42" TV on Peerless Bracket ST640

## 4/S301

### STUD DESIGN

|               |   |                       |                                                                               |
|---------------|---|-----------------------|-------------------------------------------------------------------------------|
| $n_{stud}$    | = | 3                     | Number of studs engaged                                                       |
| $H_{stud}$    | = | 13.7 ft               | Height of stud (maximum)                                                      |
| $H_{partial}$ | = | 9.5 ft                | Height of stud (partial height wall)                                          |
| $W_{p,wall}$  | = | 8.0 psf               | Unit wt of partition wall                                                     |
| $s_{stud}$    | = | 16 in                 | Stud spacing                                                                  |
| $F_{ph}$      | = | 5.0 psf               | = $\text{Max}[(F_{ph})(W_{p,wall}), 5\text{psf min}]$                         |
| $w_{wall}$    | = | 6.7 plf/stud          | = $F_{ph} \cdot (s_{stud}/12)$                                                |
| $M$           | = | 2.3 kip-in            | Max Moment (per stud)                                                         |
| $R_{TOP}$     | = | 55 lbs                | = $w_{wall} \cdot H_{stud}/2 + F_{ph} + (W_p + F_{pv}) \cdot (D/12)/H_{stud}$ |
| $R_{BOT}$     | = | 55 lbs                | = $w_{wall} \cdot H_{stud}/2 + F_{ph} + (W_p + F_{pv}) \cdot (D/12)/H_{stud}$ |
| Stud          | = | 400S125-54            | (min)                                                                         |
| $S_e$         | = | 0.361 in <sup>3</sup> |                                                                               |
| $I_e$         | = | 0.830 in <sup>4</sup> |                                                                               |
| $M'$          | = | 10.8 kip-in           | = $S_e F_y / \Omega_b, \Omega_b = 1.67$                                       |
| $\Delta$      | = | 0.31 in (L/522)       | Maximum Deflection (Limit to L/120)                                           |



### Stud Wall Top & Bot Track Connections (ASD)

Top Connection: 0.157"φ Hilti X-U w/ 1" Embed (ICC ESR-2269)

Above: NWC o/ Mtl Deck

|           |   |               |                                                |
|-----------|---|---------------|------------------------------------------------|
| $s_{top}$ | = | 24 in         | Anchor spacing at top of wall                  |
| $n_{top}$ | = | 2             | Total number of anchors engaged at top of wall |
| $V$       | = | 82 Lbs/anchor | = $R_{TOP} \cdot (n_{stud}/n_{top})$           |
| $V'$      | = | 90 Lbs/anchor | Shear capacity (ASD)                           |

Top Connection: Braced

|              |   |              |                                                                                                                      |
|--------------|---|--------------|----------------------------------------------------------------------------------------------------------------------|
| $s_{top}$    | = | 48 in        | Brace spacing at top of wall                                                                                         |
| $n_{braces}$ | = | 2            | Total number of braces engaged at top of wall                                                                        |
| $V$          | = | 51 Lbs/brace | = $[w_{wall} \cdot H_{partial}/2 + 0.7F_{ph} + (W_p + 0.7F_{pv}) \cdot (D/12)/H_{partial}] \cdot (n_{stud}/n_{top})$ |

Bottom Connection: 0.157"φ Hilti X-U w/ 1" Embed (ICC ESR-2269)

Below: NWC o/ Mtl Deck

|           |   |               |                                                   |
|-----------|---|---------------|---------------------------------------------------|
| $s_{bot}$ | = | 24 in         | Anchor spacing at bottom of wall                  |
| $n_{bot}$ | = | 2             | Total number of anchors engaged at bottom of wall |
| $V$       | = | 82 Lbs/anchor | = $R_{BOT} \cdot (n_{stud}/n_{bot})$              |
| $V'$      | = | 90 Lbs/anchor | Shear capacity (ASD)                              |

|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 11 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |


## DETAIL

## Floor Mounted Equipment - Refrigerator (GE)

7/S301

|              |        |
|--------------|--------|
| Design =     | City   |
| $a_p$ =      | 1.0    |
| $R_p$ =      | 2.5    |
| $\Omega_o$ = | 2.5    |
| $S_{DS}$ =   | 1.35 g |
| $I_p$ =      | 1.00   |
| $z/h$ =      | 0.33   |

ASCE 7 Table 13.5-1 & Table 13.6-1  
ASCE 7 Table 13.5-1 & Table 13.6-1  
ASCE 7 Table 13.5-1 & Table 13.6-1  
See USGS sheet  
ASCE 7 Table 11.5-1  
2nd Floor




### Dimensions

|         |      |          |                                                |
|---------|------|----------|------------------------------------------------|
| $W_p$ = | 800  | Lbs*     | Equip weight                                   |
| $B$ =   | 39.0 | in       | Dist between anchors (36" + 2·1.5")            |
| $D$ =   | 22.0 | in (min) | Dist between anchors & edge of unit (28"/2+8") |
| $CG$ =  | 36.0 | in       | Dist to centroid                               |
| $n$ =   | 6    | (min)    | No. of anchors                                 |
| $n_t$ = | 3    | (min)    | No. of anchors in tension                      |

\*Wp includes 480 Lbs of contents

\*2 middle anchors count as one anchor



### Forces

|                           |      |       |                                  |
|---------------------------|------|-------|----------------------------------|
| $F_{ph,min}$ =            | 0.41 | $W_p$ | (Governs)                        |
| $F_{ph}$ =                | 0.36 | $W_p$ |                                  |
| $F_{ph}$ =                | 324  | Lbs   |                                  |
| $\Omega_o \cdot F_{ph}$ = | 810  | Lbs   |                                  |
| $F_{pv}$ =                | 0.27 | $W_p$ |                                  |
| $F_{pv}$ =                | 216  | Lbs   |                                  |
| $V_u$ =                   | 54   | Lbs   | Shear per anchor                 |
| $\Omega_o \cdot V_u$ =    | 135  | Lbs   | Shear per anchor w/ $\Omega_o$   |
| $P_u$ =                   | 93   | Lbs   | Tension per anchor               |
| $\Omega_o \cdot P_u$ =    | 358  | Lbs   | Tension per anchor w/ $\Omega_o$ |

$$F_{ph,min} = 0.3 \cdot S_{DS} \cdot I_p \cdot W_p$$

$$F_{ph} = \frac{0.4 S_{DS} a_p}{(R_p / I_p)} \left( 1 + 2 \frac{z}{h} \right) W_p$$

$$F_{pv} = 0.2 \cdot S_{DS} \cdot W_p$$

$$V_u = F_{ph} / n$$

$$\Omega_o \cdot V_u = \Omega_o \cdot F_{ph} / n$$

$$P_{u,1} = (F_{ph} \cdot CG) / [\min(B,D) \cdot n_t] - (0.9W_p - F_{pv}) / n$$

$$\Omega_o \cdot P_{u,1} = (\Omega_o \cdot F_{ph} \cdot CG) / [\min(B,D) \cdot n_t] - (0.9W_p - F_{pv}) / n$$

### Connection of Angle Brackets to Equipment Frame:

|                     |             |                                                        |
|---------------------|-------------|--------------------------------------------------------|
| Fastener =          | Screw       | Type of fastener (Screw or Bolt)                       |
| $n_{conn}$ =        | 1 (min)     | No. of screws per anchorage point                      |
| SMS =               | 1/4" $\phi$ | Size of sheet metal screw                              |
| Metal =             | 20 ga (min) | Equipment frame gauge                                  |
| $t$ =               | 0.0346 in   | Equipment frame thickness                              |
| $F_u$ =             | 45 ksi      | Ultimate strength of steel (min)                       |
| $V_{u,conn}$ =      | 107 Lbs     | Shear demand per screw                                 |
| $\phi V_{n,conn}$ = | 305 Lbs     | Screw shear capacity (per SSMA p.60, converted to ULT) |
| DCR =               | 0.35 (OK)   | $V_{u,conn} / \phi V_{n,conn} \leq 1.0$                |

$$(\Omega = 3.0, \phi = 0.5)$$

$$V_{u,conn} = (P_u^2 + V_u^2)^{1/2} \div n_{conn}$$

### Angle Bracket Design

|                      |           |                 |                                                        |
|----------------------|-----------|-----------------|--------------------------------------------------------|
| $P_u$ =              | 0.1       | kips            | Tension per angle                                      |
| $d$ =                | 4.0       | in (max)        | Distance from bottom of angle to SMS conn.             |
| $b$ =                | 1.5       | in              | Distance from centerline of anchor to angle leg        |
| $p$ =                | 3.0       | in              | Tributary angle width                                  |
| $d_{anchor}$ =       | 3/8       | in              | Anchor diameter                                        |
| $b'$ =               | 1.13      | in              | Distance from edge of hole to center of angle leg      |
| $t_{min}$ =          | 0.07      | in              | Min thickness for no prying action (AISC Section 9-10) |
| $t$ =                | 1/4       | in (min)        | Thickness                                              |
| $M_{u,angle}$ =      | 0.10      | kip-in          | Moment demand                                          |
| $Z$ =                | 0.047     | in <sup>3</sup> | Plastic section modulus                                |
| $F_y$ =              | 36        | ksi             | Yield stress                                           |
| $\phi M_{n,angle}$ = | 1.52      | kip-in          | Moment capacity                                        |
| DCR =                | 0.07 (OK) |                 | $M_{u,angle} / \phi M_{n,angle} \leq 1.0$              |

$$(\phi = 0.90)$$



Sheet:

|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 12 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |

DETAIL

|                                                    |               |
|----------------------------------------------------|---------------|
| <b>Floor Mounted Equipment - Refrigerator (GE)</b> | <b>7/S301</b> |
|----------------------------------------------------|---------------|

Hilti KB-TZ Expansion Anchors: (ICC ESR-1917)

Anchor Mark =  \*

\* See "Anchorage to Topside of Concrete - Hilti KB-TZ (ESR-1917)" calculation sheet for additional info.

|              |                |       |
|--------------|----------------|-------|
| Anchor =     | CS 3/8 (1 1/2) |       |
|              | Concrete       | Steel |
| $\phi P_n =$ | 815            | 4,875 |
| $\phi V_n =$ | 1,383          | 1,417 |
| $DCR_p =$    | 0.44           | 0.07  |
| $DCR_v =$    | 0.10           | 0.10  |

3/8"  $\phi$  Hilti KB-TZ (Carbon Steel) w/ 1 1/2" Embedment

(Concrete tension capacity has been multiplied by 0.75 for seismic)

$$\Omega_o P_u / \phi P_n \leq 1.0$$

$$\Omega_o V_u / \phi V_n \leq 1.0$$

$$DCR_{p+v} = \text{0.27} (DCR_{p,max})^{5/3} + (DCR_{v,max})^{5/3} \leq 1.0$$

|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 13 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |

## DETAIL


## Floor Mounted Equipment - Warming Cabinet (Steris)

8/S301

Design = City

|            |        |
|------------|--------|
| $a_p$      | 1.0    |
| $R_p$      | 2.5    |
| $\Omega_o$ | 2.5    |
| $S_{DS}$   | 1.35 g |
| $I_p$      | 1.00   |
| $z/h$      | 0.00   |

ASCE 7 Table 13.5-1 & Table 13.6-1  
ASCE 7 Table 13.5-1 & Table 13.6-1  
ASCE 7 Table 13.5-1 & Table 13.6-1  
See USGS sheet  
ASCE 7 Table 11.5-1




### Dimensions

|       |               |                                                |
|-------|---------------|------------------------------------------------|
| $W_p$ | 691 Lbs*      | Equip weight                                   |
| $B$   | 33.0 in       | Dist between anchors (30" + 2·1.5")            |
| $D$   | 20.0 in (min) | Dist between anchors & edge of unit (24"/2+8") |
| $CG$  | 37.4 in       | Dist to centroid                               |
| $n$   | 6 (min)       | No. of anchors                                 |
| $n_t$ | 3 (min)       | No. of anchors in tension                      |

\*Wp includes 158 Lbs of contents

\*2 middle anchors count as one anchor



### Forces

|                         |            |                                  |
|-------------------------|------------|----------------------------------|
| $F_{ph,min}$            | 0.41 $W_p$ | (Governs)                        |
| $F_{ph}$                | 0.22 $W_p$ |                                  |
| $F_{ph}$                | 280 Lbs    |                                  |
| $\Omega_o \cdot F_{ph}$ | 700 Lbs    |                                  |
| $F_{pv}$                | 0.27 $W_p$ |                                  |
| $F_{pv}$                | 187 Lbs    |                                  |
| $V_u$                   | 47 Lbs     | Shear per anchor                 |
| $\Omega_o \cdot V_u$    | 117 Lbs    | Shear per anchor w/ $\Omega_o$   |
| $P_u$                   | 102 Lbs    | Tension per anchor               |
| $\Omega_o \cdot P_u$    | 363 Lbs    | Tension per anchor w/ $\Omega_o$ |

$$F_{ph,min} = 0.3 \cdot S_{DS} \cdot I_p \cdot W_p$$

$$F_{ph} = \frac{0.4 S_{DS} a_p}{(R_p / I_p)} \left( 1 + 2 \frac{z}{h} \right) W_p$$

$$F_{pv} = 0.2 \cdot S_{DS} \cdot W_p$$

$$V_u = F_{ph} / n$$

$$\Omega_o \cdot V_u = \Omega_o \cdot F_{ph} / n$$

$$P_{u,1} = (F_{ph} \cdot CG) / [\min(B,D) \cdot n_t] - (0.9W_p - F_{pv}) / n$$

$$\Omega_o \cdot P_{u,1} = (\Omega_o \cdot F_{ph} \cdot CG) / [\min(B,D) \cdot n_t] - (0.9W_p - F_{pv}) / n$$

### Connection of Angle Brackets to Equipment Frame:

|                   |             |                                                        |
|-------------------|-------------|--------------------------------------------------------|
| Fastener          | Screw       | Type of fastener (Screw or Bolt)                       |
| $n_{conn}$        | 1 (min)     | No. of screws per anchorage point                      |
| SMS               | 1/4" $\phi$ | Size of sheet metal screw                              |
| Metal             | 20 ga (min) | Equipment frame gauge                                  |
| $t$               | 0.0346 in   | Equipment frame thickness                              |
| $F_u$             | 45 ksi      | Ultimate strength of steel (min)                       |
| $V_{u,conn}$      | 112 Lbs     | Shear demand per screw                                 |
| $\phi V_{n,conn}$ | 305 Lbs     | Screw shear capacity (per SSMA p.60, converted to ULT) |
| DCR               | 0.37 (OK)   | $V_{u,conn} / \phi V_{n,conn} \leq 1.0$                |

$$(\Omega = 3.0, \phi = 0.5)$$

$$V_{u,conn} = (P_u^2 + V_u^2)^{1/2} \div n_{conn}$$

### Angle Bracket Design

|                    |                       |                                                        |
|--------------------|-----------------------|--------------------------------------------------------|
| $P_u$              | 0.1 kips              | Tension per angle                                      |
| $d$                | 4.0 in (max)          | Distance from bottom of angle to SMS conn.             |
| $b$                | 1.5 in                | Distance from centerline of anchor to angle leg        |
| $p$                | 3.0 in                | Tributary angle width                                  |
| $d_{anchor}$       | 3/8 in                | Anchor diameter                                        |
| $b'$               | 1.13 in               | Distance from edge of hole to center of angle leg      |
| $t_{min}$          | 0.07 in               | Min thickness for no prying action (AISC Section 9-10) |
| $t$                | 1/4 in (min)          | Thickness                                              |
| $M_{u,angle}$      | 0.11 kip-in           | Moment demand                                          |
| $Z$                | 0.047 in <sup>3</sup> | Plastic section modulus                                |
| $F_y$              | 36 ksi                | Yield stress                                           |
| $\phi M_{n,angle}$ | 1.52 kip-in           | Moment capacity                                        |
| DCR                | 0.08 (OK)             | $M_{u,angle} / \phi M_{n,angle} \leq 1.0$              |

$$(\phi = 0.90)$$



Sheet:

|          |                                |                |    |
|----------|--------------------------------|----------------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |                | 14 |
| Calc By: | ISG                            | Date: 02/21/19 |    |

DETAIL

|                                                           |               |
|-----------------------------------------------------------|---------------|
| <b>Floor Mounted Equipment - Warming Cabinet (Steris)</b> | <b>8/S301</b> |
|-----------------------------------------------------------|---------------|

Hilti KB-TZ Expansion Anchors: (ICC ESR-1917)

Anchor Mark =  \*

\* See "Anchorage to Topside of Concrete - Hilti KB-TZ (ESR-1917)" calculation sheet for additional info.

|                                    |                                                                                        |       |                                                      |
|------------------------------------|----------------------------------------------------------------------------------------|-------|------------------------------------------------------|
| Anchor =                           | CS 3/8 (1 1/2)                                                                         |       | 3/8"φ Hilti KB-TZ (Carbon Steel) w/ 1 1/2" Embedment |
|                                    | Concrete                                                                               | Steel |                                                      |
| $\phi P_n =$                       | 815                                                                                    | 4,875 | Lbs                                                  |
| $\phi V_n =$                       | 1,383                                                                                  | 1,417 | Lbs                                                  |
| $DCR_p =$                          | 0.45                                                                                   | 0.07  |                                                      |
| $DCR_v =$                          | 0.08                                                                                   | 0.08  |                                                      |
| $\Omega_o P_u / \phi P_n \leq 1.0$ |                                                                                        |       |                                                      |
| $\Omega_o V_u / \phi V_n \leq 1.0$ |                                                                                        |       |                                                      |
| $DCR_{p+v} =$                      | <input type="text" value="0.28"/> $(DCR_{p,max})^{5/3} + (DCR_{v,max})^{5/3} \leq 1.0$ |       |                                                      |

|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 15 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |

## DETAIL

## Wall Mounted Monitor - TV on Ergotron Bracket

### 9/S301

## GENERAL INPUT

(ASD)

|            |       |           |
|------------|-------|-----------|
| Design =   | City  |           |
| $W_p$ =    | 34    | Lbs (max) |
| $H$ =      | 27.8  | in (min)  |
| $B$ =      | 7.8   | in (min)  |
| $D$ =      | 11.9  | in (max)  |
|            | Equip | Wall      |
| $a_p$ =    | 1.0   | 1.0       |
| $R_p$ =    | 2.5   | 2.5       |
| $S_{DS}$ = | 1.35  |           |
| $I_p$ =    | 1.00  |           |
| $z_1/h$ =  | 0.33  |           |
| $z_2/h$ =  | 0.67  |           |

Equip weight (including bracket)  
 Vert distance between anchors  
 Horiz distance between anchors  
 Distance to centroid  
 ASCE 7 Tables 13.5-1 and 13.6-1  
 See USGS sheet  
 ASCE 7 Table 1.5-2  
 2nd Floor  
 3rd Floor


## SEISMIC FORCES

|                |      |            |
|----------------|------|------------|
| $F_{ph,min}$ = | 0.28 | $W_p$      |
| $F_{ph,1}$ =   | 0.25 | 0.25 $W_p$ |
| $F_{ph,2}$ =   | 0.35 | 0.35 $W_p$ |
| $F_{ph}$ =     | 0.32 | 0.32 $W_p$ |
| $F_{pv}$ =     | 0.19 | $W_p$      |
| $F_{ph}$ =     | 11   | lbs        |
| $F_{pv}$ =     | 7    | lbs        |

$$F_{ph,min} = 0.7 \cdot 0.3 S_{DS} \cdot I_p \cdot W_p$$

$$F_{ph} = 0.7 \cdot \frac{0.4 S_{DS} a_p}{R_p / I_p} \left( 1 + 2 \frac{z}{h} \right) W_p$$

$$F_{pv} = 0.7 \cdot 0.2 S_{DS} \cdot W_p$$



## FRONT-TO-BACK

|       |    |     |                                                      |
|-------|----|-----|------------------------------------------------------|
| $V$ = | 41 | Lbs | = $W_p + F_{pv}$                                     |
| $P$ = | 23 | Lbs | = $[(W_p + F_{pv}) \cdot CG + F_{ph} \cdot (H/2)]/H$ |

## SIDE-TO-SIDE

|       |    |     |                                                       |
|-------|----|-----|-------------------------------------------------------|
| $V$ = | 42 | Lbs | = $[(W_p + F_{pv})^2 + F_{ph}^2]^{0.5}$               |
| $P$ = | 34 | Lbs | = $[(W_p + F_{pv}) \cdot CG]/H + (F_{ph} \cdot CG)/B$ |

PROFILE

PLAN

## Screws into Backing Plate

|       |       |           |
|-------|-------|-----------|
| SMS = | 1/4"φ | (min)     |
| V =   | 10    | Lbs/screw |
| P =   | 17    | Lbs/screw |
| V' =  | 613   | Lbs       |
| P' =  | 261   | Lbs       |
| DCR = | 0.08  | (OK)      |

$n_{wall}$  = 4 No. of screws into backing (min)  
 Metal = 16 ga backing  
 Shear demand (in-plane)  
 Pull-out  
 Screw shear capacity per SSMA allowable loads table, p.60  
 Screw pull-out capacity per SSMA allowable loads table, p.60  
 $DCR = V/V' + P/P' \leq 1.0$

## Screws into Metal Studs

|       |      |       |
|-------|------|-------|
| SMS = | #10  | (min) |
| V =   | 3    | Lbs   |
| P =   | 6    | Lbs   |
| V' =  | 613  | Lbs   |
| P' =  | 261  | Lbs   |
| DCR = | 0.03 | (OK)  |

$n_{wall}$  = 12 No. of screws into metal studs  
 Metal = 16 ga studs (min)  
 Shear demand (in-plane)  
 Pull-out  
 Screw shear capacity per SSMA allowable loads table, p.60  
 Screw pull-out capacity per SSMA allowable loads table, p.60



|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 16 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |


## DETAIL

## Wall Mounted Monitor - TV on Ergotron Bracket

### 9/S301

**STUD DESIGN**

|               |   |                       |                                                                               |
|---------------|---|-----------------------|-------------------------------------------------------------------------------|
| $n_{stud}$    | = | 2                     | Number of studs engaged                                                       |
| $H_{stud}$    | = | 13.7 ft               | Height of stud (maximum)                                                      |
| $H_{partial}$ | = | 9.5 ft                | Height of stud (partial height wall)                                          |
| $W_{p,wall}$  | = | 8.0 psf               | Unit wt of partition wall                                                     |
| $s_{stud}$    | = | 16 in                 | Stud spacing                                                                  |
| $F_{ph}$      | = | 5.0 psf               | = $\text{Max}[(F_{ph})(W_{p,wall}), 5\text{psf min}]$                         |
| $w_{wall}$    | = | 6.7 plf/stud          | = $F_{ph} \cdot (s_{stud}/12)$                                                |
| $M$           | = | 2.3 kip-in            | Max Moment (per stud)                                                         |
| $R_{TOP}$     | = | 52 lbs                | = $w_{wall} \cdot H_{stud}/2 + F_{ph} + (W_p + F_{pv}) \cdot (D/12)/H_{stud}$ |
| $R_{BOT}$     | = | 52 lbs                | = $w_{wall} \cdot H_{stud}/2 + F_{ph} + (W_p + F_{pv}) \cdot (D/12)/H_{stud}$ |
| Stud          | = | 400S125-54            | (min)                                                                         |
| $S_e$         | = | 0.361 in <sup>3</sup> |                                                                               |
| $I_e$         | = | 0.830 in <sup>4</sup> |                                                                               |
| $M'$          | = | 10.8 kip-in           | = $S_e F_y / \Omega_b, \Omega_b = 1.67$                                       |
| $\Delta$      | = | 0.26 in (L/633)       | Maximum Deflection (Limit to L/120)                                           |


**Stud Wall Top & Bot Track Connections (ASD)**

Top Connection: 0.157"φ Hilti X-U w/ 1" Embed (ICC ESR-2269)

Above: NWC o/ Mtl Deck

|           |   |               |                                                |
|-----------|---|---------------|------------------------------------------------|
| $s_{top}$ | = | 24 in         | Anchor spacing at top of wall                  |
| $n_{top}$ | = | 2             | Total number of anchors engaged at top of wall |
| $V$       | = | 52 Lbs/anchor | = $R_{TOP} \cdot (n_{stud}/n_{top})$           |
| $V'$      | = | 90 Lbs/anchor | Shear capacity (ASD)                           |

Top Connection: Braced

|              |   |              |                                                                                                                      |
|--------------|---|--------------|----------------------------------------------------------------------------------------------------------------------|
| $s_{top}$    | = | 48 in        | Brace spacing at top of wall                                                                                         |
| $n_{braces}$ | = | 2            | Total number of braces engaged at top of wall                                                                        |
| $V$          | = | 34 Lbs/brace | = $[w_{wall} \cdot H_{partial}/2 + 0.7F_{ph} + (W_p + 0.7F_{pv}) \cdot (D/12)/H_{partial}] \cdot (n_{stud}/n_{top})$ |

Bottom Connection: 0.157"φ Hilti X-U w/ 1" Embed (ICC ESR-2269)

Below: NWC o/ Mtl Deck

|           |   |               |                                                   |
|-----------|---|---------------|---------------------------------------------------|
| $s_{bot}$ | = | 24 in         | Anchors spacing at bottom of wall                 |
| $n_{bot}$ | = | 2             | Total number of anchors engaged at bottom of wall |
| $V$       | = | 52 Lbs/anchor | = $R_{BOT} \cdot (n_{stud}/n_{bot})$              |
| $V'$      | = | 90 Lbs/anchor | Shear capacity (ASD)                              |

|          |                                |       |          |
|----------|--------------------------------|-------|----------|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          |
| Calc By: | ISG                            | Date: | 02/21/19 |

17

DETAIL

## Suspended Ceiling Equipment- (EF-1 & RF-1)

See Mech Dwgs


Design = City  
 $S_{DS} = 1.35$  See USGS sheet  
 $I_p = 1.0$  ASCE 7 Table 11.5-1

| Mark | Description              |
|------|--------------------------|
| EF-1 | Exhaust Fan (Cook SQL-B) |
| RF-1 | Exhaust Fan (Cook SQL-B) |

$$F_{pv} = 0.27 W_p (ULT) = 0.2 S_{DS} \cdot W_p$$

$$F_{ph (MIN)} = 0.41 W_p (ULT) = 0.3 S_{DS} \cdot I_p \cdot W_p$$

$$= \frac{0.4 S_{DS} a_p}{(R_p / I_p)} \left( 1 + 2 \frac{z}{h} \right) W_p$$



Assumptions & Dimensions:

| Mark                    | EF-1     | RF-1     |             |
|-------------------------|----------|----------|-------------|
| Equipment               | Flexible | Flexible |             |
| Isolators               | Yes      | Yes      |             |
| $a_p$                   | 2.5      | 2.5      |             |
| $R_p$                   | 2.5      | 2.5      |             |
| $\Omega_o$              | 2.5      | 2.5      |             |
| $z/h$                   | 0.67     | 0.67     |             |
| $F_{ph}$                | 1.26     | 1.26     | $W_p (ULT)$ |
| $W_p$                   | 208      | 431      | Lbs         |
| $B$                     | 24.8     | 47.4     | in          |
| $D$                     | 32.9     | 52.5     | in          |
| $H$                     | 26.9     | 46.5     | in          |
| $CG$                    | 13.5     | 23.3     | in          |
| $F_{ph}$                | 263      | 545      | Lbs (ULT)   |
| $\Omega_o \cdot F_{ph}$ | 657      | 1,362    | Lbs (ULT)   |
| $F_{pv}$                | 56       | 116      | Lbs (ULT)   |

ASCE 7 Table 13.6-1

ASCE 7 Table 13.6-1

$z$  = height of attachment  
 $h$  = roof height  
 Equipment weight  
 Equipment width  
 Equipment depth  
 Equipment height  
 Center of gravity (CG) height  
 Lateral seismic force  
 Lateral seismic force (w/ overstrength factor)  
 Vertical seismic force

Equipment Screw Conn to P1538A (Unistrut Angle) on Trapeze

|            |       |       |           |
|------------|-------|-------|-----------|
| Screws     | #12   | #12   |           |
| Stl. Gage  | 18 ga | 18 ga |           |
| $n_{conn}$ | 8     | 8     |           |
| $V$        | 23    | 48    | Lbs (ASD) |
| $V'$       | 124   | 124   | Lbs (ASD) |
| $T$        | 14    | 25    | Lbs (ASD) |
| $T'$       | 263   | 263   | Lbs (ASD) |
| DCR        | 0.24  | 0.48  |           |

Sheet metal screws (SMS)  
 Base material thickness  
 Number of screws to equipment (total)  
 $= 0.7 F_{ph} / n_{conn}$   
 Screw shear capacity (SSMA Catalog pg. 60)  
 $= [0.7 F_{ph} \cdot CG - (0.6 W_p - 0.7 F_{pv}) \cdot (\min(B, D) / 2)] / (\min(B, D) \cdot n_{conn} / 2)$   
 Screw Pullout Capacity (SSMA Catalog pg. 60)  
 $= V / V' + T / T' < 1.0$

Equipment Spring Nut Conn to Trapeze

|            |      |      |           |
|------------|------|------|-----------|
| Diameter   | 1/4  | 1/4  | in        |
| $n_{HHCS}$ | 4    | 4    |           |
| $P$        | 29   | 49   | Lbs (ASD) |
| $V$        | 46   | 95   | Lbs (ASD) |
| $P'$       | 600  | 600  | Lbs (ASD) |
| $V'$       | 300  | 300  | Lbs (ASD) |
| DCR        | 0.20 | 0.40 |           |


HHCS diameter  
 Number of HHCS to unistrut (total)  
 $= [0.7 F_{ph} \cdot CG - (0.6 W_p - 0.7 F_{pv}) \cdot (\min(B, D) / 2)] / (\min(B, D) \cdot n_{conn} / 2)$   
 $= 0.7 F_{ph} / n_{conn}$   
 Spring nut pull-out capacity  
 Spring nut shear capacity  
 $= V / V' + T / T' < 1.0$

Unistrut Trapeze

|               |            |           |                 |
|---------------|------------|-----------|-----------------|
| Unistrut      | P1000      | P1000     |                 |
| $n_{trapeze}$ | 2          | 2         |                 |
| $L$           | 36         | 48        | in (min)        |
| $w$           | 41         | 64        | plf             |
| $M$           | 556        | 1,537     | Lb-in (ASD)     |
| $M'$          | 5,080      | 5,080     | Lb-in (ASD)     |
| $I$           | 0.185      | 0.185     | in <sup>4</sup> |
| $\Delta$      | 0.014      | 0.069     | in              |
|               | $L / 2571$ | $L / 698$ | (L/240 Max)     |

Total number of trapeze  
 Total length of trapeze  
 $w = (W_p + 0.7 F_{pv}) / (n_{trapeze} \times L)$

Total load deflection



|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 18 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |

## DETAIL

|                                                       |                     |
|-------------------------------------------------------|---------------------|
| <b>Suspended Ceiling Equipment- (EF-1 &amp; RF-1)</b> | <b>See Mech Dwg</b> |
|-------------------------------------------------------|---------------------|

## Vertical Hanger Rod Design (See Unistrut Catalog, page 70)


|                     |       |       |  |           |
|---------------------|-------|-------|--|-----------|
| Diameter =          | 1/2   | 1/2   |  | in        |
| s <sub>clip</sub> = | 12    | 12    |  | in oc     |
| %                   | 100%  | 100%  |  |           |
| n <sub>rods</sub> = | 4     | 4     |  |           |
| M =                 | 2,478 | 8,864 |  | Lb-in     |
| T =                 | 296   | 603   |  | Lbs (ASD) |
| T' =                | 1,350 | 1,350 |  | Lbs (ASD) |
| DCR <sub>T</sub> =  | 0.22  | 0.45  |  |           |
| C =                 | 213   | 430   |  | Lbs (ASD) |
| C' =                | 1,350 | 1,350 |  | Lbs (ASD) |
| DCR <sub>C</sub> =  | 0.16  | 0.32  |  |           |

Rod diameter  
Spacing of stiffener cradle clips  
Percentage of tensile capacity for compression  
Number of rods per trapeze  
Overturning moment =  $0.7F_{ph} \cdot CG$   
Rod tension =  $M/(2 \cdot \min[B,D]) + (W_p + 0.7F_{pv})/n_{rods} + 0.7F_{ph}$   
Rod tensile capacity  
Rod compression =  $M/(2 \cdot \min[B,D]) + (0.7F_{pv} - 0.6W_p)/n_{rods} + 0.7F_{ph}$   
Rod compressive capacity

## Anchorage to Underside of Concrete - Hilti KB-TZ (ICC ESR-1917)

|                                   |                |                |  |                 |
|-----------------------------------|----------------|----------------|--|-----------------|
| Conc =                            | NWC            | NWC            |  |                 |
| Metal deck =                      | W2 Deck        | W2 Deck        |  |                 |
| f <sub>c</sub> =                  | 4,000          | 4,000          |  | psi             |
| Anchor =                          | CS 1/2 (3 1/4) | CS 1/2 (3 1/4) |  |                 |
| Steel Type =                      | Carbon         | Carbon         |  |                 |
| d <sub>a</sub> =                  | 1/2            | 1/2            |  | in              |
| h <sub>ef</sub> =                 | 3 1/4          | 3 1/4          |  | in              |
| h =                               | 4 3/4          | 4 3/4          |  | in              |
| h <sub>min</sub> =                | 4 5/8          | 4 5/8          |  | in              |
| φ <sub>s</sub> =                  | 0.75           | 0.75           |  |                 |
| λ =                               | N/A            | N/A            |  |                 |
| k <sub>cr</sub> =                 | 17             | 17             |  |                 |
| k <sub>cp</sub> =                 | 2              | 2              |  |                 |
| N <sub>p,cr</sub> <sup>1</sup> =  | 3,025          | 3,025          |  | Lbs             |
| N <sub>b</sub> =                  | 6,299          | 6,299          |  | Lbs             |
| s <sub>min</sub> =                | 9 3/4          | 9 3/4          |  | in              |
| c <sub>min</sub> =                | 7 1/2          | 7 1/2          |  | in              |
| A <sub>n</sub> =                  | 95             | 95             |  | in <sup>2</sup> |
| A <sub>no</sub> =                 | 95             | 95             |  | in <sup>2</sup> |
| N <sub>sa</sub> =                 | 10,705         | 10,705         |  | lbs             |
| V <sub>sa,eq</sub> <sup>2</sup> = | 4,945          | 4,945          |  | lbs             |
| φP <sub>n,conc</sub> =            | 1,475          | 1,475          |  | Lbs             |
| φV <sub>n,conc</sub> =            | N/A            | N/A            |  | Lbs             |
| φP <sub>n,steel</sub> =           | 8,029          | 8,029          |  | Lbs             |
| φV <sub>n,steel</sub> =           | 3,214          | 3,214          |  | Lbs             |

Normal or lightweight concrete  
Concrete over metal deck?  
Concrete compressive strength  
Hilti KB-TZ anchor  
Carbon steel or Stainless steel  
Anchor O.D.  
Effective min anchor embedment  
Concrete thickness  
Min member thickness  
Seismic reduction per ACI App. D  
LWC reduction per ACI App. D  
Effectiveness factor  
Coefficient for pryout strength



$= k_{cr} \cdot (f'_c)^{0.5} \cdot h_{ef}^{1.5}$   
Min anchor spacing  
Min. edge distance  
 $= 3h_{ef} \cdot (\min(1.5h_{ef}/s/2) + \min(1.5h_{ef}/c))$   
 $= 9 \cdot h_{ef}^2$   
Steel strength in tension  
Steel strength in shear  
 $= \phi_s \lambda \phi_{t,conc} \cdot \min(N_{p,cr}, N_b) \cdot (A_n/A_{no})$   
 $= \lambda \phi_{v,conc} \cdot k_{cp} \cdot N_b \cdot (A_n/A_{no})$   
 $= \phi_{t,steel} \cdot N_{sa}$   
 $= \phi_{v,steel} \cdot V_{sa}$

|                        |      |
|------------------------|------|
| φ <sub>t,conc</sub> =  | 0.65 |
| φ <sub>v,conc</sub> =  | 0.70 |
| φ <sub>t,steel</sub> = | 0.75 |
| φ <sub>v,steel</sub> = | 0.65 |

- <sup>1</sup> If anchor is into concrete over metal deck this value refers to "N<sub>p,deck,cr</sub>"  
<sup>2</sup> If anchor is into concrete over metal deck this value refers to "V<sub>sa,deck,eq</sub>"

## Vertical Hanger Anchorage (Hilti KB-TZ, ICC ESR-1917)

|                                   |      |      |  |           |
|-----------------------------------|------|------|--|-----------|
| n =                               | 1    | 2    |  | (min)     |
| Ω <sub>o</sub> · P <sub>u</sub> = | 778  | 802  |  | Lbs (ULT) |
| DCR <sub>P,conc</sub> =           | 0.53 | 0.54 |  |           |
| DCR <sub>P,steel</sub> =          | 0.10 | 0.10 |  |           |

Total number of anchors  
Tension =  $(\Omega_o \cdot F_{ph} \cdot CG)/(2 \cdot \min[B,D]) + 1.2W_p + F_{pv})/n_{rods} + \Omega_o \cdot F_{ph}$   
 $\Omega_o P_u / \phi P_{n,conc} \leq 1.0$   
 $\Omega_o P_u / \phi P_{n,steel} \leq 1.0$

## Cable Bracing Design


|            |       |       |  |           |
|------------|-------|-------|--|-----------|
| Diameter = | 1/8   | 1/8   |  | in        |
| T =        | 260   | 539   |  | Lbs (ASD) |
| T' =       | 1,000 | 1,000 |  | Lbs (ASD) |
| DCR =      | 0.26  | 0.54  |  |           |

Prestretched Aircraft cable diameter  
Tension per cable =  $(0.7F_{ph}) \cdot 2^{0.5}$   
Per ASHRAE

## Brace Anchorage (Same anchor parameters as vertical anchor)

|                                   |      |      |  |           |
|-----------------------------------|------|------|--|-----------|
| n =                               | 1    | 2    |  | (min)     |
| Ω <sub>o</sub> · P <sub>u</sub> = | 657  | 681  |  | Lbs (ULT) |
| Ω <sub>o</sub> · V <sub>u</sub> = | 657  | 340  |  | Lbs (ULT) |
| DCR <sub>P,conc</sub> =           | 0.45 | 0.46 |  |           |
| DCR <sub>V,conc</sub> =           | N/A  | N/A  |  |           |
| DCR <sub>P,steel</sub> =          | 0.08 | 0.08 |  |           |
| DCR <sub>V,steel</sub> =          | 0.20 | 0.11 |  |           |
| DCR <sub>P+V</sub> =              | 0.33 | 0.30 |  |           |

Total number of anchors  
Tension Demand =  $\Omega_o \cdot F_{ph}/n$   
Shear Demand =  $\Omega_o \cdot F_{ph}/n$   
 $\Omega_o P_u / \phi P_{n,conc} \leq 1.0$   
 $\Omega_o V_u / \phi V_{n,conc} \leq 1.0$   
 $\Omega_o P_u / \phi P_{n,steel} \leq 1.0$   
 $\Omega_o V_u / \phi V_{n,steel} \leq 1.0$   
 $\max[DCR_{P,conc}, DCR_{P,steel}]^{5/3} + \max[DCR_{V,conc}, DCR_{V,steel}]^{5/3} \leq 1.0$



|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 19 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |

## DETAIL

## Typical Suspended Single Pipe/Conduit Support Under Concrete over Steel Deck

4/S101

|                   |        |
|-------------------|--------|
| Design =          | City   |
| S <sub>DS</sub> = | 1.35 g |
| a <sub>p</sub> =  | 2.5    |
| R <sub>p</sub> =  | 6.0    |
| Ω <sub>o</sub> =  | 2.5    |

See USGS sheet  
ASCE 7 Table 13.6-1  
ASCE 7 Table 13.6-1  
ASCE 7 Table 13.6-1

$$I_p = 1.00 \quad (1.5 \text{ for essential or hazardous})$$


$$F_{pv} = 0.27 W_{p(ULT)} = 0.2 S_{DS} \cdot W_p$$

$$F_{ph(MIN)} = 0.41 W_{p(ULT)} = 0.3 S_{DS} \cdot I_p \cdot W_p$$

$$F_{ph} = \frac{0.4 S_{DS} a_p}{(R_p / I_p)} \left( 1 + 2 \frac{z}{h} \right) W_p$$

|                                    |      |
|------------------------------------|------|
| z/h =                              | 0.67 |
| F <sub>ph(calc)</sub> =            | 0.53 |
| F <sub>ph</sub> =                  | 0.53 |
| Ω <sub>o</sub> · F <sub>ph</sub> = | 1.32 |
| Φ <sub>PIPE</sub> =                | 4    |
| W <sub>PIPE</sub> =                | 16.3 |
| S <sub>HGR</sub> =                 | 10.0 |
| S <sub>TRANS</sub> =               | 20.0 |
| S <sub>LONG</sub> =                | 40.0 |
| W <sub>PIPE</sub> =                | 163  |
| F <sub>ph</sub> =                  | 172  |
| Ω <sub>o</sub> · F <sub>ph</sub> = | 429  |
| F <sub>pv</sub> =                  | 44   |

z = height of attachment, h = roof height  
ASCE 7 (13.3-1)  
Governing F<sub>ph</sub> coefficient  
Pipe diameter  
Std pipe full of water used  
Hanger spacing  
Transverse brace spacing  
Longitudinal brace spacing (pairs)  
= W<sub>PIPE</sub> (S<sub>HGR</sub>)  
= F<sub>ph</sub> W<sub>PIPE</sub> (S<sub>TRANS</sub>/S<sub>HGR</sub>)  
= Ω<sub>o</sub> · F<sub>ph</sub> W<sub>PIPE</sub> (S<sub>TRANS</sub>/S<sub>HGR</sub>)  
= F<sub>pv</sub> W<sub>PIPE</sub>



### Vertical Hanger Rod Design (See Unistrut Catalog, page 70)

|                     |       |           |
|---------------------|-------|-----------|
| Diameter =          | 1/2   | in        |
| S <sub>clip</sub> = | 12    | in oc     |
| % =                 | 100%  |           |
| T =                 | 314   | Lbs (ASD) |
| T' =                | 1,350 | Lbs (ASD) |
| DCR <sub>T</sub> =  | 0.23  |           |
| C =                 | 4     | Lbs (ASD) |
| C' =                | 1,350 | Lbs (ASD) |
| DCR <sub>C</sub> =  | 0.00  |           |


Rod diameter  
Spacing of stiffener cradle clips  
Percentage of tensile capacity for compression  
Rod tension T = W<sub>p</sub> + 0.7 F<sub>pv</sub> + 0.7 F<sub>ph</sub>  
Rod tensile capacity

Rod compression C = 0.7 F<sub>ph</sub> + 0.7 F<sub>pv</sub> - 0.9 W<sub>p</sub>  
Rod compression capacity

### Vertical Hanger Anchorage (Hilti KB-TZ, ICC ESR-1917, Table 5)

|                        |                |  |  |     |
|------------------------|----------------|--|--|-----|
| Conc =                 | NWC            |  |  |     |
| Metal deck =           | W2 Deck        |  |  |     |
| $f'_c$ =               | 4,000          |  |  | psi |
| Anchor =               | CS 1/2 (3 1/4) |  |  |     |
| Steel Type =           | Carbon         |  |  |     |
| $d_o$ =                | 1/2            |  |  | in  |
| $h_{ef}$ =             | 3 1/4          |  |  | in  |
| $h$ =                  | 2 3/4          |  |  | in  |
| $h_{min,top}$ =        | 2 5/8          |  |  | in  |
| $\phi_s$ =             | 0.75           |  |  |     |
| $N_{p,deck,cr}$ =      | 3,025          |  |  | Lbs |
| $s_{min}$ =            | 2 3/8          |  |  | in  |
| $c_{min}$ =            | 2 3/8          |  |  | in  |
| $N_{sa}$ =             | 10,705         |  |  | lbs |
| $V_{sa,deck,eq}$ =     | 4,945          |  |  | lbs |
| $\phi P_{n,conc}$ =    | 1,475          |  |  | Lbs |
| $\phi P_{n,steel}$ =   | 8,029          |  |  | Lbs |
| $\phi V_{n,steel}$ =   | 3,214          |  |  | Lbs |
| $\Omega_o \cdot P_u$ = | 669            |  |  | Lbs |
| $DCR_{P,conc}$ =       | 0.45           |  |  |     |
| $DCR_{P,steel}$ =      | 0.08           |  |  |     |

Normal or lightweight concrete  
Figure 5A  
Concrete compressive strength  
Hilti KB-TZ anchor  
Carbon steel or Stainless steel  
Anchor O.D.  
Effective min anchor embedment  
Concrete thickness o/ deck  
Min concrete thickness o/ deck per section 4.1.10  
Seismic reduction per ACI Ch.17  
= N<sub>p,cr</sub> (f<sub>c</sub>/3000)  
Min anchor spacing per sections  
Min. edge distance  
Steel strength in tension (table 3 or 4)  
Steel strength in shear  
= Φ<sub>s</sub> · Φ<sub>t,conc</sub> · N<sub>p,deck,cr</sub>  
= Φ<sub>t,steel</sub> · N<sub>sa</sub>  
= Φ<sub>v,steel</sub> · V<sub>sa,deck,eq</sub>  
Tension demand Ω<sub>o</sub> · P<sub>u</sub> = 1.2 W<sub>p</sub> + F<sub>pv</sub> + Ω<sub>o</sub> · F<sub>ph</sub>  
Ω<sub>o</sub> · P<sub>u</sub> / Φ<sub>P<sub>n,conc</sub></sub> ≤ 1.0  
Ω<sub>o</sub> · P<sub>u</sub> / Φ<sub>P<sub>n,steel</sub></sub> ≤ 1.0



Note: All values are calculated based on tabulated values found in ICC-ESR 1917. Based on this report, concrete breakout and shear are not applicable. See Table 5, footnote 8 for additional information. No reduction for LWC required per section 4.1.12, last paragraph.

### Bracing Design (Unistrut P1000, Lmax = 9'-6", r<sub>min</sub> = 0.577, KL/r = 198, load applied at slotted face)


|       |       |           |
|-------|-------|-----------|
| C =   | 170   | Lbs (ASD) |
| C' =  | 1,200 | Lbs (ASD) |
| DCR = | 0.14  |           |

Brace compression C = (0.7 F<sub>ph</sub>) · 2<sup>0.5</sup>  
Brace compression capacity, based on 10'-0" length, pg 4-6

### Brace Anchorage (Same anchor parameters as vertical anchor)

|                                   |      |     |
|-----------------------------------|------|-----|
| Ω <sub>o</sub> · P <sub>u</sub> = | 429  | Lbs |
| Ω <sub>o</sub> · V <sub>u</sub> = | 429  | Lbs |
| DCR <sub>P,conc</sub> =           | 0.29 |     |
| DCR <sub>P,steel</sub> =          | 0.05 |     |
| DCR <sub>V,steel</sub> =          | 0.13 |     |
| DCR <sub>P+V,steel</sub> =        | 0.04 |     |

Tension demand Ω<sub>o</sub> · P<sub>u</sub> = Ω<sub>o</sub> · F<sub>ph</sub>  
Shear Demand Ω<sub>o</sub> · V<sub>u</sub> = Ω<sub>o</sub> · F<sub>ph</sub>  
Ω<sub>o</sub> · P<sub>u</sub> / Φ<sub>P<sub>n,conc</sub></sub> ≤ 1.0  
Ω<sub>o</sub> · P<sub>u</sub> / Φ<sub>P<sub>n,steel</sub></sub> ≤ 1.0  
Ω<sub>o</sub> · V<sub>u</sub> / Φ<sub>V<sub>n,steel</sub></sub> ≤ 1.0  
(Ω<sub>o</sub> · P<sub>u</sub> / Φ<sub>P<sub>n,steel</sub></sub>)<sup>5/3</sup> + (Ω<sub>o</sub> · V<sub>u</sub> / Φ<sub>V<sub>n,steel</sub></sub>)<sup>5/3</sup> ≤ 1.0



|          |                                |    |
|----------|--------------------------------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic | 20 |
| Calc By: | ISG                            |    |
| Date:    | 02/21/19                       |    |

DETAIL

Typical Suspended Pipe/Conduit Trapeze Support Under Concrete over Steel Deck 5/S101

Design = City

|                 |      |                      |
|-----------------|------|----------------------|
| S <sub>DS</sub> | 1.35 | See USGS sheet       |
| a <sub>p</sub>  | 2.5  | ASCE 7 Tables 13.6-1 |
| R <sub>p</sub>  | 6.0  | ASCE 7 Tables 13.6-1 |
| Ω <sub>0</sub>  | 2.0  | ASCE 7 Table 13.6-1  |

|                       |      |                                                                         |
|-----------------------|------|-------------------------------------------------------------------------|
| I <sub>p</sub>        | 1.00 | ASCE 7 Table 11.5-1                                                     |
| F <sub>pv</sub>       | 0.27 | W <sub>p</sub> (ULT) = 0.2S <sub>DS</sub> W <sub>p</sub>                |
| F <sub>ph</sub> (MIN) | 0.41 | W <sub>p</sub> (ULT) = 0.3S <sub>DS</sub> I <sub>p</sub> W <sub>p</sub> |

|                                |      |                      |
|--------------------------------|------|----------------------|
| z/h                            | 0.67 |                      |
| F <sub>ph</sub> (calc)         | 0.53 | W <sub>p</sub> (ULT) |
| F <sub>ph</sub>                | 0.53 | W <sub>p</sub> (ULT) |
| Ω <sub>0</sub> F <sub>ph</sub> | 1.05 | W <sub>p</sub> (ULT) |
| W <sub>PIPES</sub>             | 35   | plf                  |
| S <sub>TRAPEZE</sub>           | 10   | ft                   |
| S <sub>TRANS</sub>             | 20   | ft                   |
| S <sub>LONG</sub>              | 40   | ft                   |
| W <sub>PIPES</sub>             | 350  | Lbs                  |
| W <sub>TRAPEZE</sub>           | 5    | Lbs                  |
| W <sub>TOTAL</sub>             | 355  | Lbs                  |
| F <sub>ph</sub>                | 374  | Lbs (ULT)            |
| Ω <sub>0</sub> F <sub>ph</sub> | 748  | Lbs (ULT)            |
| F <sub>pv</sub>                | 96   | Lbs (ULT)            |

z = height of attachment, h = roof height  
ASCE 7 (13.3-1)  
Governing F<sub>ph</sub> coefficient  $F_{ph} = \frac{0.4S_{DS}a_p}{(R_p/I_p)} \left(1 + 2\frac{z}{h}\right) W_p$


Total Linear Weight of Pipes  
Trapeze Linear Spacing (in Plan)  
Transverse brace spacing  
Longitudinal brace spacing (pairs)  
Weight of Pipes on Horiz. Unistrut  
Weight of Unistrut Framing & Misc  
= W<sub>PIPES</sub> + W<sub>TRAPEZE</sub>  
= F<sub>ph</sub> W<sub>TOTAL</sub> (S<sub>TRANS</sub>/S<sub>TRAPEZE</sub>)  
= Ω<sub>0</sub> F<sub>ph</sub> W<sub>TOTAL</sub> (S<sub>TRANS</sub>/S<sub>TRAPEZE</sub>)  
= F<sub>pv</sub> W<sub>TOTAL</sub>

Unistrut Trapeze (ASD)

|                 |       |                 |
|-----------------|-------|-----------------|
| Unistrut        | P1000 |                 |
| L               | 4.0   | ft (max)        |
| w               | 106   | plf             |
| M               | 2,533 | Lb-in (ASD)     |
| M'              | 5,080 | Lb-in (ASD)     |
| I               | 0.185 | in <sup>4</sup> |
| Δ <sub>DL</sub> | 0.10  | in              |
|                 | L/504 | (L/240 Max)     |

$\Delta_{DL} = (W_{TOTAL} + 0.7F_{pv})/L$   
 $\Delta_{DL} = (w/12) \cdot L^2/8$   
(Per Unistrut Catalog p. 24)

Dead load deflection  
(L/240 Max)



Vertical Hanger Rod Design (See Unistrut Catalog, page 70)


|                   |       |           |
|-------------------|-------|-----------|
| Diameter          | 1/2   | in        |
| S <sub>clip</sub> | 12    | in oc     |
| %                 | 100%  |           |
| T                 | 473   | Lbs (ASD) |
| T'                | 1,350 | Lbs (ASD) |
| DCR <sub>T</sub>  | 0.35  |           |
| C                 | 335   | Lbs (ASD) |
| C'                | 1,350 | Lbs (ASD) |
| DCR <sub>C</sub>  | 0.25  |           |

Rod diameter  
Spacing of stiffener cradle clips  
Percentage of tensile capacity for compression  
Rod Tension  $T = (W_p + 0.7F_{pv})/2 + 0.7F_{ph}$   
Rod Tensile Capacity  
Rod Compression  $C = 0.7F_{ph} + (0.6W_p - 0.7F_{pv})/2$   
Rod Compressive Capacity

Vertical Hanger Anchorage (Hilti KB-TZ, ICC ESR-1917)

|                               |                |     |
|-------------------------------|----------------|-----|
| Conc                          | NWC            |     |
| Metal deck                    | W2 Deck        |     |
| f <sub>c</sub>                | 4,000          | psi |
| Anchor                        | CS 1/2 (3 1/4) |     |
| Steel Type                    | Carbon         |     |
| d <sub>a</sub>                | 1/2            | in  |
| h <sub>el</sub>               | 3 1/4          | in  |
| h                             | 2 3/4          | in  |
| h <sub>min, top</sub>         | 2 5/8          | in  |
| φ <sub>s</sub>                | 0.75           |     |
| N <sub>p, deck, cr</sub>      | 3,025          | Lbs |
| S <sub>min</sub>              | 2 3/8          | in  |
| C <sub>min</sub>              | 2 3/8          | in  |
| N <sub>sa</sub>               | 10,705         | lbs |
| V <sub>sa, deck, eq</sub>     | 4,945          | lbs |
| φP <sub>n, conc</sub>         | 1,475          | Lbs |
| φP <sub>n, steel</sub>        | 8,029          | Lbs |
| φV <sub>n, steel</sub>        | 3,214          | Lbs |
| Ω <sub>0</sub> P <sub>u</sub> | 1,009          | Lbs |
| DCR <sub>P, conc</sub>        | 0.68           |     |
| DCR <sub>P, steel</sub>       | 0.13           |     |

Normal or lightweight concrete  
Figure 5A  
Concrete compressive strength  
Hilti KB-TZ anchor  
Carbon steel or Stainless steel  
Anchor O.D.  
Effective min anchor embedment  
Concrete thickness o/ deck  
Min concrete thickness o/ deck per section 4.1.10  
Seismic reduction per ACI Ch.17  
 $= N_{p, cr} (f_c/3000)$   
Min anchor spacing per sections  
Min. edge distance  
Steel strength in tension (table 3 or 4)  
Steel strength in shear  
 $= \phi_s \lambda \phi_{L, conc} N_{p, deck, cr}$   
 $= \phi_{L, steel} N_{sa}$   
 $= \phi_{V, steel} V_{sa, deck, eq}$   
Tension Demand  $\Omega_0 P_u = (1.2W_p + F_{pv})/2 + \Omega_0 F_{ph}$   
 $\Omega_0 P_u / \phi P_{n, conc} \leq 1.0$   
 $\Omega_0 P_u / \phi P_{n, steel} \leq 1.0$



|                       |      |
|-----------------------|------|
| φ <sub>L, steel</sub> | 0.75 |
| φ <sub>V, steel</sub> | 0.65 |
| φ <sub>L, conc</sub>  | 0.65 |

Note: All values are calculated based on tabulated values found in ICC-ESR 1917. Based on this report, concrete breakout and shear are not applicable. See Table 5, footnote 8 for additional information. No reduction for LWC required per section 4.1.12, last paragraph.

Bracing Design (Unistrut P1000, Lmax = 9'-6", rmin = 0.577, KL/r = 198, load applied at slotted face)


|     |       |           |
|-----|-------|-----------|
| C   | 370   | Lbs (ASD) |
| C'  | 1,380 | Lbs (ASD) |
| DCR | 0.27  |           |

$C = (0.7F_{ph}) \cdot 2^{0.5}$   
Brace compression capacity, based on 10'-0" length  
Unistrut Catalog, pg 20

Brace Anchorage (Same anchor parameters as vertical anchor)

|                               |      |     |
|-------------------------------|------|-----|
| Ω <sub>0</sub> P <sub>u</sub> | 748  | Lbs |
| Ω <sub>0</sub> V <sub>u</sub> | 748  | Lbs |
| DCR <sub>P, conc</sub>        | 0.51 |     |
| DCR <sub>P, steel</sub>       | 0.09 |     |
| DCR <sub>V, steel</sub>       | 0.23 |     |
| DCR <sub>P+V, steel</sub>     | 0.11 |     |

Tension demand  $\Omega_0 P_u = \Omega_0 F_{ph}$   
Shear Demand  $\Omega_0 V_u = \Omega_0 F_{ph}$   
 $\Omega_0 P_u / \phi P_{n, conc} \leq 1.0$   
 $\Omega_0 P_u / \phi P_{n, steel} \leq 1.0$   
 $\Omega_0 V_u / \phi V_{n, steel} \leq 1.0$   
 $(\Omega_0 P_u / \phi P_{n, steel})^{5/3} + (\Omega_0 V_u / \phi V_{n, steel})^{5/3} \leq 1.0$



|          |                                |    |
|----------|--------------------------------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic | 21 |
| Calc By: | ISG                            |    |
| Date:    | 02/21/19                       |    |

## Typical Wall-Mounted Pipe/Conduit Unistrut Support

DETAIL

10/S101

### Seismic Input

|          |      |                                 |
|----------|------|---------------------------------|
| Design = | City |                                 |
| $a_p$    | 2.5  | ASCE 7 Tables 13.5-1 and 13.6-1 |
| $R_p$    | 6.0  | See USGS sheet                  |
| $S_{DS}$ | 1.35 | ASCE 7 Table 11.5-1             |
| $I_p$    | 1.00 | Floor below (2nd Floor)         |
| $z_1/h$  | 0.33 | Floor above (3rd Floor)         |
| $z_2/h$  | 0.67 |                                 |

### Weight & Dimensions

|             |     |           |                                                      |
|-------------|-----|-----------|------------------------------------------------------|
| $W_{pipes}$ | 100 | Lbs (max) | Total weight of pipes/conduit @ strut support        |
| $W_{strut}$ | 5   | Lbs (max) | Weight of strut support                              |
| $W_p$       | 105 | Lbs (max) | Total weight ( $W_{pipes} + W_{strut}$ )             |
| $H$         | 24  | in (min)  | Distance between top & bottom screws                 |
| $D$         | 5   | in (max)  | Distance from face of wall to center of pipe/conduit |

### Seismic Forces

|              |      |       |                                     |
|--------------|------|-------|-------------------------------------|
| $F_{ph,min}$ | 0.41 | $W_p$ | $= 0.3S_{DS} \cdot I_p \cdot W_p$   |
| $F_{ph,1}$   | 0.37 | $W_p$ | $F_{ph}$ at floor below ( $z_1/h$ ) |
| $F_{ph,2}$   | 0.53 | $W_p$ | $F_{ph}$ at floor above ( $z_2/h$ ) |
| $F_{ph,avg}$ | 0.45 | $W_p$ | Average of $F_{ph,1}$ & $F_{ph,2}$  |
| $F_{ph}$     | 0.45 | $W_p$ | Max of $F_{ph,min}$ & $F_{ph,avg}$  |
| $F_{pv}$     | 0.27 | $W_p$ | $= 0.2S_{DS} \cdot W_p$             |
| $F_{ph}$     | 47   | Lbs   | Horizontal seismic force            |
| $F_{pv}$     | 28   | Lbs   | Vertical seismic force              |

### Screws into Stud

|                       |       |      |
|-----------------------|-------|------|
| SMS =                 | 1/4"φ |      |
| V <sub>VERT</sub> =   | 42    | Lbs  |
| V <sub>HORIZ</sub> =  | 11    | Lbs  |
| P <sub>F-B</sub> =    | 37    | Lbs  |
| P <sub>S-S</sub> =    | 26    | Lbs  |
| V' <sub>VERT</sub> =  | 613   | Lbs  |
| V' <sub>HORIZ</sub> = | 613   | Lbs  |
| P' =                  | 261   | Lbs  |
| DCR =                 | 0.21  | (OK) |

|       |       |                                      |
|-------|-------|--------------------------------------|
| $n$   | 3     | No. of screws at strut to stud (min) |
| Metal | 16 ga | studs (min)                          |

|                                            |                                               |
|--------------------------------------------|-----------------------------------------------|
| Shear per screw (vertical, gravity loads)  | $= (W_p + 0.7F_{pv}) \div n$                  |
| Shear per screw (horizontal, side-to-side) | $= 0.7F_{ph} \div n$                          |
| Tension per screw (front-to-back)          | $= (W_p + 0.7F_{pv}) \cdot D/H + 0.7F_{ph}/n$ |
| Tension per screw (side-to-side)           | $= (W_p + 0.7F_{pv}) \cdot D/H$               |

Screw shear capacity per SSMA allowable loads table, p.60

Screw shear capacity per SSMA allowable loads table, p.60

Screw pull-out capacity per SSMA allowable loads table, p.60

$$DCR = \max \left( \left( \frac{V_{VERT}}{V'_{VERT}} + \frac{P_{F-B}}{P'} \right), \left( \frac{V_{VERT}}{V'_{VERT}} + \frac{V_{HORIZ}}{V'_{HORIZ}} + \frac{P_{S-S}}{P'} \right) \right) \leq 1.0$$

### Stud Design

|                  |            |        |
|------------------|------------|--------|
| $H_{stud}$       | 13.7       | ft     |
| $H_{partial}$    | 9.5        | ft     |
| $W_{p,wall}$     | 8.0        | psf    |
| $s_{stud}$       | 16         | in     |
| Stud             | 400S125-54 | (min)  |
| $S_e$            | 0.361      | $in^3$ |
| $I_e$            | 0.830      | $in^4$ |
| $M'$             | 10.8       | kip-in |
| $0.7F_{ph,wall}$ | 2.5        | psf    |
| Live             | 5.0        | psf    |

Height of stud (maximum)

Height of stud (partial height wall)

Unit wt of partition wall

Stud spacing

$$= S_e F_y / \Omega_b, \Omega_b = 1.67$$



$$= 0.7(0.45) W_{p,wall}$$

### Load Case 1: (D+0.7E)


|               |      |                 |                                                                                                 |
|---------------|------|-----------------|-------------------------------------------------------------------------------------------------|
| $W_{wall}$    | 3.4  | plf / stud      | $= 0.7F_{ph,wall} \cdot (s_{stud}/12)$                                                          |
| $R_{TOP}$     | 60   | Lbs / stud      | $= W_{wall} \cdot H_{stud}/2 + 0.7F_{ph} + (W_p + 0.7F_{pv}) \cdot (D/12)/H_{stud}$             |
| $R_{PARTIAL}$ | 55   | Lbs / stud      | $= W_{wall} \cdot H_{partial}/2 + 0.7F_{ph} + (W_p + 0.7F_{pv}) \cdot (D/12)/H_{partial}$       |
| $R_{BOT}$     | 60   | Lbs / stud      | $= W_{wall} \cdot H_{stud}/2 + 0.7F_{ph} + (W_p + 0.7F_{pv}) \cdot (D/12)/H_{stud}$             |
| $M$           | 2.6  | kip-in          | $= W_{wall} \cdot H_{stud}^2/8 + 0.7F_{ph} \cdot H_{stud}/4 + (W_p + 0.7F_{pv}) \cdot (D/12)/2$ |
| $DCR_M$       | 0.24 | $\leq 1.0$ (OK) | $= M/M' \leq 1.0$                                                                               |
| $\Delta$      | 0.24 | in (L/694)      | Maximum Deflection (Limit to L/120)                                                             |

### Load Case 2: (D+L)

|               |      |                 |                                                                 |
|---------------|------|-----------------|-----------------------------------------------------------------|
| $W_{wall}$    | 6.7  | plf / stud      | $= Live \cdot (s_{stud}/12)$                                    |
| $R_{TOP}$     | 49   | Lbs / stud      | $= W_{wall} \cdot H_{stud}/2 + W_p \cdot (D/12)/H_{stud}$       |
| $R_{PARTIAL}$ | 36   | Lbs / stud      | $= W_{wall} \cdot H_{partial}/2 + W_p \cdot (D/12)/H_{partial}$ |
| $R_{BOT}$     | 49   | Lbs / stud      | $= W_{wall} \cdot H_{stud}/2 + W_p \cdot (D/12)/H_{stud}$       |
| $M$           | 2.1  | kip-in          | $= W_{wall} \cdot H_{stud}^2/8 + W_p \cdot (D/12)/2$            |
| $DCR_M$       | 0.20 | $\leq 1.0$ (OK) | $= M/M' \leq 1.0$                                               |
| $\Delta$      | 0.22 | in (L/754)      | Maximum Deflection (Limit to L/120)                             |



MAX MOMENT



MAX END REACTIONS

|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 22 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |

|                                                    |         |
|----------------------------------------------------|---------|
| Typical Wall-Mounted Pipe/Conduit Unistrut Support | 10/S101 |
|----------------------------------------------------|---------|

**Connections at Top Track of Full-Height Wall - Load Case 1: (D+0.7E) Governs**

|                                     |                                                                                                  |
|-------------------------------------|--------------------------------------------------------------------------------------------------|
| NWC o/ Mtl Deck                     | Type of existing floor/roof structure above                                                      |
| Conn <sub>(E)</sub> = PAF           | Existing connections at top track are power-actuated fasteners (PAF)                             |
| s <sub>(E)</sub> = 24 in            | Spacing of existing PAF along top track of full-height wall (max)                                |
| n <sub>(E)</sub> = 1                | Number of existing PAF resisting out-of-plane reaction from pipe/conduit loads                   |
| V <sub>(5 psf)</sub> = 68 Lbs / PAF | Existing shear demand at top of wall (based on 5 psf out-of-plane live load)                     |
| V <sub>wall</sub> = 34 Lbs / PAF    | Shear demand at top of wall from uniform wall loads (based on 2.5 psf out-of-plane seismic load) |
| V <sub>pipe</sub> = 37 Lbs / PAF    | Additional shear demand from pipe/conduit only (based on Load Case 1)                            |
| V <sub>(E)</sub> = 71 Lbs / PAF     | = V <sub>wall</sub> + V <sub>pipe</sub>                                                          |
| V' <sub>(E)</sub> = 90 Lbs          | 0.157" $\phi$ Hilti X-U w/ 1" Embed (ICC ESR-2269)                                               |
| DCR = 0.79 $\leq$ 1.0 (OK)          | = V <sub>(E)</sub> /V' <sub>(E)</sub> $\leq$ 1.0                                                 |

**Braces at Top Track of Partial-Height Wall - Load Case 1: (D+0.7E) Governs**

|                                       |                                                                                                                             |
|---------------------------------------|-----------------------------------------------------------------------------------------------------------------------------|
| s <sub>brace</sub> = 48 in            | Spacing of existing braces along top track of partial-height wall (max)                                                     |
| n <sub>brace</sub> = 1                | Number of existing braces resisting out-of-plane reaction at top track (min)                                                |
| V <sub>(5 psf)</sub> = 95 Lbs / brace | Existing horizontal reaction force at brace (based on 5 psf out-of-plane live load)                                         |
| V <sub>wall</sub> = 48 Lbs / brace    | Horizontal reaction force at brace from uniform wall loads (based on 2.5 psf out-of-plane seismic load)                     |
| V <sub>pipe</sub> = 39 Lbs / brace    | Additional horizontal reaction force at brace from pipe/conduit only (based on Load Case 1)                                 |
| V <sub>brace</sub> = 87 Lbs / brace   | = V <sub>wall</sub> + V <sub>pipe</sub> 87 Lbs $\leq$ 95 Lbs (from 5 psf live), therefore braces are adequate by inspection |

**Connections at Bottom Track - Load Case 1: (D+0.7E) Governs**

|                                     |                                                                                                     |
|-------------------------------------|-----------------------------------------------------------------------------------------------------|
| NWC o/ Mtl Deck                     | Type of existing floor structure below                                                              |
| Conn <sub>(E)</sub> = PAF           | Existing connections at bottom track are power-actuated fasteners (PAF)                             |
| s <sub>(E)</sub> = 24 in            | Spacing of existing PAF along bottom track (max)                                                    |
| n <sub>(E)</sub> = 1                | Number of existing PAF resisting out-of-plane reaction from pipe/conduit loads                      |
| V <sub>(5 psf)</sub> = 68 Lbs / PAF | Existing shear demand at bottom of wall (based on 5 psf out-of-plane live load)                     |
| V <sub>wall</sub> = 34 Lbs / PAF    | Shear demand at bottom of wall from uniform wall loads (based on 2.5 psf out-of-plane seismic load) |
| V <sub>pipe</sub> = 37 Lbs / PAF    | Additional shear demand from pipe/conduit only (based on Load Case 1)                               |
| V <sub>(E)</sub> = 71 Lbs / PAF     | = V <sub>wall</sub> + V <sub>pipe</sub>                                                             |
| V' <sub>(E)</sub> = 90 Lbs          | 0.157" $\phi$ Hilti X-U w/ 1" Embed (ICC ESR-2269)                                                  |
| DCR = 0.79 $\leq$ 1.0 (OK)          | = V <sub>(E)</sub> /V' <sub>(E)</sub> $\leq$ 1.0                                                    |

|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 23 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |

## DETAIL

## Typical Wall-Mounted Equipment (150 Lbs max)

12/S101

### Seismic Input

Design = City

|            |      |                         |
|------------|------|-------------------------|
| $a_p$ =    | 2.5  | ASCE 7 Tables 13.5-1    |
| $R_p$ =    | 6.0  | and 13.6-1              |
| $S_{DS}$ = | 1.35 | See USGS sheet          |
| $I_p$ =    | 1.00 | ASCE 7 Table 11.5-1     |
| $z_1/h$ =  | 0.33 | Floor below (2nd Floor) |
| $z_2/h$ =  | 0.67 | Floor above (3rd Floor) |


### Weight & Dimensions

|         |     |           |                                                     |
|---------|-----|-----------|-----------------------------------------------------|
| $W_p$ = | 150 | Lbs (max) | Equipment weight                                    |
| $H$ =   | 8.0 | in (min)  | Height between top & bottom connections to backing  |
| $B$ =   | 6.0 | in (min)  | Width between left and right connections to backing |
| $D$ =   | 8.0 | in (max)  | Depth to centroid                                   |

### Seismic Forces

|                |      |       |                                     |
|----------------|------|-------|-------------------------------------|
| $F_{ph,min}$ = | 0.41 | $W_p$ | $= 0.3S_{DS} \cdot I_p \cdot W_p$   |
| $F_{ph,1}$ =   | 0.37 | $W_p$ | $F_{ph}$ at floor below ( $z_1/h$ ) |
| $F_{ph,2}$ =   | 0.53 | $W_p$ | $F_{ph}$ at floor above ( $z_2/h$ ) |
| $F_{ph,avg}$ = | 0.45 | $W_p$ | Average of $F_{ph,1}$ & $F_{ph,2}$  |
| $F_{ph}$ =     | 0.45 | $W_p$ | Max of $F_{ph,min}$ & $F_{ph,avg}$  |
| $F_{pv}$ =     | 0.27 | $W_p$ | $= 0.2S_{DS} \cdot W_p$             |
| $F_{ph}$ =     | 68   | Lbs   | Horizontal seismic force            |
| $F_{pv}$ =     | 41   | Lbs   | Vertical seismic force              |

$$F_{ph} = \frac{0.4S_{DS}a_p}{R_p/I_p} \left(1 + 2\frac{z}{h}\right) W_p$$



### Screws into Backing


|             |       |                                                                     |       |                                                                          |
|-------------|-------|---------------------------------------------------------------------|-------|--------------------------------------------------------------------------|
| SMS =       | 1/4"φ | $n_{bkg}$ =                                                         | 4     | No. of screws into backing (min)                                         |
| $V_{F-B}$ = | 45    | Metal =                                                             | 16 ga | backing (min)                                                            |
| $V_{S-S}$ = | 46    | Shear per screw (front-to-back)                                     |       | $= (W_p + 0.7F_{pv}) \div n_{bkg}$                                       |
| $P_{F-B}$ = | 101   | Shear per screw (side-to-side)                                      |       | $= [(W_p + 0.7F_{pv})^2 + 0.7F_{ph}^2]^{0.5} \div n_{bkg}$               |
| $P_{S-S}$ = | 121   | Tension per screw (front-to-back)                                   |       | $= [(W_p + 0.7F_{pv}) \cdot D/H + 0.7F_{ph}/2] \div (n_{bkg}/2)$         |
| $V'$ =      | 613   | Tension per screw (side-to-side)                                    |       | $= [(W_p + 0.7F_{pv}) \cdot D/H + 0.7F_{ph} \cdot D/B] \div (n_{bkg}/2)$ |
| $P'$ =      | 261   | Screw shear capacity per SSMA allowable loads table, p.90           |       |                                                                          |
| DCR =       | 0.54  | Screw pull-out capacity per SSMA allowable loads table, p.90        |       |                                                                          |
|             |       | $= \max[V_{F-B}/V' + P_{F-B}/P', V_{S-S}/V' + P_{S-S}/P'] \leq 1.0$ |       |                                                                          |

### Screws into Metal Studs

|             |      |                                                                     |       |                                                                           |
|-------------|------|---------------------------------------------------------------------|-------|---------------------------------------------------------------------------|
| SMS =       | #10  | $n_{wall}$ =                                                        | 18    | No. of screws into metal studs (min)                                      |
| $V_{F-B}$ = | 10   | Metal =                                                             | 16 ga | studs (min)                                                               |
| $V_{S-S}$ = | 10   | Shear per screw (front-to-back)                                     |       | $= (W_p + 0.7F_{pv}) \div n_{wall}$                                       |
| $P_{F-B}$ = | 22   | Shear per screw (side-to-side)                                      |       | $= [(W_p + 0.7F_{pv})^2 + 0.7F_{ph}^2]^{0.5} \div n_{wall}$               |
| $P_{S-S}$ = | 27   | Tension per screw (front-to-back)                                   |       | $= [(W_p + 0.7F_{pv}) \cdot D/H + 0.7F_{ph}/2] \div (n_{wall}/2)$         |
| $V'$ =      | 534  | Tension per screw (side-to-side)                                    |       | $= [(W_p + 0.7F_{pv}) \cdot D/H + 0.7F_{ph} \cdot D/B] \div (n_{wall}/2)$ |
| $P'$ =      | 198  | Screw shear capacity per SSMA allowable loads table, p.90           |       |                                                                           |
| DCR =       | 0.15 | Screw pull-out capacity per SSMA allowable loads table, p.90        |       |                                                                           |
|             |      | $= \max[V_{F-B}/V' + P_{F-B}/P', V_{S-S}/V' + P_{S-S}/P'] \leq 1.0$ |       |                                                                           |

### Stud Design

|                  |   |                       |                                            |
|------------------|---|-----------------------|--------------------------------------------|
| $n_{stud}$       | = | 3                     | Number of studs engaged                    |
| $H_{stud}$       | = | 13.7 ft               | Height of stud (maximum)                   |
| $H_{partial}$    | = | 9.5 ft                | Height of stud (partial height wall)       |
| $W_{p,wall}$     | = | 8.0 psf               | Unit weight of partition wall              |
| $s_{stud}$       | = | 16 in                 | Stud spacing                               |
| Stud             | = | 400S125-54            | (min)                                      |
| $S_e$            | = | 0.361 in <sup>3</sup> |                                            |
| $I_e$            | = | 0.830 in <sup>4</sup> |                                            |
| $M'$             | = | 10.8 kip-in           | = $S_e F_y / \Omega_b$ , $\Omega_b = 1.67$ |
| $0.7F_{ph,wall}$ | = | 2.5 psf               | = $0.7(0.45) W_{p,wall}$                   |
| Live             | = | 5.0 psf               | Uniform live load on wall (CBC 1607.14)    |





|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 24 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |

## DETAIL

|                                              |         |
|----------------------------------------------|---------|
| Typical Wall-Mounted Equipment (150 Lbs max) | 12/S101 |
|----------------------------------------------|---------|

## Load Case 1: (D+0.7E)

|               |   |      |                 |                                     |                                                                                                            |
|---------------|---|------|-----------------|-------------------------------------|------------------------------------------------------------------------------------------------------------|
| $w_{wall}$    | = | 3.4  | plf / stud      | =                                   | $0.7F_{ph,wall} \cdot (s_{stud}/12)$                                                                       |
| $R_{TOP}$     | = | 42   | Lbs / stud      | =                                   | $w_{wall} \cdot H_{stud}/2 + [0.7F_{ph} + (W_p + 0.7F_{pv}) \cdot (D/12)/H_{stud}] / n_{stud}$             |
| $R_{PARTIAL}$ | = | 36   | Lbs / stud      | =                                   | $w_{wall} \cdot H_{partial}/2 + [0.7F_{ph} + (W_p + 0.7F_{pv}) \cdot (D/12)/H_{partial}] / n_{stud}$       |
| $R_{BOT}$     | = | 42   | Lbs / stud      | =                                   | $w_{wall} \cdot H_{stud}/2 + [0.7F_{ph} + (W_p + 0.7F_{pv}) \cdot (D/12)/H_{stud}] / n_{stud}$             |
| $M$           | = | 1.8  | kip-in          | =                                   | $w_{wall} \cdot H_{stud}^2/8 + [0.7F_{ph} \cdot H_{stud}/4 + (W_p + 0.7F_{pv}) \cdot (D/12)/2] / n_{stud}$ |
| $DCR_M$       | = | 0.17 | $\leq 1.0$ (OK) | =                                   | $M/M' \leq 1.0$                                                                                            |
| $\Delta$      | = | 0.17 | in (L/966)      | Maximum Deflection (Limit to L/120) |                                                                                                            |

## Load Case 2: (D+L)

|               |   |      |                 |                                     |                                                                                |
|---------------|---|------|-----------------|-------------------------------------|--------------------------------------------------------------------------------|
| $w_{wall}$    | = | 6.7  | plf / stud      | =                                   | $Live \cdot (s_{stud}/12)$                                                     |
| $R_{TOP}$     | = | 48   | Lbs / stud      | =                                   | $w_{wall} \cdot H_{stud}/2 + W_p \cdot (D/12)/(H_{stud} \cdot n_{stud})$       |
| $R_{PARTIAL}$ | = | 35   | Lbs / stud      | =                                   | $w_{wall} \cdot H_{partial}/2 + W_p \cdot (D/12)/(H_{partial} \cdot n_{stud})$ |
| $R_{BOT}$     | = | 48   | Lbs / stud      | =                                   | $w_{wall} \cdot H_{stud}/2 + W_p \cdot (D/12)/(H_{stud} \cdot n_{stud})$       |
| $M$           | = | 2.1  | kip-in          | =                                   | $w_{wall} \cdot H_{stud}^2/8 + W_p \cdot (D/12)/(2 \cdot n_{stud})$            |
| $DCR_M$       | = | 0.19 | $\leq 1.0$ (OK) | =                                   | $M/M' \leq 1.0$                                                                |
| $\Delta$      | = | 0.22 | in (L/754)      | Maximum Deflection (Limit to L/120) |                                                                                |

## Connections at Top Track of Full-Height Wall - Load Case 2: (D+L) Governs

|                        |                                             |                                                                                                     |
|------------------------|---------------------------------------------|-----------------------------------------------------------------------------------------------------|
| NWC o/ Mtl Deck        | Type of existing floor/roof structure above |                                                                                                     |
| Conn(E) =              | PAF                                         | Existing connections at top track are power-actuated fasteners (PAF)                                |
| $s_{(E)}$ =            | 24 in                                       | Spacing of existing PAF along top track of full-height wall (max)                                   |
| $n_{(E)}$ =            | 2                                           | Number of existing PAF resisting reaction from equipment loads (distributed by backing & top track) |
| $V_{(5\text{ psf})}$ = | 68 Lbs / PAF                                | Existing shear demand at top of wall (based on 5 psf out-of-plane live load)                        |
| $V_{wall}$ =           | 68 Lbs / PAF                                | Shear demand at top of wall from uniform wall loads (based on 5 psf out-of-plane live load)         |
| $V_{equip}$ =          | 4 Lbs / PAF                                 | Additional shear demand from equipment only (based on Load Case 2)                                  |
| $V_{(E)}$ =            | 72 Lbs / PAF                                | $= V_{wall} + V_{equip}$                                                                            |
| $V'_{(E)}$ =           | 90 Lbs                                      | 0.157" $\phi$ Hilti X-U w/ 1" Embed (ICC ESR-2269)                                                  |
| $DCR$ =                | 0.80 $\leq 1.0$ (OK)                        | $= V_{(E)}/V'_{(E)} \leq 1.0$                                                                       |

## Braces at Top Track of Partial-Height Wall - Load Case 2: (D+L) Governs

|                        |                |                                                                                                              |
|------------------------|----------------|--------------------------------------------------------------------------------------------------------------|
| $s_{brace}$ =          | 48 in          | Spacing of existing braces along top track of partial-height wall (max)                                      |
| $n_{brace}$ =          | 2              | Number of existing braces supporting section of top track at equipment (min)                                 |
| $V_{(5\text{ psf})}$ = | 95 Lbs / brace | Existing horizontal reaction force at brace (based on 5 psf out-of-plane live load)                          |
| $V_{wall}$ =           | 48 Lbs / brace | Horizontal reaction force at brace from uniform wall loads (based on 5 psf out-of-plane live load)           |
| $V_{equip}$ =          | 30 Lbs / brace | Additional horizontal reaction force at brace from equipment only (based on Load Case 2)                     |
| $V_{brace}$ =          | 78 Lbs / brace | $= V_{wall} + V_{equip}$ 78 Lbs $\leq$ 95 Lbs (from 5 psf live), therefore braces are adequate by inspection |

## Connections at Bottom Track - Load Case 2: (D+L) Governs

|                        |                                        |                                                                                                        |
|------------------------|----------------------------------------|--------------------------------------------------------------------------------------------------------|
| NWC o/ Mtl Deck        | Type of existing floor structure below |                                                                                                        |
| Conn(E) =              | PAF                                    | Existing connections at bottom track are power-actuated fasteners (PAF)                                |
| $s_{(E)}$ =            | 24 in                                  | Spacing of existing PAF along bottom track (max)                                                       |
| $n_{(E)}$ =            | 2                                      | Number of existing PAF resisting reaction from equipment loads (distributed by backing & bottom track) |
| $V_{(5\text{ psf})}$ = | 68 Lbs / PAF                           | Existing shear demand at bottom of wall (based on 5 psf out-of-plane live load)                        |
| $V_{wall}$ =           | 68 Lbs / PAF                           | Shear demand at bottom of wall from uniform wall loads (based on 5 psf out-of-plane live load)         |
| $V_{equip}$ =          | 4 Lbs / PAF                            | Additional shear demand from equipment only (based on Load Case 2)                                     |
| $V_{(E)}$ =            | 72 Lbs / PAF                           | $= V_{wall} + V_{equip}$                                                                               |
| $V'_{(E)}$ =           | 90 Lbs                                 | 0.157" $\phi$ Hilti X-U w/ 1" Embed (ICC ESR-2269)                                                     |
| $DCR$ =                | 0.80 $\leq 1.0$ (OK)                   | $= V_{(E)}/V'_{(E)} \leq 1.0$                                                                          |

|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 25 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |

## Typical Unistrut Wall-Mounted Equipment (150 Lbs max)

### DETAIL 13/S101

#### Seismic Input

|            |      |
|------------|------|
| Design =   | City |
| $a_p$ =    | 2.5  |
| $R_p$ =    | 6.0  |
| $S_{DS}$ = | 1.35 |
| $I_p$ =    | 1.00 |
| $z_1/h$ =  | 0.33 |
| $z_2/h$ =  | 0.67 |

ASCE 7 Tables 13.5-1 and 13.6-1  
See USGS sheet  
ASCE 7 Table 11.5-1  
Floor below (2nd Floor)  
Floor above (3rd Floor)

#### Weight & Dimensions

|         |     |           |
|---------|-----|-----------|
| $W_p$ = | 150 | Lbs (max) |
| $H$ =   | 8.0 | in (min)  |
| $B$ =   | 6.0 | in (min)  |
| $D$ =   | 8.0 | in (max)  |
| $e$ =   | 1.6 | in        |



Equipment weight  
Height between top & bottom connections to backing  
Width between left and right connections to backing  
Depth to centroid  
Eccentricity from Unistrut

#### Seismic Forces

|                |      |       |
|----------------|------|-------|
| $F_{ph,min}$ = | 0.41 | $W_p$ |
| $F_{ph,1}$ =   | 0.37 | $W_p$ |
| $F_{ph,2}$ =   | 0.53 | $W_p$ |
| $F_{ph,avg}$ = | 0.45 | $W_p$ |
| $F_{ph}$ =     | 0.45 | $W_p$ |
| $F_{pv}$ =     | 0.27 | $W_p$ |
| $F_{ph}$ =     | 68   | Lbs   |
| $F_{pv}$ =     | 41   | Lbs   |

$= 0.3S_{DS} \cdot I_p \cdot W_p$   
 $F_{ph}$  at floor below ( $z_1/h$ )  
 $F_{ph}$  at floor above ( $z_2/h$ )  
Average of  $F_{ph,1}$  &  $F_{ph,2}$   
Max of  $F_{ph,min}$  &  $F_{ph,avg}$   
 $= 0.2S_{DS} \cdot W_p$   
Horizontal seismic force  
Vertical seismic force

$$F_{ph} = \frac{0.4S_{DS}a_p}{R_p/I_p} \left(1 + 2\frac{z}{h}\right) W_p$$



#### HHCS Equip Conn to Unistrut

|             |       |                 |
|-------------|-------|-----------------|
| Metal =     | 18 ga | (min)           |
| $d$ =       | 1/4   | in              |
| $m_f$ =     | 0.75  |                 |
| $C$ =       | 3.0   |                 |
| $V_{F-B}$ = | 45    | Lbs             |
| $V_{S-S}$ = | 46    | Lbs             |
| $P_{F-B}$ = | 101   | Lbs             |
| $P_{S-S}$ = | 121   | Lbs             |
| $V'_b$ =    | 362   | Lbs             |
| $V'_s$ =    | 300   | Lbs             |
| $P'_b$ =    | 457   | Lbs             |
| $P'_s$ =    | 600   | Lbs             |
| DCR =       | 0.60  | $\leq 1.0$ (OK) |

$n_{HHCS} = 4$  No. of HHCS to Unistrut  
 $t = 0.0451$  in Equipment metal thickness (min)

Bolt diameter  
Modification factor per AISI Table E3.3.1-2  
Bearing factor per AISI Table E3.3.1-1  
Shear per HHCS (front-to-back)  $= (W_p + 0.7F_{pv}) \div n_{HHCS}$   
Shear per HHCS (side-to-side)  $= [(W_p + 0.7F_{pv})^2 + 0.7F_{ph}^{2.0.5} + n_{HHCS}] \div n_{HHCS}$   
Tension per HHCS (front-to-back)  $= [(W_p + 0.7F_{pv}) \cdot D/H + 0.7F_{ph}/2] \div (n_{HHCS}/2)$   
Tension per HHCS (side-to-side)  $= [(W_p + 0.7F_{pv}) \cdot D/H + 0.7F_{ph} \cdot D/B] \div (n_{HHCS}/2)$   
Shear capacity of metal (AISI Eqn. E4.3.1-1)  $= [4.2(t^{3.0})^{1/2} \cdot F_u]/\Omega$   
Slip resistance capacity of spring nut connection to strut per Unistrut catalog  
Bearing capacity of metal (AISI Eqn. E3.3.1-1)  $= [m_f \cdot C \cdot d \cdot t \cdot F_u]/\Omega$   
Pullout capacity of spring nut connection to strut per Unistrut catalog  
 $= \max[V_{F-B}/\min(V'_b, V'_s) + P_{F-B}/\min(P'_b, P'_s), V_{S-S}/\min(V'_b, V'_s) + P_{S-S}/\min(P'_b, P'_s)] \leq 1.0$

#### Screws into Metal Studs

|                    |               |
|--------------------|---------------|
| SMS =              | 1/4"φ         |
| V <sub>F-B</sub> = | 15 Lbs        |
| V <sub>S-S</sub> = | <b>15</b> Lbs |
| P <sub>F-B</sub> = | 40 Lbs        |
| P <sub>S-S</sub> = | 46 Lbs        |
| V' =               | 613 Lbs       |
| P' =               | 261 Lbs       |
| DCR =              | 0.20 ≤ 1      |


$n_{wall} = 12$  No. of screws into metal studs (2 screws into each stud at each Unistrut)  
Metal = 16 ga studs (min)

Shear per screw (front-to-back)  $= (W_p + 0.7F_{pv}) \div n_{wall}$   
Shear per screw (side-to-side)  $= [(W_p + 0.7F_{pv})^2 + 0.7F_{ph}^{2.0.5} + n_{wall}] \div n_{wall}$   
Tension per screw (front-to-back)  $= [(W_p + 0.7F_{pv}) \cdot (D+e)/H + 0.7F_{ph}/2] \div (n_{wall}/2)$   
Tension per screw (side-to-side)  $= [(W_p + 0.7F_{pv}) \cdot (D+e)/H + 0.7F_{ph} \cdot (D+e)/B] \div (n_{wall}/2)$   
Screw shear capacity per SSMA allowable loads table, p.90  
Screw pull-out capacity per SSMA allowable loads table, p.90  
 $= \max[V_{F-B}/V' + P_{F-B}/P', V_{S-S}/V' + P_{S-S}/P'] \leq 1.0$

#### Stud Design

|                  |   |            |                 |
|------------------|---|------------|-----------------|
| $n_{stud}$       | = | 3          |                 |
| $H_{stud}$       | = | 13.7       | ft              |
| $H_{partial}$    | = | 9.5        | ft              |
| $W_{p,wall}$     | = | 8.0        | psf             |
| $s_{stud}$       | = | 16         | in              |
| Stud             | = | 400S125-54 |                 |
| $S_e$            | = | 0.361      | in <sup>3</sup> |
| $I_e$            | = | 0.830      | in <sup>4</sup> |
| $M'$             | = | 10.8       | kip-in          |
| $0.7F_{ph,wall}$ | = | 2.5        | psf             |
| Live             | = | 5.0        | psf             |

Number of studs engaged  
Height of stud (maximum)  
Height of stud (partial height wall)  
Unit weight of partition wall  
Stud spacing  
 $S_e F_y / \Omega_b, \Omega_b = 1.67$   
 $= 0.7(0.45) W_{p,wall}$   
Uniform live load on wall (CBC 1607.14)



|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | 26 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |

## DETAIL

|                                                       |         |
|-------------------------------------------------------|---------|
| Typical Unistrut Wall-Mounted Equipment (150 Lbs max) | 13/S101 |
|-------------------------------------------------------|---------|

## Load Case 1: (D+0.7E)

|               |                   |                                                                                                              |
|---------------|-------------------|--------------------------------------------------------------------------------------------------------------|
| $w_{wall}$    | = 3.4 plf / stud  | = $0.7F_{ph,wall} \cdot (s_{stud}/12)$                                                                       |
| $R_{TOP}$     | = 42 Lbs / stud   | = $w_{wall} \cdot H_{stud}/2 + [0.7F_{ph} + (W_p + 0.7F_{pv}) \cdot (D/12)/H_{stud}] / n_{stud}$             |
| $R_{PARTIAL}$ | = 36 Lbs / stud   | = $w_{wall} \cdot H_{partial}/2 + [0.7F_{ph} + (W_p + 0.7F_{pv}) \cdot (D/12)/H_{partial}] / n_{stud}$       |
| $R_{BOT}$     | = 42 Lbs / stud   | = $w_{wall} \cdot H_{stud}/2 + [0.7F_{ph} + (W_p + 0.7F_{pv}) \cdot (D/12)/H_{stud}] / n_{stud}$             |
| $M$           | = 1.8 kip-in      | = $w_{wall} \cdot H_{stud}^2/8 + [0.7F_{ph} \cdot H_{stud}/4 + (W_p + 0.7F_{pv}) \cdot (D/12)/2] / n_{stud}$ |
| $DCR_M$       | = 0.17 ≤ 1.0 (OK) | = $M/M' \leq 1.0$                                                                                            |
| $\Delta$      | = 0.17 in (L/966) | Maximum Deflection (Limit to L/120)                                                                          |

## Load Case 2: (D+L)

|               |                   |                                                                                  |
|---------------|-------------------|----------------------------------------------------------------------------------|
| $w_{wall}$    | = 6.7 plf / stud  | = $Live \cdot (s_{stud}/12)$                                                     |
| $R_{TOP}$     | = 48 Lbs / stud   | = $w_{wall} \cdot H_{stud}/2 + W_p \cdot (D/12)/(H_{stud} \cdot n_{stud})$       |
| $R_{PARTIAL}$ | = 35 Lbs / stud   | = $w_{wall} \cdot H_{partial}/2 + W_p \cdot (D/12)/(H_{partial} \cdot n_{stud})$ |
| $R_{BOT}$     | = 48 Lbs / stud   | = $w_{wall} \cdot H_{stud}/2 + W_p \cdot (D/12)/(H_{stud} \cdot n_{stud})$       |
| $M$           | = 2.1 kip-in      | = $w_{wall} \cdot H_{stud}^2/8 + W_p \cdot (D/12)/(2 \cdot n_{stud})$            |
| $DCR_M$       | = 0.19 ≤ 1.0 (OK) | = $M/M' \leq 1.0$                                                                |
| $\Delta$      | = 0.22 in (L/754) | Maximum Deflection (Limit to L/120)                                              |

## Connections at Top Track of Full-Height Wall - Load Case 2: (D+L) Governs

|                      |                   |                                                                                                     |
|----------------------|-------------------|-----------------------------------------------------------------------------------------------------|
| NWC o/ Mtl Deck      |                   | Type of existing floor/roof structure above                                                         |
| Conn <sub>(E)</sub>  | = PAF             | Existing connections at top track are power-actuated fasteners (PAF)                                |
| $s_{(E)}$            | = 24 in           | Spacing of existing PAF along top track of full-height wall (max)                                   |
| $n_{(E)}$            | = 2               | Number of existing PAF resisting reaction from equipment loads (distributed by backing & top track) |
| $V_{(5\text{ psf})}$ | = 68 Lbs / PAF    | Existing shear demand at top of wall (based on 5 psf out-of-plane live load)                        |
| $V_{wall}$           | = 68 Lbs / PAF    | Shear demand at top of wall from uniform wall loads (based on 5 psf out-of-plane live load)         |
| $V_{equip}$          | = 4 Lbs / PAF     | Additional shear demand from equipment only (based on Load Case 2)                                  |
| $V_{(E)}$            | = 72 Lbs / PAF    | = $V_{wall} + V_{equip}$                                                                            |
| $V'_{(E)}$           | = 90 Lbs          | 0.157" $\phi$ Hilti X-U w/ 1" Embed (ICC ESR-2269)                                                  |
| $DCR$                | = 0.80 ≤ 1.0 (OK) | = $V_{(E)}/V'_{(E)} \leq 1.0$                                                                       |


## Braces at Top Track of Partial-Height Wall - Load Case 2: (D+L) Governs

|                      |                  |                                                                                                         |
|----------------------|------------------|---------------------------------------------------------------------------------------------------------|
| $s_{brace}$          | = 48 in          | Spacing of existing braces along top track of partial-height wall (max)                                 |
| $n_{brace}$          | = 2              | Number of existing braces supporting section of top track at equipment (min)                            |
| $V_{(5\text{ psf})}$ | = 95 Lbs / brace | Existing horizontal reaction force at brace (based on 5 psf out-of-plane live load)                     |
| $V_{wall}$           | = 48 Lbs / brace | Horizontal reaction force at brace from uniform wall loads (based on 5 psf out-of-plane live load)      |
| $V_{equip}$          | = 30 Lbs / brace | Additional horizontal reaction force at brace from equipment only (based on Load Case 2)                |
| $V_{brace}$          | = 78 Lbs / brace | = $V_{wall} + V_{equip}$ 78 Lbs ≤ 95 Lbs (from 5 psf live), therefore braces are adequate by inspection |


## Connections at Bottom Track - Load Case 2: (D+L) Governs

|                      |                   |                                                                                                        |
|----------------------|-------------------|--------------------------------------------------------------------------------------------------------|
| NWC o/ Mtl Deck      |                   | Type of existing floor structure below                                                                 |
| Conn <sub>(E)</sub>  | = PAF             | Existing connections at bottom track are power-actuated fasteners (PAF)                                |
| $s_{(E)}$            | = 24 in           | Spacing of existing PAF along bottom track (max)                                                       |
| $n_{(E)}$            | = 2               | Number of existing PAF resisting reaction from equipment loads (distributed by backing & bottom track) |
| $V_{(5\text{ psf})}$ | = 68 Lbs / PAF    | Existing shear demand at bottom of wall (based on 5 psf out-of-plane live load)                        |
| $V_{wall}$           | = 68 Lbs / PAF    | Shear demand at bottom of wall from uniform wall loads (based on 5 psf out-of-plane live load)         |
| $V_{equip}$          | = 4 Lbs / PAF     | Additional shear demand from equipment only (based on Load Case 2)                                     |
| $V_{(E)}$            | = 72 Lbs / PAF    | = $V_{wall} + V_{equip}$                                                                               |
| $V'_{(E)}$           | = 90 Lbs          | 0.157" $\phi$ Hilti X-U w/ 1" Embed (ICC ESR-2269)                                                     |
| $DCR$                | = 0.80 ≤ 1.0 (OK) | = $V_{(E)}/V'_{(E)} \leq 1.0$                                                                          |

|          |                                |    |
|----------|--------------------------------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic | A1 |
| Calc By: | ISG                            |    |
| Date:    | 02/21/19                       |    |



|          |                                |          |    |
|----------|--------------------------------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |          | A2 |
| Calc By: | ISG                            | Date:    |    |
|          |                                | 02/21/19 |    |



**Figure 46: Anchorage & Seismic single ceiling model.**

|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | A3 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |

## Model Numbers

**WARRANTY: Limited 5-year**
**SA730P** SmartMount® Articulating Wall Mount for 10" to 29" Displays

## Product Specifications

|        | DIMENSIONS (W x H x D)                                  | PRODUCT WEIGHT  | LOAD CAPACITY | FINISH                           | AVAILABLE COLORS |
|--------|---------------------------------------------------------|-----------------|---------------|----------------------------------|------------------|
| SA730P | 10.01" x 8.06" x 2.77"-16.99"<br>(254 x 205 x 70-432mm) | 3.55lb (1.61kg) | 25lb (11kg)   | Scratch Resistant<br>Fused Epoxy | Semi-Gloss Black |

## Package Specifications

|        | PACKAGE SIZE (W x H x D)                      | PACKAGE SHIP WEIGHT | PACKAGE UPC CODE | PACKAGE CONTENTS                                                                       | UNITS IN PACKAGE |
|--------|-----------------------------------------------|---------------------|------------------|----------------------------------------------------------------------------------------|------------------|
| SA730P | 14.13" x 3.75" x 10.38"<br>(358 x 95 x 263mm) | 4.75lb (2.15kg)     | 735029237389     | Wall Mount, Wall and<br>Display Installation<br>Hardware, Installation<br>Instructions | 1                |

## Accessories

**ACC918:** Security Fasteners






**ACC2X1:** VESA® 200 x 100mm Adaptor Plate

**ESHV models:** AV Wall Shelves

**IBA4-W:** Easy Mount Recessed Low Voltage Cable Plate

**IBA5-W:** Recessed Low Voltage Media Plate with Duplex Surge Suppressor

**WSP700/WSP701:** Metal Stud Wall Plates for 16"/24" Center Metal Studs

All dimensions = **inch** (mm)

**TOP VIEW**

**WALL PLATE DETAIL**

**FRONT VIEW**

**SIDE VIEW  
COLLAPSED**

**SIDE VIEW EXTENDED  
+/-35° TILT**

## Architect Specifications

The SmartMount® Articulating Wall Mount shall be a Peerless-AV model SA730P and shall be located where indicated on the plans. Assembly and installation shall be done according to instructions provided by the manufacturer.

Visit [peerless-av.com](http://peerless-av.com) to see the complete line of AV solutions from Peerless-AV, including outdoor displays, wireless, kiosks, digital audio, display mounts, projector mounts, carts/stands, and a full assortment of accessories.

**Peerless-AV**  
2300 White Oak Circle  
Aurora, IL 60502 USA  
**(800) 865-2112**  
**(630) 375-5100**  
**Fax: (800) 359-6500**

**Peerless-AV EMEA**  
Unit 3 Watford Interchange  
Colonial Way, Watford  
Herts, WD24 4WP  
United Kingdom  
**+44 (0) 1923 200100**  
**Fax: +44 (0) 1923 200101**

**Peerless-AV Latin America**  
Ave de las Industrias 413  
Parque Industrial Escobedo  
Escobedo, N.L.,  
Mexico 66062  
**+52 (81) 8384-8300**  
**Fax: +52 (81) 8384-8360**

**peerless-AV®**  
Driving Technology Through Innovation



|          |                                |          |    |
|----------|--------------------------------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |          | A4 |
| Calc By: | ISG                            | Date:    |    |
|          |                                | 02/21/19 |    |

**EASE**

**EQUIPMENT ANCHORAGE  
& SEISMIC ENGINEERING**

5877 Pine Ave, Ste. 210  
Chino Hills, CA. 91709  
Phn: (909) 606-7622

Office of Statewide Health Planning and Development  
**PREAPPROVAL OF MANUFACTURER'S CERTIFICATION**  
**OPM-0212-13**


THIS PREAPPROVAL CONFORMS TO THE 2013 CALIFORNIA BUILDING CODE

MANUFACTURER: **PEERLESS INDUSTRIES, INC.**  
EQUIPMENT NAME: **SMARTMOUNT ARTICULATING WALL ARM**

Sheet: 1 of 6  
Date: 7/27/15

**GENERAL NOTES**

1. THIS OSHPD PREAPPROVAL OF MANUFACTURER'S CERTIFICATION (OPM) IS BASED ON THE 2013 CBC. THE DEMANDS (DESIGN FORCES) FOR USE WITH THIS OPM SHALL BE BASED ON THE 2013 CBC
2. THIS DOCUMENT MAY ONLY BE USED WITH THE EXPRESS WRITTEN CONSENT OF THE MANUFACTURER LISTED ABOVE FOR THE SPECIFIC PROJECT SITE AND INSTALLATION LOCATION. THIS DOCUMENT IS INVALID WITHOUT SUCH CONSENT.
3. THIS PREAPPROVAL CONFORMS TO THE 2013 CALIFORNIA BUILDING CODE WHERE  $S_{ds}$  IS NOT GREATER THAN 1.60, 2.20
4. FORCES PER ASCE 7-10 SECTION 13.3.1, EQUATIONS 13.3-1, 13.3-2 & 13.3-3,  
WHERE  $S_{ds} = 1.60$ ,  $a_p = 1.0$ ,  $I_p = 1.5$ ,  $R_p = 1.5$ ,  $z/h \leq 1$  CONCRETE WALL. SEE FOLLOWING SHEETS FOR  $\Omega$ .  
WHERE  $S_{ds} = 2.20$ ,  $a_p = 1.0$ ,  $I_p = 1.5$ ,  $R_p = 1.5$ ,  $z/h \leq 1$  SEE FOLLOWING SHEETS FOR  $\Omega$ .
5. THIS PREAPPROVAL COVERS ONLY THE SUPPORTS AND ATTACHMENTS OF THE EQUIPMENT TO THE STRUCTURE.
6. ALL DESIGN FORCES SHOWN ON THE DRAWINGS ARE FACTORED LOADS THAT SHALL BE USED FOR STRENGTH DESIGN.
7. CONCRETE WALL VALID FOR DEMANDS SHOWN AT ANY ELEVATION (i.e.  $z/h \leq 1$ )
8. **RESPONSIBILITIES OF THE STRUCTURAL ENGINEER OF RECORD OF THE BUILDING**
  - A. PROVIDE SUPPORTING STRUCTURE TO SUPPORT WEIGHTS AND FORCES SHOWN IN ADDITION TO ALL OTHER LOADS.
  - B. VERIFY THAT THE INSTALLATION IS IN CONFORMANCE WITH THE 2013 CBC AND WITH THE DETAILS, MATERIAL AND GAGE OF THE UNIT WHERE ATTACHMENTS ARE MADE AGREE WITH THE INFORMATION SHOWN ON THE PREAPPROVAL DOCUMENTS.
  - C. VERIFY THAT PROJECT SPECIFIC VALUES OF  $S_{ds}$  &  $z/h$  RESULT IN SEISMIC FORCES ( $E_h$ ,  $E_v$ ) THAT DO NOT EXCEED THE VALUES ON THE DETAILS.
  - D. VERIFY THAT THE CONCRETE WALL TO WHICH THE EQUIPMENT IS ANCHORED MEETS THE REQUIREMENTS OF THE APPLICABLE ICC ESR.
  - E. VERIFY THAT THE ANCHORS ARE AN ADEQUATE DISTANCE FROM ANY CONCRETE WALL EDGES OR OPENINGS (SEE TYPICAL DETAIL ON SHEET 2).
  - F. VERIFY THAT ALL NEW OR EXISTING ANCHORS ARE AN ADEQUATE DISTANCE FROM THE UNIT ATTACHMENTS AND CHECK FOR INTERACTION WHERE OTHER ANCHORS ARE WITHIN 18" OR  $6h_{ef}$  FROM THIS UNIT'S ANCHORS.
  - G. DESIGN BACKING BARS, STUDS, ETC. WHICH THE UNITS ARE ATTACHED TO AS NOTED ON THE DRAWINGS.



|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | A5 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |

**EASE**
**EQUIPMENT ANCHORAGE & SEISMIC ENGINEERING**  
www.EquipmentAnchorage.com

**PEERLESS INDUSTRIES, INC.**

DES. **J. ROBERSON**


SHEET

**3**

JOB NO. **11-1502**
**SMARTMOUNT ARTICULATING WALL ARM**

DATE **7/27/15**

OF **6** SHEETS


SEISMIC SUPPORTS & ATTACHMENTS
WALL MOUNTED

STEEL STUD WALL SECTION
NOTES:

- FORCES ARE DETERMINED PER 2013 CALIFORNIA BUILDING CODE AND ASCE 7-10. STRENGTH DESIGN IS USED. ( $S_{DS} = 2.20$ ,  $a_p = 2.5$ ,  $I_p = 1.5$ ,  $R_p = 2.5$ ,  $z/h \leq 1$ )

$$\text{HORIZONTAL FORCE (E}_h\text{)} = 3.96 W_p$$

$$\text{VERTICAL FORCE (E}_v\text{)} = 0.44 W_p$$

- CENTER OF GRAVITY (C.G.) AND WEIGHT ARE THE GOVERNING PARAMETERS FOR DESIGN. THIS PREAPPROVAL ENCOMPASSES ALL WEIGHTS UP TO THE MAXIMUM WEIGHT SHOWN.
- STRUCTURAL ENGINEER OF RECORD FOR THE BUILDING SHALL PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.
- SEE GENERAL NOTES: SHEETS 1 AND 2





|          |                                |          |    |
|----------|--------------------------------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |          | A6 |
| Calc By: | ISG                            | Date:    |    |
|          |                                | 02/21/19 |    |

**EASE**

**EQUIPMENT ANCHORAGE & SEISMIC ENGINEERING**  
www.EquipmentAnchorage.com

**PEERLESS INDUSTRIES, INC.**

DES. **J. ROBERSON**

SHEET

**4**

JOB NO. **11-1502**


**SMARTMOUNT ARTICULATING WALL ARM**

DATE **7/27/15**

OF **6** SHEETS

SEISMIC SUPPORTS & ATTACHMENTS

WALL MOUNTED




STRUCTURAL ENGINEER OF RECORD SHALL DESIGN THE BACKING PLATE (16 GA., 50 KSI MIN.) AND THE WALL STRUCTURE

C.G. WT. = 63 LB (MAX)  
(55 LB MONITOR AND  
8 LB MOUNT)  
( $\bar{X}$  = 23.2")

USE 2- 1/4"Ø (GRADE 5) BOLTS  
W/ NUT & STD WASHER  
TO STRUCTURAL WALL SUPPORT  
(BY STRUCTURAL ENGINEER  
OF RECORD)

UNIT BACKING  
(A380 ALUMINUM,  $F_y$ =23 KSI MIN)

**ELEVATION AT WALL PLATE**  
(MODEL SA740P)



|          |                                |       |          |    |
|----------|--------------------------------|-------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | A7 |
| Calc By: | ISG                            | Date: | 02/21/19 |    |

SmartMount® Universal Tilt Wall Mount | Peerless-AV



**B2B** (HTTPS://B2B.PEERLESS-

AV.COM/USER/LOGIN.ASPX?



### SmartMount® Universal Tilt Wall Mount

for 32" to 50" Displays

SKU: ST640

**Price: \$180.00**

1

ADD TO CART

Share:



Certifications:

Packaging



California Residents:

**WARNING:** Cancer and reproductive harm- See [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov) for more information.

| Name                           | Value                                          |
|--------------------------------|------------------------------------------------|
| Minimum to Maximum Screen Size | 32" to 50"                                     |
| VESA Pattern                   | 400 x 400                                      |
| Weight Capacity                | 150lb (68.0kg)                                 |
| Color                          | Black                                          |
| Finish                         | Powder Coat                                    |
| Distance from Wall             | 2.63 - 5.71" (67 - 145mm)                      |
| Increlock Increments           | -5, 0, 5, 10, 15                               |
| Mounting Pattern               | 458 x 405mm (18.02 x 15.95")                   |
| Security Features              | Security Hardware                              |
| Tilt                           | +15 / -5                                       |
| Product Dimensions             | 21.69 X 10.71 X 2.95" (550 X 272 X 75mm)       |
| Shipping Weight                | 7.82lb (7.82kg)                                |
| Ship Dimensions                | 10.71 x 2.95 x 21.69" (272.0 x 74.9 x 550.9mm) |
| UPC Code                       | 735029235699                                   |

|          |                                |       |          |
|----------|--------------------------------|-------|----------|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       | A8       |
| Calc By: | ISG                            | Date: |          |
|          |                                |       | 02/21/19 |

## EASE

**EQUIPMENT ANCHORAGE  
& SEISMIC ENGINEERING**

5877 Pine Ave, Ste. 210  
Chino Hills, CA. 91709  
Phn: (909) 606-7622

Office of Statewide Health Planning and Development  
**PREAPPROVAL OF MANUFACTURER'S CERTIFICATION**  
**OPM-0211-13**

THIS PREAPPROVAL CONFORMS TO THE 2013 CALIFORNIA BUILDING CODE


MANUFACTURER: **PEERLESS INDUSTRIES, INC.** Sheet: 1 of 8  
EQUIPMENT NAME: **UNIVERSAL FLAT AND TILT WALL MOUNT FOR FLAT TV WEIGHT UP TO 175 LB** Date: 7/27/15

### GENERAL NOTES

1. THIS OSHPD PREAPPROVAL OF MANUFACTURER'S CERTIFICATION (OPM) IS BASED ON THE 2013 CBC. THE DEMANDS (DESIGN FORCES) FOR USE WITH THIS OPM SHALL BE BASED ON THE 2013 CBC
2. THIS DOCUMENT MAY ONLY BE USED WITH THE EXPRESS WRITTEN CONSENT OF THE MANUFACTURER LISTED ABOVE FOR THE SPECIFIC PROJECT SITE AND INSTALLATION LOCATION. THIS DOCUMENT IS INVALID WITHOUT SUCH CONSENT.
3. THIS PREAPPROVAL CONFORMS TO THE 2013 CALIFORNIA BUILDING CODE WHERE  $S_{ds}$  IS NOT GREATER THAN 2.20.
4. FORCES PER ASCE 7-10 SECTION 13.3.1, EQUATIONS 13.3-1, 13.3-2 & 13.3-3,  
WHERE  $S_{ds} = 2.20$ ,  $a_p = 1.0$ ,  $I_p = 1.5$ ,  $R_p = 1.5$ ,  $z/h \leq 1$  CONCRETE WALL. SEE FOLLOWING SHEETS FOR  $\Omega$ .
5. THIS PREAPPROVAL COVERS ONLY THE SUPPORTS AND ATTACHMENTS OF THE EQUIPMENT TO THE STRUCTURE.
6. ALL DESIGN FORCES SHOWN ON THE DRAWINGS ARE FACTORED LOADS THAT SHALL BE USED FOR STRENGTH DESIGN.
7. CONCRETE WALL DETAIL VALID FOR DEMANDS SHOWN AT ANY ELEVATION. (i.e.  $z/h \leq 1$ )

### 8. RESPONSIBILITIES OF THE STRUCTURAL ENGINEER OF RECORD OF THE BUILDING

- A. PROVIDE SUPPORTING STRUCTURE TO SUPPORT WEIGHTS AND FORCES SHOWN IN ADDITION TO ALL OTHER LOADS.
- B. VERIFY THAT THE INSTALLATION IS IN CONFORMANCE WITH THE 2013 CBC AND WITH THE DETAILS, MATERIAL AND GAGE OF THE UNIT WHERE ATTACHMENTS ARE MADE AGREE WITH THE INFORMATION SHOWN ON THE PREAPPROVAL DOCUMENTS.
- C. VERIFY THAT PROJECT SPECIFIC VALUES OF  $S_{ds}$  &  $z/h$  RESULT IN SEISMIC FORCES ( $E_h$ ,  $E_v$ ) THAT DO NOT EXCEED THE VALUES ON THE DETAILS.
- D. VERIFY THAT THE CONCRETE WALL TO WHICH THE EQUIPMENT IS ANCHORED MEETS THE REQUIREMENTS OF THE APPLICABLE ICC ESR.
- E. VERIFY THAT THE ANCHORS ARE AN ADEQUATE DISTANCE FROM ANY CONCRETE WALL EDGES OR OPENINGS (SEE TYPICAL DETAIL ON SHEET 2).
- F. VERIFY THAT ALL NEW OR EXISTING ANCHORS ARE AN ADEQUATE DISTANCE FROM THE UNIT ATTACHMENTS AND CHECK FOR INTERACTION WHERE OTHER ANCHORS ARE WITHIN 18" OR  $6h_{ef}$  FROM THIS UNIT'S ANCHORS.
- G. DESIGN BACKING BARS, STUDS, ETC. WHICH THE UNITS ARE ATTACHED TO AS NOTED ON THE DRAWINGS.



|          |                                |          |    |
|----------|--------------------------------|----------|----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |          | A9 |
| Calc By: | ISG                            | Date:    |    |
|          |                                | 02/21/19 |    |

**EASE**

**EQUIPMENT ANCHORAGE & SEISMIC ENGINEERING**  
www.EquipmentAnchorage.com

**PEERLESS INDUSTRIES, INC.**

DES. **J. ROBERSON**

SHEET

**3**

JOB NO. **11-1502**


DATE **7/27/15**

OF **8** SHEETS

**UNIVERSAL FLAT AND TILT WALL MOUNT  
FOR FLAT TV WEIGHT UP TO 175 LB**

SEISMIC SUPPORTS & ATTACHMENTS

WALL MOUNTED



**NOTES:**


- FORCES ARE DETERMINED PER 2013 CALIFORNIA BUILDING CODE AND ASCE 7-10. STRENGTH DESIGN IS USED. ( $S_{ds} = 2.20$ ,  $a_p = 1.0$ ,  $I_p = 1.5$ ,  $R_p = 1.5$ ,  $\Omega_o = 1.5$ ,  $z/h \leq 1$ )

HORIZONTAL FORCE ( $E_h$ ) =  $2.64 W_p$

HORIZONTAL FORCE ( $E_{mh}$ ) =  $3.96 W_p$  (FOR CONCRETE ANCHORAGE)

VERTICAL FORCE ( $E_v$ ) =  $0.44 W_p$

- CENTER OF GRAVITY (C.G.) AND WEIGHT ARE THE GOVERNING PARAMETERS FOR DESIGN. THIS PREAPPROVAL ENCOMPASSES ALL WEIGHTS UP TO THE MAXIMUM WEIGHT SHOWN.
- STRUCTURAL ENGINEER OF RECORD FOR THE BUILDING SHALL PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN, IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.
- SEE GENERAL NOTES: SHEETS 1 AND 2



|          |                                |       |          |     |
|----------|--------------------------------|-------|----------|-----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | A10 |
| Calc By: | ISG                            | Date: | 02/21/19 |     |

**EASE**

**EQUIPMENT ANCHORAGE & SEISMIC ENGINEERING**  
www.EquipmentAnchorage.com

**PEERLESS INDUSTRIES, INC.**

DES. **J. ROBERSON**

SHEET

**4**

JOB NO. **11-1502**



DATE **7/27/15**

OF **8** SHEETS

**UNIVERSAL FLAT AND TILT WALL MOUNT  
FOR FLAT TV WEIGHT UP TO 175 LB**

SEISMIC SUPPORTS & ATTACHMENTS

WALL MOUNTED





|          |                                |       |          |     |
|----------|--------------------------------|-------|----------|-----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | A11 |
| Calc By: | ISG                            | Date: | 02/21/19 |     |

Corners and intersections on the face of the cabinet and door are structurally formed for rigidity, cleanability and appearance. Both models are supported on a stainless-steel integral subbase. The cabinet doors are available in solid vinyl coated galvanized steel material with stainless steel inside and include optional tempered double pane glass window(s). Interior cabinet shelves (wire racks) are polyester powder coated steel. Interior air ducts and fan guards are flame retardant Acrylonitrile Butadiene Styrene (ABS) material. If a freestanding model, the cabinet top and side panels are vinyl coated galvanized steel.

Doors are of double-wall construction with 1-1/2" (38 mm) thick insulation between the walls. Right-hand door swing is provided; swing is reversible. Door closes against a heat-resistant, magnet-imbedded, vinyl gasket. Pivot type hinges are stainless steel.

**Heating chamber** compartment is insulated with 1" (25 mm) thick, fiberglass blanket. An impedance protected fan circulates air within the chamber to provide even heat distribution.

**Lower chamber (dual-compartment model)** includes two polyester powder coated steel wire rack shelves, adjustable in 3" (76 mm) increments. Door structure mounting, gasket and hinges are the same as the door on the upper chamber.

Chamber(s) is heated by an electric rod heater operating on 120 or 230 Volt, 50/60 Hz power.

#### ENGINEERING DATA

| Unit                               | Approx. Unit Wt. lb (kg) |
|------------------------------------|--------------------------|
| <b>Single-Compartment:*</b>        |                          |
| 18" (457 mm) Wall/Counter Mounting | 131 (60)                 |
| 18" (457 mm) Recess Mounting       | 105 (48)                 |
| 24" (610 mm) Wall/Counter Mounting | 142 (65)                 |
| 24" (610 mm) Recess Mounting       | 115 (52)                 |
| <b>Dual-Compartment:†</b>          |                          |
| 18" (457 mm) Open-Mounted          | 324 (147)                |
| 18" (457 mm) Recessed Mounting     | 288 (131)                |
| 24" (610 mm) Open-Mounted          | 375 (170)                |
| 24" (610 mm) Recessed Mounting     | 328 (149)                |
| 24" (610 mm) Mobile Base           | 483 (219)                |

\* For glass door option, add 6 lb (2.7 kg).

† For all glass door options except 18" (457 mm), add 14 lb (6 kg); for 18" (457 mm) glass door option, add 48 lb (22 kg).

#### CONTROLS

**Cabinet controls** are digital and similar for single- and dual-compartment configurations. Both controls have a Main Power on/off switch.

The double cabinet control panel has control and temperature display functions for both cabinets. The upper cabinet control includes an on/standby key and digital temperature display. Also included is a °F/°C temperature display selection key and a SET temperature key with incremental raise/lower temperature set keys. LED lights indicate the on/standby status for cabinet heating, door ajar indication and SET selections have been made. The lower cabinet control includes an on/standby switch and digital temperature display. The lower cabinet also includes a SET temperature switch with incremental raise/lower temperature set keys. Temperature control lockout designates user adjustment.

The single cabinet control panel has control and temperature display functions including an on/standby switch, digital temperature display, °F/°C selection key and a SET temperature key with incremental raise/lower temperature set keys. LED lights indicate the on/standby status for cabinet heating, door ajar position and when SET selections have been made.

Upper compartment and single compartment controls include IV and IRR/Blanket mode setting switches, limiting temperature set ranges to 90-110°F (32.2-43.3°C) and 90-160°F (32.2-71.1°C), respectively. For lower compartment controls, the temperature selection range is 90-160°F (32.2-71.1°C).

Both controls monitor and regulate the heating of the interior compartment(s). The control for upper or single compartment ensures a temperature accuracy of ±3°F (±1.7°C) when warming IV/irrigation solution. The control for lower compartment ensures a temperature accuracy of ±5°F (±2.8°C) when warming irrigation solution.

An overtemperature alarm visually and audibly alerts operator should an overtemperature condition occur (chamber temperature greater than 10°F [5.5°C] above set temperature). In the event of an overtemperature condition, the overtemperature control automatically turns off the heater(s).

An optional USB peripheral connection allows Customer to plug a PC or laptop computer into the warming cabinet to retrieve stored temperature data from control memory. The data is stored or printed from the computer. Data capture software for use on PC is provided with the warming cabinet.

#### MOUNTING ARRANGEMENT

Dual-compartment models may be installed as freestanding or recessing into a partition wall. If model is recess installed, a synthetic-rubber sealing gasket is provided to ensure close fit of cabinet front to the face of the wall partition. Recessed cabinet requires no supplementary supports behind the wall partition (except in seismic locations).

Single-compartment models may be installed freestanding on shelf or counter surfaces or recessed into a partition wall.

|          |                                |       |          |     |
|----------|--------------------------------|-------|----------|-----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | A12 |
| Calc By: | ISG                            | Date: | 02/21/19 |     |

## OPTIONS

**Mobile base** with bumpers (for dual 24" [610 mm] deep cabinets only). Casters are used to allow warming cabinet mobility. Press foot lever down to lock; push foot lever in to unlock.

**USB port** for temperature recording.

**Electrical numeric keypad door locks** are available for keyless entry.

## PREVENTIVE MAINTENANCE

A global network of skilled service specialists can provide periodic inspections and adjustments to help ensure cost-effective performance. STERIS representatives can provide information regarding annual maintenance agreements.

## NOTES

1. Due to the variety of building constructions employed, fasteners for mounting cabinet to wall are not provided by STERIS. Wall(s) must be adequately reinforced to support operating weight of cabinet.
2. Customer must ensure warming cabinet is installed per applicable seismic requirements.

## INTERNAL DIMENSIONS AND CAPACITY

| Unit      | Upper Chamber Single Chamber Unit<br>(Height x Width x Depth) | Lower Chamber Double Chamber Unit<br>(Height x Width x Depth) |
|-----------|---------------------------------------------------------------|---------------------------------------------------------------|
| 18" Depth | 13-1/2 x 24 x 16-7/8" = 3.1 cu. ft.<br>(343 x 610 x 429 mm)   | 36-1/2 x 24 x 16-7/8" = 8.5 cu. ft.<br>(927 x 610 x 429 mm)   |
| 24" Depth | 13-1/2 x 24 x 22-7/8" = 4.2 cu. ft.<br>(343 x 603 x 581 mm)   | 36-1/2 x 24 x 22-7/8" = 11.6 cu. ft.<br>(927 x 603 x 581 mm)  |

## UTILITY REQUIREMENTS – Single Compartment Model

### Electricity (E)

120 Volt, 50/60 Hz, 1-Phase, 7.0 Amps, 840 Watts; or  
230 Volts, 50/60 Hz, 1-Phase, 3.6 Amps, 869 Watts


**CUSTOMER IS RESPONSIBLE FOR COMPLIANCE WITH APPLICABLE LOCAL AND NATIONAL CODES AND REGULATIONS.**

|          |                                |       |          |
|----------|--------------------------------|-------|----------|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          |
| Calc By: | ISG                            | Date: | 02/21/19 |

A13

Reference listed equipment drawing for detailed installation specifications.  
Obtain this drawing from your STERIS Representative.

| Equip. Dwg. No. | Equipment Drawing Title                                                           |
|-----------------|-----------------------------------------------------------------------------------|
| 413726-638      | 30 x 18 x 74" Warming Cabinet Electric, Freestanding or Recessed Dual Compartment |
| 413726-640      | 30 x 24 x 74" Warming Cabinet Electric, Freestanding or Recessed Dual Compartment |







**COOK**

|          |                                |       |          |            |
|----------|--------------------------------|-------|----------|------------|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | <b>A14</b> |
| Calc By: | ISG                            | Date: | 02/21/19 |            |




|                           |
|---------------------------|
| <b>MARK: EF-1</b>         |
| <b>PROJECT: COOK FANS</b> |
| <b>DATE: 1/10/2019</b>    |

## SQI-B

**Square Centrifugal  
Inline  
Belt Drive**

### STANDARD CONSTRUCTION FEATURES:

All aluminum wheel - Minimum 18 gauge Lorenized steel housing - Hinged access door sizes 90 thru 180 - Removable access door sizes 195 thru 402 - Straightening vanes - Bearings rated at 200,000 hours average life - Adjustable pitch drives through 5 hp - All fans factory adjusted to specified fan RPM.



Motor and access door positions are designated from the discharge end.  
3:00 motor & 9:00 access door positions shown.

### Performance (\*Bhp includes 7% drive loss)

| Qty | Catalog Number | Flow (CFM) | SP (inwc) | Fan RPM | Power* (HP) | FEG |
|-----|----------------|------------|-----------|---------|-------------|-----|
| 1   | 165SQIB        | 3700       | 1.00      | 1617    | 1.75        | 56  |

Altitude (ft): 0 Temperature (F): 70

### Motor Information

| HP | RPM  | Volts/Ph/Hz | Enclosure | FLA  | Position | Mounted |
|----|------|-------------|-----------|------|----------|---------|
| 2  | 1725 | 208/1/60    | ODP -SE   | 13.2 | 3:00     | Yes     |

FLA based on NEC (2014) Table 430.248

### Fan Information

| Fan Mount     | Access |
|---------------|--------|
| Horz. Ceiling | 9:00   |

### Sound Data Inlet Sound Power by Octave Band

| 1  | 2  | 3  | 4  | 5  | 6  | 7  | 8  | LwA | dBA | Sones |
|----|----|----|----|----|----|----|----|-----|-----|-------|
| 91 | 95 | 92 | 88 | 82 | 78 | 74 | 69 | 89  | 78  | 30    |

### Accessories:

DRIVES (1.5 SF) @ 1617 RPM  
GRAV DAMPER-165 SQI


### Dimensions (inches)

|          |          |
|----------|----------|
| <b>A</b> | 23-13/16 |
| <b>B</b> | 25-5/16  |
| <b>C</b> | 27-3/4   |
| <b>D</b> | 26-15/16 |
| <b>E</b> | 14-5/16  |

NOTE: Accessories may affect dimensions shown.

|                       |                 |            |             |            |
|-----------------------|-----------------|------------|-------------|------------|
| <b>Weight(lbs)***</b> | <b>Shipping</b> | <b>310</b> | <b>Unit</b> | <b>208</b> |
|-----------------------|-----------------|------------|-------------|------------|

\*\*\*Includes fan, motor & accessories.



### Fan Curve Legend

|                    |     |
|--------------------|-----|
| CFM vs SP (1617)   | —   |
| MaxRPM (1833)      | —   |
| MinRPM (771)       | —   |
| CFM vs HP          | —   |
| Point of Operation | ○   |
| System Curve       | --- |



**COOK**

|          |                                |       |          |     |
|----------|--------------------------------|-------|----------|-----|
| Job:     | 18SHA11 ARMC Ambulatory Clinic |       |          | A15 |
| Calc By: | ISG                            | Date: | 02/21/19 |     |




|                    |
|--------------------|
| MARK: RF-1         |
| PROJECT: COOK FANS |
| DATE: 1/10/2019    |

## SQI-B

Square Centrifugal  
Inline  
Belt Drive

### STANDARD CONSTRUCTION FEATURES:

All aluminum wheel - Minimum 18 gauge Lorenized steel housing - Hinged access door sizes 90 thru 180 - Removable access door sizes 195 thru 402 - Straightening vanes - Bearings rated at 200,000 hours average life - Adjustable pitch drives through 5 hp - All fans factory adjusted to specified fan RPM.



Motor and access door positions are designated from the discharge end.  
3:00 motor & 9:00 access door positions shown.

### Performance (\*Bhp includes 5% drive loss)

| Qty | Catalog Number | Flow (CFM) | SP (inwc) | Fan RPM | Power* (HP) | FEG |
|-----|----------------|------------|-----------|---------|-------------|-----|
| 1   | 300SQIB        | 14500      | 1.50      | 949     | 7.37        | 63  |

Altitude (ft): 0 Temperature (F): 70

### Motor Information

| HP    | RPM  | Volts/Ph/Hz | Enclosure | FLA | Position | Mounted |
|-------|------|-------------|-----------|-----|----------|---------|
| 7-1/2 | 1725 | 460/3/60    | ODP -PE   | 11  | 3:00     | Yes     |

NEMA Premium® efficiency motor per MG-1 (2014) Table 12-12  
FLA based on NEC (2014) Table 430.250

### Fan Information

| Fan Mount     | Access |
|---------------|--------|
| Horz. Ceiling | 9:00   |

### Sound Data Inlet Sound Power by Octave Band

| 1  | 2  | 3  | 4  | 5  | 6  | 7  | 8  | LwA | dBA | Sones |
|----|----|----|----|----|----|----|----|-----|-----|-------|
| 88 | 91 | 94 | 85 | 83 | 80 | 73 | 66 | 90  | 78  | 30    |

### Accessories:

Premium Efficiency Motor (Min. 91.0%)  
DRIVES (1.5 SF) @ 949 RPM  
REINFORCED WHEEL

### Dimensions (inches)

|   |          |
|---|----------|
| A | 43-7/16  |
| B | 47-13/16 |
| C | 50-7/16  |
| D | 46-1/2   |
| E | 17-1/2   |

NOTE: Accessories may affect dimensions shown.

| Weight(lbs)*** | Shipping | 615 | Unit | 431 |
|----------------|----------|-----|------|-----|
|----------------|----------|-----|------|-----|

\*\*\*Includes fan, motor & accessories.

