

Issued: June 10, 2019

**ADDENDUM NO. 4
SPRING VALLEY LAKE ADA AND OVERLAY PROJECTS
WORK ORDER: H14932 & H15010
AREA: Spring Valley Lake**

~~BIDS OPEN 2:00 PM, THURSDAY, JUNE 13, 2019~~
BIDS OPEN 3:30 PM, THURSDAY, JUNE 13, 2019

By Email via ePro System or Facsimile and Regular Mail with Telephone Confirmation (Paper Plan Holders)

Amend the Special Provisions as follows:

1. The bid opening time and date as shown on page NB-1 is changed as follows:

BIDS OPEN 3:30 PM, THURSDAY, JUNE 13, 2019

2. Delete the Second paragraph of section 8-1.04B, titled "Standard Start" and replace with the following:

The Contractor shall diligently prosecute the work to completion before the expiration of

ONE HUNDRED AND TWENTY (120) WORKING DAYS

starting with the First Working Day Designated. (Refer to the definition of "Working Day" in section 1-1.07B of these Special Provisions.) However, as provided in section 8-1.04A, the failure by Contractor to provide the required submittals identified in the Notice to Proceed with Submittals within the time frame specified in the Notice to Proceed with Submittals may subject the Contractor to being charged working days for each day and every day after the submittal due date.

The following question(s) have been received by bidders:

A complete list of questions and answers was attached in "*Spring Valley Lake ADA RAMPS & Overlay Addendum 3 - Q&A*"

The previous answer to Question #8 is revised to read "Traffic will be allowed on the SAMI for up to a maximum of seven (7) days prior to overlay."

Attached to this addendum is the previously indicated *County Standard Drawing 109 (Modified) Addendum 3.*

Addendum No. 4

SPRING VALLEY LAKE ADA RAMPS AND VARIOUS ROADS OVERLAY PROJECT

June 10, 2019

Page 2 of 2

The addition of these requirements shall be considered in concert with existing documents in preparation of bids. **THE BIDDER'S CERTIFICATION FOR THIS ADDENDUM NO. 4 SHALL BE SIGNED BY THE SAME PERSON WHO SIGNS THE PROPOSAL AND SHALL BE SUBMITTED WITH THE PROPOSAL. ANY proposal not accompanied by a signed BIDDER'S CERTIFICATION (below) acknowledging receipt of this Addendum No. 4 will NOT be accepted.**

KEVIN BLAKESLEE, Director
Department of Public Works

By: 

MOHAMMAD ALI, P.E., Chief
Contracts Division

BIDDER'S CERTIFICATION

By my signature hereunder, I acknowledge receipt of Addendum No. 4 and I fully understand the intent and detail of Addendum No. 4, which I have considered in my preparation of the attached proposal.


Bidder's Signature

Date


Note: The page containing the executed BIDDER'S CERTIFICATION (just this page), must be included with the proposal.

Attachments:


County Standard Drawing 109 (modified) Addendum 3




TYPE "A"



TYPE "B"



TYPE "C"



TYPE "D"

1. TYPE "C" SIDEWALKS ADJACENT TO CURB SHALL ONLY BE USED ON LOCAL AND COLLECTOR STREETS AND ONLY UPON APPROVAL OF THE TRANSPORTATION DEPT.
2. SIDEWALK SHALL BE CONSTRUCTED OF ~~CLASS "B"~~ CONCRETE.
3. WEAKENED PLANE JOINTS SHALL BE CONSTRUCTED ON 10' SPACING.
4. SCORING SIDEWALK WILL BE PERMITTED.
5. IN EXPANSIVE SOIL AREAS, REFER TO SECTION 73 OF THE COUNTY SPECIFICATIONS.

San Bernardino County Transportation Department

APP. MAR. 1975

John R. Shone

DIRECTOR OF TRANSPORTATION

SIDEWALK

109

(MODIFIED) Addendum 3