
Short Net (1)       Text (2)       Co (				- A	NE					· • • • •	<b></b>					
A.B. RUNK       2.5		<n>PANEL</n>		'F:	S'				VOL	TAGE			120/	208	V	
Description       model       dot Add/no       model       Description         0 <th></th> <th>LOCATION FUEL S</th> <th>STATI</th> <th>ON</th> <th></th> <th></th> <th></th> <th></th> <th></th> <th></th> <th></th> <th></th> <th>NQC</th> <th>D</th> <th></th> <th></th>		LOCATION FUEL S	STATI	ON									NQC	D		
Image: 1         Image: 1         Image: 2		AIC RATING 22 KAI	2						PHA	.SE	3		WIR	E	4	
1         1         1         2		DESCRIPTION									_		<u> </u>		DESCRIPTION	
2       000       1       200       000       1       000       1       000       1       0000       0000       0000       0000 <td>1</td> <td>EPO RELAY</td> <td>-</td> <td>_</td> <td></td> <td></td> <td></td> <td></td> <td>l –</td> <td></td> <td></td> <td>-</td> <td></td> <td></td> <td>UNLEA DED DISPENSER</td> <td>2</td>	1	EPO RELAY	-	_					l –			-			UNLEA DED DISPENSER	2
9         9         1         X         0	3	CONTROL CIRCUIT	1	20				1	1.7		0.0		-	-		4
2       3       1       2	5	WP RECEPT	1	20		0.0	0.						2	20	DIESEL DISPENSER	6
9         9	7	SPARE	1	20		0.0		0.2					-	-		8
<sup>1</sup> / <sub>2</sub> So So F <sup>1</sup> / <sub>2</sub> Ab Co F	9	SPA RE	1	20		0.0			1.7		0.0		1	20	SPARE	10
1         1         0	11	SPA RE	1	20		0.0					0.0		1	20	SPARE	12
Image: Sector in the sector	13	SPA RE	1	20		0.0					0.0		1	20	SPARE	14
Image: Sector in the sector			+	+	+	0.0					0.0				SPACE	16
eta box           etabox           etabox			+	<u> </u>	+	0.0		_			0.0	+			SPACE	18
21       98-52       2       99-52       25         25       96-52       2       3-30       3			+	<u> </u>	+	0.0					0.0	+			SPACE	
Simol         Simol <th< td=""><td></td><td></td><td>+</td><td>+</td><td>+</td><td>0.0</td><td></td><td></td><td></td><td></td><td>0.0</td><td></td><td></td><td></td><td>SPACE</td><td></td></th<>			+	+	+	0.0					0.0				SPACE	
2         MACR         0 <th0< th="">         0         0         0</th0<>			+	<u> </u>	+	0.0		_			0.0	<u> </u>			SPACE	
27       SNCE       30       <			+	+	+	0.0					0.0		$\vdash$		SPACE	
B         SNCC         B         CO         G         S         CO         SPACE         SPACE <th< td=""><td></td><td></td><td>+</td><td></td><td>+</td><td>0.0</td><td></td><td></td><td></td><td></td><td>0.0</td><td></td><td></td><td></td><td>SPACE</td><td></td></th<>			+		+	0.0					0.0				SPACE	
Skitt/Titl         0.3         0 <th0< th="">         0         0         <th< td=""><td></td><td></td><td>+</td><td><u> </u></td><td>+</td><td>0.0</td><td></td><td>_</td><td></td><td></td><td>0.0</td><td></td><td><math>\vdash</math></td><td></td><td>SPACE</td><td></td></th<></th0<>			+	<u> </u>	+	0.0		_			0.0		$\vdash$		SPACE	
Mail OR HUG Methodszi Freisen Kerrike ND Mound Methodszi Freisen Kerrike ND Mound Methodszi Freisen Kerrike ND Mound Methodszi Freisen Methodszi Freisen Methodsz	29															30
BURNING         125 AMES         TOTAL LOG PASEC         1         2 MA           DURNING         100000         100000         100000         100000         100000         1000000         10000000         1000000000         1000000000000000000000000000000000000					 s											
OPTIONS       1       CONTRUMENT       TOTAL INVEL LOAD (MARS)       TOTAL INVEL LOAD (MARS)         1       DETTOR MEAN       1       CONTRUMENT       TOTAL INVEL LOAD (MARS)       TOTAL INVEL LOAD (MARS)         2       DETTOR MEAN       1       CONTRUMENT       TOTAL INVEL LOAD (MARS)       TOTAL INVEL LOAD (MARS)         2       DETTOR MEAN       1       CONTRUMENT       TOTAL INVEL LOAD (MARS)       TOTAL INVEL LOAD (MARS)         2       DETTOR MEAN       1       CAL       TOTAL INVEL LOAD (MARS)       TOTAL INVEL LOAD (MARS)         2       DETTOR MEAN       -       LOAD (MARS)       TOTAL INVEL INVEL INVEL (MARS)       TOTAL INVEL INVEL (MARS)         2       DETTOR MEAN       -       LOAD (MARS)       TOTAL INVEL INVEL (MARS)       TOTAL INVEL INVEL (MARS)         2       DETTOR MEAN       -       LOAD (MARS)       TOTAL INVEL (MARS)       TOTAL INVEL (MARS)         2       DETTOR MEAN       -       LOAD (MARS)       TOTAL INVEL (MARS)       TOTAL INVEL (MARS)         1       DETTOR MEAN       -       LOAD (MARS)       TOTAL INVEL (MARS)       TOTAL INVEL (MARS)         1       DETTOR MEAN       TOTAL INVEL (MARS)       TOTAL INVEL (MARS)       TOTAL INVEL (MARS)       TOTAL INVEL (MARS)         1       DE		BUS RATING	125	AMPS	S	(ED)			TOTA	LLOAD	PHASE	С	215 2	Δ 1)	2 KVA	
I EBROCKINSC:         2 COMPRISING           3 COMPRISING         3 COMPRISING           3 COMPRISING         3 COMPRISING           3 COMPRISING         3 COMPRISING           1 EBROCKINSC:         1 CA           2 EBROCKINSC:         1 CA			<u>,</u> ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	. v∹\IVI⊏		ىت.			TOTA	LPANE	LOAD	(KVA)		/s. 1)	7 KVA	
2         DOOR NILCOURIE           2         DOOR NILCOURIE         120/2017         120/		1 FED FROM 'MSA'							1014			(AIVIPS	))			
'LA'         VOLTAGE         120/208 V           LOCATION         SERVICE AREA         TYPE            AIG RATING          PHASE         3         WIRE         4           DESCRIPTION         BRYGE 100 WBST- REDEPT         1         0.0         0.0         1         20         SERVICE 100 SERVICE 103 - REDEPT         2           1         SREVICE 100 WBST- REDEPT         1         0.0         0.4         0.0         1         20         SERVICE 103 - REDEPT         2           1         SREVICE 100 WBST- REDEPT         1         0.0         0.4         0.4         0.0         1         20         SERVICE 103 - REDEPT         4           5         SREVICE 103 WBST- REDEPT         1         0.0         0.4         0.4         0.0         1         20         SERVICE 103 W- CORD RELS         1         10         0.0         0.0         0.0         0.0         0.0         1         20         SERVICE 108 W- CORD RELS         1         10         0.0         0.0         0.0         0.0         0.0         1         10         10         0.0         0.0         1         10         10         10         10         0.0																
'LA'         VOLTAGE         120/208 V           LOCATION         SERVICE AREA         TYPE            AIG RATING          PHASE         3         WIRE         4           DESCRIPTION         BRYGE 100 WBST- REDEPT         1         0.0         0.0         1         20         SERVICE 100 SERVICE 103 - REDEPT         2           1         SREVICE 100 WBST- REDEPT         1         0.0         0.4         0.0         1         20         SERVICE 103 - REDEPT         2           1         SREVICE 100 WBST- REDEPT         1         0.0         0.4         0.4         0.0         1         20         SERVICE 103 - REDEPT         4           5         SREVICE 103 WBST- REDEPT         1         0.0         0.4         0.4         0.0         1         20         SERVICE 103 W- CORD RELS         1         10         0.0         0.0         0.0         0.0         0.0         1         20         SERVICE 108 W- CORD RELS         1         10         0.0         0.0         0.0         0.0         0.0         1         10         10         0.0         0.0         1         10         10         10         10         0.0																
DESCRIPTION         BMR         IVA LOAD         IVA LOAD         IVA LOAD         BRR         DESCRIPTION           1         BERVICE 110 WEST - RECEPT         1         0.0         0.4         0.4         0.0         1         20         SERVICE 110 KEST - RECEPT         2           3         SERVICE 110 WEST - RECEPT         -         0.0         0.4					•				TYP	Ξ		-				
P         T         LOL         A         B         C         C			-		T			,	PHA	SE	3		WIRI	E		
1       SERVICE 110 WEST-RECEPT       2       0.4       0.4       0.0       1       22       SERVICE 110 WEST-RECEPT       2         3       SERVICE 110 WEST-RECEPT       3       20       0.0       0.4       0.4       0.0       1       22       SERVICE 110 SW-CORD RELS       1       0.0       0.4       0.4       0.0       1       22       SERVICE 110 SW-CORD RELS       1       0.0       0.5       0.0       0.0       2       20       SERVICE 110 NE-RECEPT       12         11       SERVICE 110 NE-CORD RELS       1       20       0.0       0.5       0.4       0.0       1       23       SERVICE 110 NE-RECEPT       14         15       SERVICE 110 NE-CORD RELS       1       20       0.0       0.5       0.4       0.0       1       23       SERVICE 110 NE-RECEPT       14         15       SERVICE 110 NE-CORD RELS       1       20       0.0       0.5       0.4       0.0       1       23       SERVICE 110 NE-RECEPT       14         15       SERVICE 110 NE-CORD RELS       1       20		DESCRIPTION									<u> </u>	CL			DESCRIPTION	
3       0       0       0       0       0       0       0       0       1       20       SERVICE 110 WEST - RECEPT       0       0       0       1       20       SERVICE 110 WEST - RECEPT       6         7       SERVICE 110 WEST - RECEPT       1       20       0.0       0.5       0.5       0.5       0.5       0.0       2       20       SERVICE 110 WE - RECEPT       120       0.0       0.5       0.5       0.5       0.5       0.0       -       -       SERVICE 110 WE - RECEPT       120       0.0       0.5       0.5       0.4       0.4       0.0       0.5       0.0       -       -       SERVICE 110 WE - RECEPT       120       0.0       0.5       0.4       0.0       0.5       0.4       0.4       0.4       0.0       0.5       0.4       0.4       0.0       0.5       0.4       0.4       0.0       0.5       0.5       0.4       0.5       0.4       0.5 <td< td=""><td>1</td><td>SERVICE 110 WEST - RECEPT</td><td>-</td><td>-</td><td></td><td></td><td>0.4</td><td></td><td>0.4</td><td></td><td>0.0</td><td></td><td>1</td><td>20</td><td>SERVICE 110 S - RECEPT</td><td>2</td></td<>	1	SERVICE 110 WEST - RECEPT	-	-			0.4		0.4		0.0		1	20	SERVICE 110 S - RECEPT	2
a         b         c <thc< th="">         c         c         c</thc<>	3	SERVICE 110 WEST - RECEPT	3	20	(	0.0	0.4	4		0.4	0.0		1	20	SERVICE 110 S - RECEPT	4
1         0         0.5         0.5         0.6         0.6         0.7         SERVICE 110 SW- CORD REELS         1         20         0.0         0.5         0.6         0.0         -         SERVICE 110 SW- CORD REELS         1         20         0.0         0.5         0.0         -         SERVICE 110 N- RECEPT         1         20         0.0         0.5         0.4         0.0         3         20         SERVICE 110 N- RECEPT         1           13         SERVICE 110 N- RECEPT         1         20         0.0         0.4         0.0         3         20         SERVICE 110 N- RECEPT         14           15         SERVICE 110 N- CORD REELS         2         20         0.0         0.5         0.4         0.0         -         -         SERVICE 110 N- RECEPT         16           17         SERVICE 110 N- CORD REELS         1         0.0         0.5         0.0         -         -         SERVICE 110 N- CORD REELS         22           21         PREALARM ORCUT         1         20         0.0         0.5         0.0         -         -         SERVICE 110 N- CORD REELS         22           23         SERVICE 110 N- ROL RELS         0.0         0.5         0.5         0.0	5	SERVICE 110 WEST - RECEPT	-	-		0.0		0.4					1	20	SERVICE 110 S - RECEPT	6
BERVICE 110 SW- CORD REELS         1         20         0.0         0.5         0.5         0.6         0.0         -         SERVICE 110 SE- CORD REELS         10           11         SERVICE 110 N- RECEPT         1         20         0.0         0.5         0.4         0.0         -         -         SERVICE 110 NE- RECEPT         12           13         SERVICE 110 NE- CORD REELS         2         20         0.0         0.5         0.4         0.0         3         20         SERVICE 110 NE- RECEPT         14           15         SERVICE 110 NE- CORD REELS         -         0.0         0.5         0.4         0.0         -         SERVICE 110 NE- RECEPT         14           16         SERVICE 110 NE- CORD REELS         -         0.0         0.5         0.5         0.0         -         SERVICE 110 NE- CORD REELS         12           21         FIRE ALA RMORCUT         1         20         0.0         0.5         0.5         0.0         1         20         SERVICE 110 W- CORD REELS         20           22         0         0.5         0.5         0.0         1         20         SERVICE 110 W- CORD REELS         22           23         GERENTOR- BATTERY         1	7	SERVICE 110 SW - CORD REELS	1	20			0.5		0.5		0.0		2	20	SERVICE 110 SE - CORD REELS	8
11       SERVICE 110 SW- CORD REELS       1       20       0.0       0	9	SERVICE 110 SW - CORD REELS	1	20				5		0.5	0.0		-	-	SERVICE 110 SE - CORD REELS	10
13       SERVICE 110 N - RECEPT       1       20       0.0       0.4       0.4       0.0       3       20       SERVICE 110 NE - RECEPT       14         16       SERVICE 110 NE - CORD REELS       2       20       0.0       0.5       0.4       0.0       -       -       SERVICE 110 NE - RECEPT       16         17       SERVICE 110 NE - CORD REELS       -       0.0       0.5       0.5       0.0       3       20       SERVICE 110 NW - CORD REELS       20         13       SERVICE 110 ILTGEXIT SIGNS       1       20       0.0       1.1       0.5       0.0       3       20       SERVICE 110 NW - CORD REELS       20         21       IREALARM CIRCUIT       1       20       0.0       0.5       2.0       0.0       1       20       SERVICE 110 NW - CORD REELS       20         23       GENERATOR - BATTERY       1       20       0.0       0.5       2.0       0.0       1       20       SERVICE 110 NW - CORD REELS       22         24       GENERATOR - BATTERY       1       20       0.0       0.5       2.0       0.0       1       20       SERVICE 110 NW - CORD REELS       22         25       FFARE       1       20	11	SERVICE 110 SW - CORD REELS	1	20		0.0							-	-	SERVICE 110 NE - RECEPT	
15       SERVICE 110 NE - CORD RELS       2       20       0.0       0.5       0.4       0.0       -       -       SERVICE 110 NE - RECEPT       16         17       SERVICE 110 NE - CORD RELS       -       0.0       0.5       0.6       0.5       0.0       -       -       SERVICE 110 NE - RECEPT       16         13       SERVICE 110 LTGREAT SIGNS       1       20       0.0       0.1       0.5       0.0       3       20       SERVICE 110 NW - CORD RELS       20         21       FRE ALARM CIRCUIT       1       20       0.0       0.5       0.5       0.0       -       -       SERVICE 110 NW - CORD RELS       22         23       GENERATOR - BATTERY       1       20       0.0       0.5       2.0       0.0       1       20       SERVICE 110 NW - CORD RELS       22         24       GENERATOR - BATTERY       1       20       0.0       0.5       2.0       0.0       1       20       SERVICE 110 NW - CORD RELS       22         25       GENERATOR - BATTERY       1       20       0.0       0.0       1       20       SERVICE 110 NW - CORD RELS       22         26       SERVICE 110 NW - CORD RELS       20       0.0	13	SERVICE 110 N - RECEPT	1	20	<u> </u> ,			0.5				+				12
17       SERVICE 110 NE - CORD REELS       -       -       0.0       0.5       0.0       -       -       SERVICE 110 NW - CORD REELS       18         19       SERVICE 110 LTGRENT SIGNS       1       20       0.0       1.1       0.5       0.0       3       20       SERVICE 110 NW - CORD REELS       20         21       IREALARM CIRCUIT       1       20       0.0       0.5       0.0       -       -       SERVICE 110 NW - CORD REELS       20         23       GENERATOR - BATTERY       1       20       0.0       0.5       2.0       0.0       1       20       SERVICE 110 NW - CORD REELS       22         26       GENERATOR - BATTERY       1       20       0.0       0.5       2.0       0.0       1       20       SERVICE 110 NW - CORD REELS       22         26       GENERATOR - BATTERY       1       20       0.0       0.5       2.0       0.0       1       20       SERVICE 110 NW - CORD REELS       22         27       SPARE       1       20       0.0       0.0       1       20       SERVICE 110 NW - CORD REELS       28         28       SERVICE 110       1       20       0.0       0.0       1       20				1	. 1		0.4		0.4				3	20	SERVICE TTU NE - RECEPT	
19       SERVICE 110 LTGIENT SIGNS       1       20       0.0       1.1       0.5       0.0       3       20       SERVICE 110 NW- CORD REELS       20         21       PREALARM CIRCUIT       1       20       0.0       0.5       0.5       0.0       -       -       SERVICE 110 NW- CORD REELS       22         23       GENERATOR - BATTERY       1       20       0.0       0.5       2.0       0.0       1       20       SERVICE 110 NW- CORD REELS       22         23       GENERATOR - BATTERY       1       20       0.0       0.5       2.0       0.0       1       20       SERVICE 110 NW- CORD REELS       22         24       GENERATOR - BATTERY       1       20       0.0       0.5       2.0       0.0       1       20       SERVICE 110 NW- CORD REELS       22         25       GENERATOR - BLOCK HEATER       1       20       0.0       0.0       1       20       SERVICE 110 NW- COLL UP DOOR       26         27       SPARE       1       20       0.0       0.0       1       20       SERVICE 110 W- ROLL UP DOOR       26         28       TOTALLOK PLASTA       0.0       0.0       0.0       0.0       0.0       1 <td>15</td> <td>SERVICE 110 NE - CORD REELS</td> <td>2</td> <td>20</td> <td>+</td> <td>_</td> <td></td> <td></td> <td>0.4</td> <td>0.1</td> <td>0.0</td> <td></td> <td></td> <td></td> <td></td> <td>14</td>	15	SERVICE 110 NE - CORD REELS	2	20	+	_			0.4	0.1	0.0					14
1       PREALARM CIRCUIT       1       20       0.0       0.5       0.5       0.0       -       SERVICE 110 NW - CORD REELS       22         23       GENERATOR - BATTERY       1       20       0.0       0.5       0.5       0.0       1       20       SERVICE 110 W- ROLL UP DOOR       24         25       GENERATOR - BLOCK HEATER       1       20       0.0       0.5       2.0       0.0       1       20       SERVICE 110 W- ROLL UP DOOR       26         27       SPARE       1       20       0.0       0.5       0.0       1       20       MOTORIZED LOWERS       28         29						0.0					0.0		-	-	SERVICE 110 NE - RECEPT	14 16
23       GENERATOR - BATTERY       1       20       0.0       0.5       0.5       0.0       1       20       SERVICE 110 W- ROLL UP DOOR       24         25       GENERATOR - BLOCK HEATER       1       20       0.0       0.5       2.0       0.0       1       20       SERVICE 110 W- ROLL UP DOOR       26         27       SPARE       1       20       0.0       0.5       0.0       1       20       SERVICE 110 W- ROLL UP DOOR       26         29        -       0.0       0.0       0.0       0.0       1       20       MOTORZED LOUVERS       28         31       SPARE       3       30       0.0       0.0       0.0       3       30       SPARE       32         33        -       0.0       0.0       0.0       0.0       1       30       SPARE       32         34        -       0.0       0.0       0.0       1       30       SPARE       32         35        -       0.0       0.0       1.5       0.0       1       20       SERVICE 110 W- ROLL UP DOOR       24         36        0.0       0.0	17	SERVICE 110 NE - CORD REELS	-	-		0.0	0.5				0.0		-	-	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS	14 16 18
Image: Service	17 19	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS	-	- 20		0.0 0.0 0.0	1.1	0.5			0.0		- 3	- - 20	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS	14 16 18 20
23       0.5       2.0       0.6       0.2       2.0       2.	17 19 21	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT	- 1 1	- 20 20		0.0 0.0 0.0 0.0	1.1	0.5	0.5	0.5	0.0 0.5 0.0 0.0 0.0 0.0		- - 3 -	- - 20 -	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS	14 16 18 20 22
27       -       -       -       0.0       -       -       -       -       30         31       SPARE       3       30       0.0       0.0       -       -       -       -       30         31       SPARE       3       30       0.0       0.0       3       30       SPARE       32         31       SPARE       -       -       0.0       0.0       -       -       -       -       32         33       -       -       0.0       0.0       0.0       -       0.0       1       1       20       SITE SIGN       -       -       -       -       -       -       -       -       -       -       -       -       -       0.0       1       1       20       SITE SIGN       -       -       -       -       -       -       -       - <td< td=""><td>17 19 21 23</td><td>SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY</td><td>- 1 1 1</td><td>- 20 20 <b>20</b></td><td></td><td>0.0 0.0 0.0 0.0 0.0 0.0</td><td>0.5 1.1 0.5</td><td>0.5</td><td>0.5</td><td>0.5</td><td>0.0 0.5 0.0 0.0 0.0 0.0</td><td></td><td>- - 3 - 1</td><td>- 20 - 20</td><td>SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR</td><td>14 16 18 20 22 22 24</td></td<>	17 19 21 23	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY	- 1 1 1	- 20 20 <b>20</b>		0.0 0.0 0.0 0.0 0.0 0.0	0.5 1.1 0.5	0.5	0.5	0.5	0.0 0.5 0.0 0.0 0.0 0.0		- - 3 - 1	- 20 - 20	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR	14 16 18 20 22 22 24
29       30 <td< td=""><td>17 19 21 23 25</td><td>SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER</td><td>- 1 1 1 1</td><td>- 20 20 <b>20</b> <b>20</b> <b>20</b></td><td></td><td>0.0 0.0 0.0 0.0 0.0 0.0</td><td>0.5 1.1 0.5</td><td>0.5</td><td>0.5</td><td>0.5</td><td>0.0 0.0 0.0 0.0 0.0 2.0 0.0</td><td></td><td>- - 3 - 1 1</td><td>- 20 - 20 20</td><td>SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR</td><td>14 16 18 20 22 22 24 26</td></td<>	17 19 21 23 25	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER	- 1 1 1 1	- 20 20 <b>20</b> <b>20</b> <b>20</b>		0.0 0.0 0.0 0.0 0.0 0.0	0.5 1.1 0.5	0.5	0.5	0.5	0.0 0.0 0.0 0.0 0.0 2.0 0.0		- - 3 - 1 1	- 20 - 20 20	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR	14 16 18 20 22 22 24 26
31	17 19 21 23 25 27	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE	- 1 1 1 1 1 1 1	- 20 20 20 20 20 20		0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.5 1.1 0.5	0.5	0.5	0.5	0.0 0.5 0.0 0.0 0.0 0.0 0.0 0.0 0.2	X	- 3 - 1 1 1 1	- 20 20 20 20 20	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS	14 16 18 20 22 24 24 26 28
33       -       -       0.0       -       -       34         35	17 19 21 23 25 27 29	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE	- 1 1 1 1 1 1 -	- 20 20 20 20 20 20 -		0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0	0.5 1.1 0.5	0.5	0.5	0.5	0.5 0.0 0.5 0.0 0.0 0.0 0.0 0.2 0.0	x	- 3 - 1 1 - 1 -	- 20 20 20 20 -	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS	14 16 18 20 22 22 24 24 26 28 30
33       33       35       0       0.0       0.5       0       36       36         37       SPARE       3       50       0.0       1.5       0.0       1       20       SITE SIGN       38         39        -       0.0       1.5       0.0       1       20       BUILDING SIGN       40         41       SPARE       1       30       0.0       0.0       1.5       0.0       1       20       BUILDING SIGN       40         41       SPARE       1       30       0.0       0.0       1.5       0.0       1       20       BUILDING SIGN       40         41       SPARE       1       30       0.0       0.0       1       20       RECEPT - WP       42         SUBTOTAL       0.0       3       2       2       5       4       4       0.2       SUBTOTAL         MCB       OR MLO       MCB       TOTAL LOAD PHASEA       TOTAL LOAD PHASEA       6       KVA         MOUNTING       225 AMPS       225 AMPS       TOTAL LOAD PHASE C       6       6       KVA         OPTIONS       1       CONTRACTOR SHALL PROVIDE NEW CIRCUIT BREAKER AT BOLD       TOTA	17 19 21 23 25 27 29 31	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE	- 1 1 1 1 1 1 - 3	- 20 20 20 20 20 20 20 30		0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0	0.5 1.1 0.5	0.5	0.5	0.5	0.5 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	x	- 3 - 1 1 - 1 3 3	- 20 20 20 20 20 30	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS	14 16 18 20 22 22 24 26 28 30 30
39	17 19 21 23 25 27 29 31	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE 	- 1 1 1 1 1 - 3 -	- 20 20 20 20 20 20 - 30 -		0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0       0.0	0.5 1.1 0.5	0.5	0.5	0.5	0.5 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	X	- 3 - 1 1 - 3 - 3 -	- 20 20 20 20 20 30 30	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS	14 16 18 20 22 22 24 26 28 30 30
39       1.5       1.	17 19 21 23 25 27 29 31 33 35	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE 	- 1 1 1 1 1 1 - 3 - -	- 20 20 20 20 20 20 - 30 - -		0.0	0.5 1.1 0.5	0.5	0.5	0.5 0.6 0.6	0.5 0.5 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	x	- 3 - 1 1 - 3 - 3 - 1 -	- 20 20 20 20 20 30 - 30	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE	14         16         18         20         22         24         26         28         30         32         34
41       0.0       3       2       2       5       4       4       0.2       42         SUBTOTAL       0.0       3       2       2       5       4       4       0.2       SUBTOTAL       42         MCB OR MLO         MAIN CIRCUIT BREAKER RATING       MCB       TOTAL LOAD PHASE A       8       KVA         BUS RATING       225 AMPS       TOTAL LOAD PHASE B       6       KVA         MOUNTING       225 AMPS       TOTAL LOAD PHASE C       6       KVA         MOUNTING       SURFACE       10 KVA       10 KVA       10 KVA         OPTIONS       TOTAL LOAD (KVA)       20 KVA       20 KVA         1       CONTRACTOR SHALL PROVIDE NEW CIRCUIT BREAKER AT BOLD       TOTAL PANEL LOAD (AMPS)       54       AMPS         1       CONTRACTOR SHALL PROVIDE NEW CIRCUIT BREAKER AT BOLD       TOTAL PANEL LOAD (AMPS)       54       AMPS         2       RETURN <e>SPARE BACK TO COUNTY.       Image: Count of the panel back to county.       Image: County of the panel back to county.       Image: County of the panel back to county.       Image: County of the panel back to county.</e>	17 19 21 23 25 27 29 31 33 35	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE 	- 1 1 1 1 1 1 - 3 - -	- 20 20 20 20 20 20 - 30 - -		0.0	0.5 1.1 0.5	0.5	0.5	0.5 0.6 0.6	0.5 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	×	- 3 - 1 1 - 3 - 3 - 1 1 1	- 20 20 20 20 30 - 30 30	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN	14         16         18         20         22         24         26         28         30         32         34         36
SUBTOTAL       0.0       3       2       5       4       4       0.2       SUBTOTAL         MCB OR MLO       MCB       TOTAL LOAD PHASE A       8       KVA         MAIN CIRCUIT BREAKER RATING       225 AMPS       TOTAL LOAD PHASE B       6       KVA         BUS RATING       225 AMPS       TOTAL LOAD PHASE C       6       KVA         MOUNTING       225 AMPS       TOTAL LOAD PHASE C       6       KVA         OPTIONS       SURFACE       TOTAL LOAD (NEC/CEC 215.2.A.1)       0       KVA         1       CONTRACTOR SHALL PROVIDE NEW CIRCUIT BREAKER AT BOLD CIRCUIT. MATCH EXISTING FOR RATING.       20       KVA         2       RETURN <e>SPARE BACK TO COUNTY.       AMPS</e>	17 19 21 23 25 27 29 31 33 35 37	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE  SPA RE SPA RE	- 1 1 1 1 1 1 - 3 - 3	- 20 20 20 20 20 20 20 - 30 - 30 - 50		0.0	0.5 1.1 0.5	0.5	0.5	0.5 2 0.6 0.6 0.6	0.5 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	×	- 3 - 1 1 - 3 - 3 - 1 1 1	- 20 20 20 20 30 - 30 30	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN	14 16 18 20 22 24 26 28 30 30 32 34 36 38
MAIN CIRCUIT BREAKER RATING       225 AMPS       TOTAL LOAD PHASE B       6 KVA         BUS RATING       225 AMPS       TOTAL LOAD PHASE C       6 KVA         MOUNTING       SURFACE       TOTAL LCL (NEC/CEC 215.2.A.1)       0 KVA         OPTIONS       TOTAL DAD (KVA)       20 KVA         OPTIONS       TOTAL PANEL LOAD (AMPS)       54 AMPS         1 CONTRACTOR SHALL PROVIDE NEW CIRCUIT BREAKER AT BOLD       CIRCUIT. MATCH EXISTING FOR RATING.       54 AMPS         2 RETURN <e>SPARE BACK TO COUNTY.       AMPS       54 AMPS</e>	117 19 21 23 25 27 29 31 33 35 37 39	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE  SPA RE  SPA RE	- 1 1 1 1 1 1 - 3 - 3 - 3 -	- 20 20 20 20 20 20 20 - 30 - 30 - 50 -		0.0	0.5 1.1 0.5	0.5	0.5	0.5 2 0.6 0.6 1.5	0.5 0.5 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	X	- 3 - 1 1 - 3 - 3 - 1 1 1 1 1 1 1	- 20 20 20 20 20 30 30 20 20	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN	14         16         18         20         22         24         26         28         30         32         34         36         38         40
MAIN CIRCUIT BREAKER RATING       225 AMPS       TOTAL LOAD PHASE B       6 KVA         BUS RATING       225 AMPS       TOTAL LOAD PHASE C       6 KVA         MOUNTING       SURFACE       TOTAL LCL (NEC/CEC 215.2.A.1)       0 KVA         OPTIONS       TOTAL DAD (KVA)       20 KVA         OPTIONS       TOTAL PANEL LOAD (AMPS)       54 AMPS         1 CONTRACTOR SHALL PROVIDE NEW CIRCUIT BREAKER AT BOLD       CIRCUIT. MATCH EXISTING FOR RATING.       54 AMPS         2 RETURN <e>SPARE BACK TO COUNTY.       AMPS       54 AMPS</e>	117 19 21 23 25 27 29 31 33 35 37 39	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE  SPA RE  SPA RE  SPA RE	- 1 1 1 1 1 1 - 3 - 3 - 3 - 1	- 20 20 20 20 20 20 20 - 30 - 30 - 50 -		0.0	0.5       1.1       0.5 </td <td>0.5</td> <td>0.5</td> <td>0.5 2 0.6 0.6 1.5</td> <td>0.5 0.0 0.5 0.0 0.0 0.0 0.0 0.0 0.0 0.0</td> <td>X</td> <td>- 3 - 1 1 - 3 - 3 - 1 1 1 1 1 1 1</td> <td>- 20 20 20 20 20 30 30 20 20</td> <td>SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP</td> <td>14         16         18         20         22         24         26         28         30         32         34         36         38         40</td>	0.5	0.5	0.5 2 0.6 0.6 1.5	0.5 0.0 0.5 0.0 0.0 0.0 0.0 0.0 0.0 0.0	X	- 3 - 1 1 - 3 - 3 - 1 1 1 1 1 1 1	- 20 20 20 20 20 30 30 20 20	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP	14         16         18         20         22         24         26         28         30         32         34         36         38         40
MOUNTING       SURFACE       TOTAL LCL (NEC/CEC 215.2.A.1)       0 KVA         TOTAL PANEL LOAD (KVA)       20 KVA         OPTIONS       TOTAL PANEL LOAD (KVA)       20 KVA         1 CONTRACTOR SHALL PROVIDE NEW CIRCUIT BREAKER AT BOLD       TOTAL PANEL LOAD (AMPS)       54 AMPS         2 RETURN <e>SPARE BACK TO COUNTY.       EACK TO COUNTY.       TOTAL PANEL LOAD (AMPS)       54 AMPS</e>	17 19 21 23 25 27 29 31 33 35 37 39 41	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE  SPA RE  SPA RE  SPA RE  SPA RE	- 1 1 1 1 1 - 3 - 3 - 3 - 1 1 AL	- 20 20 20 20 20 20 20 - 30 - 50 - 30		0.0	0.5       1.1       0.5 </td <td>0.5</td> <td>0.5</td> <td>0.5 0.6 0.6 0.6 0.6 0.6 0.6 0.6 0.6</td> <td>0.5       0.0         0.5       0.0         0.0       0.0         0.0       0.0         0.0       0.0         0.0       0.0         0.0       0.0         0.0       0.0         0.0       0.0         0.0       0.0         0.0       0.0         0.5       0.0         0.5       0.0         0.5       0.0         0.5       0.0         0.5       0.0         0.5       0.0         0.5       0.0         0.2       0.0         0.2       0.0         0.2       0.0         0.2       0.0</td> <td></td> <td>- 3 - 1 1 - 3 - 3 - 1 1 1 1 1 1 1</td> <td>- 20 20 20 20 20 30 30 20 20</td> <td>SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL</td> <td>14         16         18         20         22         24         26         28         30         32         34         36         38         40</td>	0.5	0.5	0.5 0.6 0.6 0.6 0.6 0.6 0.6 0.6 0.6	0.5       0.0         0.5       0.0         0.0       0.0         0.0       0.0         0.0       0.0         0.0       0.0         0.0       0.0         0.0       0.0         0.0       0.0         0.0       0.0         0.0       0.0         0.5       0.0         0.5       0.0         0.5       0.0         0.5       0.0         0.5       0.0         0.5       0.0         0.5       0.0         0.2       0.0         0.2       0.0         0.2       0.0         0.2       0.0		- 3 - 1 1 - 3 - 3 - 1 1 1 1 1 1 1	- 20 20 20 20 20 30 30 20 20	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL	14         16         18         20         22         24         26         28         30         32         34         36         38         40
OPTIONS       TOTAL PANEL LOAD (AMPS)       54 AMPS         1       CONTRACTOR SHALL PROVIDE NEW CIRCUIT BREAKER AT BOLD CIRCUIT. MATCH EXISTING FOR RATING.       54 AMPS         2       RETURN <e>SPARE BACK TO COUNTY.</e>	17 19 21 23 25 27 29 31 33 35 37 39 41	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE 	- 1 1 1 1 1 1 - 3 - - 3 - - 1 1 AL <u>MCE</u> 225	- 20 20 20 20 20 20 20 20 20 20 20 20 20		0.0	0.5       1.1       0.5 </td <td>0.5</td> <td>0.5 2.0 1.5 1.5 5</td> <td>0.5 0.5 2 0.6 1.5 1.5 4 L LOAD L LOAD</td> <td>0.5 0.0 0.5 0.0 0.0 0.0 0.0 0.0 0.0 0.0</td> <td><ul> <li>Х</li> <li>Х</li> <li>А</li> <li>В</li> </ul></td> <td>- 3 - 1 1 - 3 - 3 - 1 1 1 1 1 1 1</td> <td>- 20 20 20 20 20 30 30 20 20</td> <td>SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR MOTORIZED LOUVERS SPARE GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL    8</td> <td>14         16         18         20         22         24         26         28         30         32         34         36         38         40</td>	0.5	0.5 2.0 1.5 1.5 5	0.5 0.5 2 0.6 1.5 1.5 4 L LOAD L LOAD	0.5 0.0 0.5 0.0 0.0 0.0 0.0 0.0 0.0 0.0	<ul> <li>Х</li> <li>Х</li> <li>А</li> <li>В</li> </ul>	- 3 - 1 1 - 3 - 3 - 1 1 1 1 1 1 1	- 20 20 20 20 20 30 30 20 20	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR MOTORIZED LOUVERS SPARE GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL    8	14         16         18         20         22         24         26         28         30         32         34         36         38         40
CIRCUIT. MATCH EXISTING FOR RATING. 2 RETURN <e>SPARE BACK TO COUNTY.</e>	17 19 21 23 25 27 29 31 33 35 37 39 41	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE ALA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE  SPARE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE 	- 1 1 1 1 1 1 1 - 3 - - 3 - - 3 - - 1 1 AL <u>MCE</u> 225	20 20 20 20 20 20 20 20 20 20 20 20 20 2		0.0	0.5       1.1       0.5 </td <td>0.5</td> <td>0.5 2.0 2.0 1.5 5 TOTA TOTA TOTA TOTA</td> <td></td> <td>0.5 0.0 0.5 0.0 0.0 0.0 0.0 0.0 0.0 0.0</td> <td></td> <td>- - 3 - 1 1 - 1 - 3 - 1 - 1 - 1 1 - 1 -</td> <td>- 20 20 20 20 20 30 - 30 20 20 20 20 20</td> <td>SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR MOTORIZED LOUVERS SPARE GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL <math display="block">\frac{ = \frac{8}{6} \text{ KVA}}{\frac{6}{6} \text{ KVA}}</math></td> <td>14         16         18         20         22         24         26         28         30         32         34         36         38         40</td>	0.5	0.5 2.0 2.0 1.5 5 TOTA TOTA TOTA TOTA		0.5 0.0 0.5 0.0 0.0 0.0 0.0 0.0 0.0 0.0		- - 3 - 1 1 - 1 - 3 - 1 - 1 - 1 1 - 1 -	- 20 20 20 20 20 30 - 30 20 20 20 20 20	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR MOTORIZED LOUVERS SPARE GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL $\frac{ = \frac{8}{6} \text{ KVA}}{\frac{6}{6} \text{ KVA}}$	14         16         18         20         22         24         26         28         30         32         34         36         38         40
2 RETURN <e>SPARE BACK TO COUNTY.</e>	17 19 21 23 25 27 29 31 33 35 37 39 41	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE  SPARE  SPARE  SPARE  SPARE  SPARE  SPARE  SPARE  SPARE  OUTIONS	- 1 1 1 1 1 1 - 3 - 3 - - 3 - - 3 - - 3 - - 1 1 AL -	- 20 20 20 20 20 20 20 20 20 20 20 20 20		0.0	0.5       1.1       0.5 </td <td></td> <td>0.5 2.0 2.0 1.5 5 TOTA TOTA TOTA TOTA TOTA</td> <td></td> <td><ul> <li>0.0</li> <li>0.0</li></ul></td> <td></td> <td>- - 3 - 1 1 - 1 - 3 - 1 - 1 - 1 1 - 1 -</td> <td>- 20 20 20 20 20 30 - 30 20 20 20 20 20</td> <td>SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL 8 KVA 6 KVA 0 KVA 20 KVA</td> <td>14         16         18         20         22         24         26         28         30         32         34         36         38         40</td>		0.5 2.0 2.0 1.5 5 TOTA TOTA TOTA TOTA TOTA		<ul> <li>0.0</li> <li>0.0</li></ul>		- - 3 - 1 1 - 1 - 3 - 1 - 1 - 1 1 - 1 -	- 20 20 20 20 20 30 - 30 20 20 20 20 20	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL 8 KVA 6 KVA 0 KVA 20 KVA	14         16         18         20         22         24         26         28         30         32         34         36         38         40
V.17	17 19 21 23 25 27 29 31 33 35 37 39 41	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE SPARE SPA RE SPA RE SPA RE SPA RE SPA RE SPA RE SPA RE SPA RE SPA RE 1 CONTRACTOR SHALL PROVIDE	- 1 1 1 1 1 1 1 - 3 - - 3 - - 3 - - 3 - - 1 1 - - - 1 1 - - - -	20 20 20 20 20 20 20 20 20 20 20 20 20 2		0.0	0.5       1.1       0.5 </td <td></td> <td>0.5 2.0 2.0 1.5 5 TOTA TOTA TOTA TOTA TOTA</td> <td></td> <td><ul> <li>0.0</li> <li>0.0</li></ul></td> <td></td> <td>- - 3 - 1 1 - 1 - 3 - 1 - 1 - 1 1 - 1 -</td> <td>- 20 20 20 20 20 30 - 30 20 20 20 20 20</td> <td>SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL 8 KVA 6 KVA 0 KVA 20 KVA</td> <td>14         16         18         20         22         24         26         28         30         32         34         36         38         40</td>		0.5 2.0 2.0 1.5 5 TOTA TOTA TOTA TOTA TOTA		<ul> <li>0.0</li> <li>0.0</li></ul>		- - 3 - 1 1 - 1 - 3 - 1 - 1 - 1 1 - 1 -	- 20 20 20 20 20 30 - 30 20 20 20 20 20	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL 8 KVA 6 KVA 0 KVA 20 KVA	14         16         18         20         22         24         26         28         30         32         34         36         38         40
V.17	17 19 21 23 25 27 29 31 33 35 37 39 41	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SUBTOTA MCB OR MLO MAIN CIRCUIT BREAKER RATING BUS RATING MOUNTING 1 CONTRACTOR SHALL PROVIDE CIRCUIT. MATCH EXISTING FOR	I         I <t< td=""><td>20 20 20 20 20 20 20 20 20 20 20 20 20 2</td><td></td><td>0.0    </td><td>0.5       1.1       0.5   <!--</td--><td></td><td>0.5 2.0 2.0 1.5 5 TOTA TOTA TOTA TOTA TOTA</td><td></td><td><ul> <li>0.0</li> <li>0.0</li></ul></td><td></td><td>- - 3 - 1 1 - 1 - 3 - 1 - 1 - 1 1 - 1 -</td><td>- 20 20 20 20 20 30 - 30 20 20 20 20 20</td><td>SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL 8 KVA 6 KVA 0 KVA 20 KVA</td><td>14         16         18         20         22         24         26         28         30         32         34         36         38         40</td></td></t<>	20 20 20 20 20 20 20 20 20 20 20 20 20 2		0.0	0.5       1.1       0.5 </td <td></td> <td>0.5 2.0 2.0 1.5 5 TOTA TOTA TOTA TOTA TOTA</td> <td></td> <td><ul> <li>0.0</li> <li>0.0</li></ul></td> <td></td> <td>- - 3 - 1 1 - 1 - 3 - 1 - 1 - 1 1 - 1 -</td> <td>- 20 20 20 20 20 30 - 30 20 20 20 20 20</td> <td>SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL 8 KVA 6 KVA 0 KVA 20 KVA</td> <td>14         16         18         20         22         24         26         28         30         32         34         36         38         40</td>		0.5 2.0 2.0 1.5 5 TOTA TOTA TOTA TOTA TOTA		<ul> <li>0.0</li> <li>0.0</li></ul>		- - 3 - 1 1 - 1 - 3 - 1 - 1 - 1 1 - 1 -	- 20 20 20 20 20 30 - 30 20 20 20 20 20	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL 8 KVA 6 KVA 0 KVA 20 KVA	14         16         18         20         22         24         26         28         30         32         34         36         38         40
	17 19 21 23 25 27 29 31 33 35 37 39 41	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SUBTOTA MCB OR MLO MAIN CIRCUIT BREAKER RATING BUS RATING MOUNTING 1 CONTRACTOR SHALL PROVIDE CIRCUIT. MATCH EXISTING FOR	I         I <t< td=""><td>20 20 20 20 20 20 20 20 20 20 20 20 20 2</td><td></td><td>0.0    </td><td>0.5       1.1       0.5   <!--</td--><td></td><td>0.5 2.0 2.0 1.5 5 TOTA TOTA TOTA TOTA TOTA</td><td></td><td><ul> <li>0.0</li> <li>0.0</li></ul></td><td></td><td>- - 3 - 1 1 - 1 - 3 - 1 - 1 - 1 1 - 1 -</td><td>- 20 20 20 20 20 30 - 30 20 20 20 20 20</td><td>SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL 8 KVA 6 KVA 0 KVA 20 KVA</td><td>14         16         18         20         22         24         26         28         30         32         34         36         38         40</td></td></t<>	20 20 20 20 20 20 20 20 20 20 20 20 20 2		0.0	0.5       1.1       0.5 </td <td></td> <td>0.5 2.0 2.0 1.5 5 TOTA TOTA TOTA TOTA TOTA</td> <td></td> <td><ul> <li>0.0</li> <li>0.0</li></ul></td> <td></td> <td>- - 3 - 1 1 - 1 - 3 - 1 - 1 - 1 1 - 1 -</td> <td>- 20 20 20 20 20 30 - 30 20 20 20 20 20</td> <td>SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL 8 KVA 6 KVA 0 KVA 20 KVA</td> <td>14         16         18         20         22         24         26         28         30         32         34         36         38         40</td>		0.5 2.0 2.0 1.5 5 TOTA TOTA TOTA TOTA TOTA		<ul> <li>0.0</li> <li>0.0</li></ul>		- - 3 - 1 1 - 1 - 3 - 1 - 1 - 1 1 - 1 -	- 20 20 20 20 20 30 - 30 20 20 20 20 20	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL 8 KVA 6 KVA 0 KVA 20 KVA	14         16         18         20         22         24         26         28         30         32         34         36         38         40
	17 19 21 23 25 27 29 31 33 35 37 39 41	SERVICE 110 NE - CORD REELS SERVICE 110 LTG/EXIT SIGNS FIRE A LA RM CIRCUIT GENERATOR - BATTERY GENERATOR - BLOCK HEATER SPARE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SPA RE  SUBTOTA MCB OR MLO MAIN CIRCUIT BREAKER RATING BUS RATING MOUNTING 1 CONTRACTOR SHALL PROVIDE CIRCUIT. MATCH EXISTING FOR	I         I <t< td=""><td>20 20 20 20 20 20 20 20 20 20 20 20 20 2</td><td></td><td>0.0    </td><td>0.5       1.1       0.5   <!--</td--><td></td><td>0.5 2.0 2.0 1.5 5 TOTA TOTA TOTA TOTA TOTA</td><td></td><td><ul> <li>0.0</li> <li>0.0</li></ul></td><td></td><td>- - 3 - 1 1 - 1 - 3 - 1 - 1 - 1 1 - 1 -</td><td>- 20 20 20 20 20 30 - 30 20 20 20 20 20</td><td>SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL 8 KVA 6 KVA 0 KVA 20 KVA</td><td>14         16         18         20         22         24         26         28         30         32         34         36         38         40         42</td></td></t<>	20 20 20 20 20 20 20 20 20 20 20 20 20 2		0.0	0.5       1.1       0.5 </td <td></td> <td>0.5 2.0 2.0 1.5 5 TOTA TOTA TOTA TOTA TOTA</td> <td></td> <td><ul> <li>0.0</li> <li>0.0</li></ul></td> <td></td> <td>- - 3 - 1 1 - 1 - 3 - 1 - 1 - 1 1 - 1 -</td> <td>- 20 20 20 20 20 30 - 30 20 20 20 20 20</td> <td>SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL 8 KVA 6 KVA 0 KVA 20 KVA</td> <td>14         16         18         20         22         24         26         28         30         32         34         36         38         40         42</td>		0.5 2.0 2.0 1.5 5 TOTA TOTA TOTA TOTA TOTA		<ul> <li>0.0</li> <li>0.0</li></ul>		- - 3 - 1 1 - 1 - 3 - 1 - 1 - 1 1 - 1 -	- 20 20 20 20 20 30 - 30 20 20 20 20 20	SERVICE 110 NE - RECEPT SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 NW - CORD REELS SERVICE 110 W - ROLL UP DOOR SERVICE 110 E - ROLL UP DOOR MOTORIZED LOUVERS  SPARE  GA TE MOTOR ENTRANCE SITE SIGN BUILDING SIGN RECEPT - WP SUBTOTAL 8 KVA 6 KVA 0 KVA 20 KVA	14         16         18         20         22         24         26         28         30         32         34         36         38         40         42

K:\drawings\County of San Bernardino\1901457 Victorville Fuel Infrastructure\1901457E-6.dwg 2/18/2021 9:06 PM Mario Gobea

 THIS DRAWING IS 24" X 36" AT FULL SIZE, 12" X 18" AT HALF SIZE. © COPYRIGHT SAL

 25
 0
 1
 2
 3
 4
 5

 25
 0
 1
 2
 3
 4
 5
 4
 5



# **Modern Custom Fabrication**

# **COMPRESS Pressure Vessel Calculations**

Description: SADDLE CALCS Project: 10K -D5 SUPERVAULT

> County of San Bernardino BUILDING AND SAFETY THE PLANS AND DETAILS HAVE BEEN **DECOMPOSITION OF THE STATE OF T**

> > **REVIEWED** FOR CODE COMPLIANCE

Mar 12, 2021

INTERWEST CONSULTING GROUP

#### Saddle #1

ASME Section VIII Division 1, 20	001 Edition, A03 Addenda
Saddle Material	SA 36
Saddle Construction	Web at edge of rib
Welded to Vessel	Yes
Saddle Allowable Stress, S <sub>s</sub>	23,760 psi
Saddle Yield Stress, S <sub>y</sub>	36,000 psi
Foundation Allowable Stress	750 psi
Design Pressure	Left Saddle Right Saddle
Operating	2.67 psi
Test	4.33 psi
Dimensio	ns
Right saddle distance to datum	32"
Tangent To Tangent Length, L	242"
Saddle separation, L <sub>s</sub>	178"
Vessel Radius, R	64.3125"
Tangent Distance Left, A <sub>l</sub>	31"
Tangent Distance Right, A <sub>r</sub>	33"
Saddle Height, H <sub>s</sub>	68.3125"
Saddle Contact Angle, $\theta$	126°
Web Plate Thickness, t <sub>s</sub>	0,25"
Base Plate Length, E	116.5625"
Base Plate Width, F	11"
Base Plate Thickness, t <sub>b</sub>	0.75"
Number of Stiffening Ribs, n	6
Largest Stiffening Rib Spacing, d <sub>i</sub>	23.0625"
Stiffening Rib Thickness, t <sub>w</sub>	0.25"
Saddle Width, b	10"
Reinforcing	Plate
Thickness, t <sub>p</sub>	0.25"
mickness, tp	0.25"
Width, Wp	16.5"
Width, Wp	16.5" 138°
Width, W <sub>p</sub> Contact Angle, θ <sub>w</sub>	16.5" 138°
Width, W <sub>p</sub> Contact Angle, θ <sub>w</sub> Bolting	16.5" 138°
Width, W <sub>p</sub> Contact Angle, θ <sub>w</sub> Bolting Material	16.5" 138° A307
Width, W <sub>p</sub> Contact Angle, θ <sub>w</sub> Bolting Material Bolt Allowable Shear	16.5" 138° A307 10,000 psi
Width, W <sub>p</sub> Contact Angle, θ <sub>w</sub> Bolting Material Bolt Allowable Shear Description	16.5" 138° A307 10,000 psi 1" coarse threaded
Width, W <sub>p</sub> Contact Angle, θ <sub>w</sub> Bolting Material Bolt Allowable Shear Description Corrosion on root	16.5" 138° A307 10,000 psi 1" coarse threaded 0"

Slotted Hole in Which Saddle	Left Saddle					
Slotted Hole Length	1"					
Weight						
	Operating, Corroded	Hydrotest				
Weight on Left Saddle	39,550 lb	45,256 lb				
Weight on Right Saddle	40,449 lb	46,285 lb				
Weight of Saddle Pair	1,294 lb					


#### Notes

(1) Saddle calculations are based on the method presented in "Stresses in Large Cylindrical Pressure Vessels on Two Saddle Supports" by L.P. Zick.

Bending S <sub>1</sub> (+)	+ pressure (psi allow		n saddles	Bendi	ng + press	ure at th	olbbes o	
•	allow				Bending + pressure at the saddle (psi)			
	(+)	S <sub>1</sub> (-)	allow (-)	S <sub>2</sub> (+)	allow (+)	S <sub>2</sub> (-)	allow (-)	
950	27,840	<u>608</u>	7,027	-52	27,840	<u>-394</u>	7,027	
<u></u>			1,021	288	27,840	-54	7,027	
798	27,840	456	7 027	14	27,840	-329	7,027	
			1,021	297	27,840	-45	7,027	
4 0.07	32,400	512	7.027	179	32,400	-376	7,027	
1,007			1,021	503	32,400	-52	7,027	
796	00.000	111	E 956	<u>14</u>	23,200	-329	5,856	
100	23,200	444	0,800	297	23,200	-45	5,856	
_	798 1,067 786	1,067 32,400	1,067 32,400 512	1,067         32,400         512         7,027	798     27,840     456     7,027     297       1,067     32,400     512     7,027     179       503     503     14	798     27,840     456     7,027     297     27,840       1,067     32,400     512     7,027     179     32,400       786     23,200     444     5,856     14     23,200	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	

				Stres	ss Sumn	nary					
				Tangential shear (psi)		Circumferential stress (psi)			s over le (psi)	Splitting (psi)	
Load	Condition	Saddle	S <sub>3</sub>	allow	S <sub>4</sub> (horns)	S <sub>4</sub> (Wear plate)	allow (+/-)	S <sub>5</sub>	allow	S <sub>6</sub>	allow
Seismic	Seismic Operating	Right Saddle	<u>2,788</u>	18,560	<u>-19,916</u>	<u>-33,339</u>	34,800	<u>9,006</u>	18,000	<u>2,439</u>	15,840
Jeismic		Left Saddle	<u>2,776</u>	18,560	-18,231	-30,389	34,800	8,806	18,000	2,385	15,840
	Operating	Right Saddle	2,010	18,560	-14,923	-24,980	34,800	6,748	18,000	1,828	15,840
Wind	Operating	Left Saddle	2,081	18,560	-13,662	-22,773	34,800	6,599	18,000	1,787	15,840
VVIIIG	Test	Right Saddle	2,240	25,920	-16,756	-28,049	32,400	7,577	32,400	2,052	32,400
	Test	Left Saddle	2,336	25,920	-15,339	-25,569	32,400	7,409	32,400	2,007	32,400
Weight	Operating	Right Saddle	1,936	18,560	-14,530	-24,323	34,800	6,571	18,000	1,780	15,840
Vieign		Left Saddle	2,026	18,560	-13,301	-22,171	34,800	6,425	18,000	1,740	15,840

Seismic base shear on vessel	
Vessel is assumed to be a rigid structure.	
Method of seismic analysis	IBC 2018 ground supported
Vertical seismic accelerations considered	Yes
Force Multiplier	0.3333
Minimum Weight Multiplier	0.2
Importance factor, I <sub>e</sub>	1.25
Site Class	D
Short period spectral response acceleration as percent of g, $\rm S_{\rm S}$	63.2
1 second spectral response acceleration as percent of g, $S_1$	24.2
From ASCE Table 11.4-1, F <sub>a</sub>	1.2944
From ASCE Table 11.4-2, F <sub>v</sub>	1.4
Risk Category (IBC Table 1604.5)	Ш
Hazardous, toxic, or explosive contents	No
Equations	
$S_{MS}=F_a\cdot S_s$	
$S_{M1} = F_v \cdot S_1$	
$S_{DS} = \left(rac{2}{3} ight) \cdot S_{MS}$	
$S_{D1}=\left(rac{2}{3} ight)\cdot S_{M1}$	
$F_p = 0.3 \cdot S_{DS} \cdot W \cdot I_e \cdot 0.7$	
Results	
$S_{MS} = 1.2944 \cdot 0.632$	0.8181
$S_{M1} = 1.4 \cdot 0.242$	0.3388
$S_{DS}=\left(rac{2}{3} ight)\cdot 0.8181$	0.5454
$S_{D1}=\left(rac{2}{3} ight)\cdot 0.3388$	0.2259
Seismic Design Category (Section 11.6)	D
$F_p = 0.3 \cdot 0.5454 \cdot 79{,}999 \cdot 1.25 \cdot 0.7$	11,452.71 lb <sub>f</sub>



Results

 $V_{wt} = 16.72 \cdot 0.85 \cdot (0.57 \cdot 112.0229 + 2 \cdot 0.2778)$ 

		$V_{we} = 16.72 \cdot 0.85 \cdot \left( rac{0.5 \cdot \pi \cdot 64.3125^{-2}}{144} + 2 \cdot 12.0398  ight)$	983.57 lb <sub>f</sub>	
	Right Saddle	$Q_t = rac{915.5\cdot 68.3125}{64.3125\cdot { m Sin}(126\ /\ 2)}$	1,091.4 lb <sub>f</sub>	
		$Q_l = rac{983.57\cdot 68.3125}{178}$	377.47 lb <sub>f</sub>	
On the first		$Q = 40,449 + \max{[1,091.4,377.47]}$	41,540.4 lb <sub>f</sub>	
Operating		$V_{wt} = 16.72 \cdot 0.85 \cdot (0.57 \cdot 110.2364 + 2 \cdot 0.2778)$	901.03 lb <sub>f</sub>	
		$V_{we} = 16.72 \cdot 0.85 \cdot \left( rac{0.5 \cdot \pi \cdot 64.3125^{-2}}{144} + 2 \cdot 12.0398  ight)$	983.57 lb <sub>f</sub>	$\mathbf{\Gamma}$
	Left Saddle	$Q_t = {901.03\cdot 68.3125 \over 64.3125 \cdot { m Sin}(126 \ / \ 2)}$	1,074.14 lb <sub>f</sub>	
		$Q_l = rac{983.57\cdot 68.3125}{178}$	377.47 lbf	7
		$Q = 39{,}550 + \max{[1{,}074.14{,}377.47]}$	40,624.14 lb <sub>f</sub>	
		$V_{wt} = 5.52 \cdot 0.85 \cdot (0.57 \cdot 112.0229 + 2 \cdot 0.2778)$	302.12 lb <sub>f</sub>	
	Right Saddle	$V_{we} = 5.52 \cdot 0.85 \cdot \left( rac{0.5 \cdot \pi \cdot 64.3125^{-2}}{144} + 2 \cdot 12.0398  ight)$	324.58 lb <sub>f</sub>	
		$Q_t = rac{302.12\cdot 68.3125}{64.3125\cdot \mathrm{Sin}(126\ /\ 2)}$	360.16 lb <sub>f</sub>	
		$Q_l = rac{324.58\cdot 68.3125}{178}$	124.57 lb <sub>f</sub>	
Teet		$Q = 46,285 + \max[360.16,124.57]$	46,645.16 lb <sub>f</sub>	
Test		$V_{utt} = 5.52 \cdot 0.85 \cdot (0.57 \cdot 110.2364 + 2 \cdot 0.2778)$	297.34 lb <sub>f</sub>	
		$V_{we} = 5.52 \cdot 0.85 \cdot \left( rac{0.5 \cdot \pi \cdot 64.3125^{-2}}{144} + 2 \cdot 12.0398  ight)$	324.58 lb <sub>f</sub>	
	Left Saddle	$Q_t = \frac{297.34.68.3125}{64.3125 \cdot \sin(126 \ / \ 2)}$	354.47 lb <sub>f</sub>	
		$Q_l = rac{324.58.68.3125}{178}$	124.57 lb <sub>f</sub>	
		$Q = 45,\!256 + \max{[354.47, 124.57]}$	45,610.47 lb <sub>f</sub>	

Longitudinal stress between saddles (Seismic, Operating, left saddle loading and geometry govern)

$$S_1 = \pm \frac{3 \cdot K_1 \cdot Q \cdot (L \ / \ 12)}{\pi \cdot R^2 \cdot t} = \frac{3 \cdot 0.6001 \cdot 54,209.85 \cdot (242 \ / \ 12)}{\pi \cdot 64.1875^2 \cdot 0.25} = 608 \text{ psi}$$

$$S_p = rac{P \cdot R}{2 \cdot t} = rac{2.67 \cdot 64.0625}{2 \cdot 0.25} = 342$$
 psi

Maximum tensile stress  $S_{1t} = S_1 + S_p = \underline{950}$  psi Maximum compressive stress (shut down)  $S_{1c} = S_1 = \underline{608}$  psi

Tensile stress is acceptable (  $\leq 1.2 \cdot S \cdot E = 27,840$  psi) Compressive stress is acceptable (  $\leq 1.2 \cdot S_c = 7,027$  psi)

#### Longitudinal stress at the right saddle (Seismic, Operating)

$$L_e = \frac{2 \cdot H_l}{3} + L + \frac{2 \cdot H_r}{3} = \frac{2 \cdot 4.5678}{3} + 242 + \frac{2 \cdot 4.5678}{3} = 248.0903 \text{ in}$$

Seismic vertical acceleration coefficient  $m = 1.397 \cdot 0.1432 = 0.2$ 

$$w = rac{W_t \cdot (1+m)}{L_e} = rac{79,999 \cdot (1+0.2)}{248.0903} = 386.95 ~ ext{lb}_f/ ext{in}$$

Bending moment at the right saddle:

$$egin{aligned} M_q &= w \cdot \left( rac{2 \cdot H_r \cdot A_r}{3} + rac{A_r^2}{2} - rac{R^2 - H_r^2}{4} 
ight) \ &= 386.95 \cdot \left( rac{2 \cdot 4.5678 \cdot 33}{3} + rac{33^2}{2} - rac{64.3125 \ ^2 - 4.5678 \ ^2}{4} 
ight) \ &= -148,518.6 \ ext{ lb } f ext{-in} \end{aligned}$$

$$S_2 = \pm rac{M_q \cdot K_1{'}}{\pi \cdot R^2 \cdot t} = rac{-148,518.6 \cdot 8.5944}{\pi \cdot 64.1875{}^2 \cdot 0.25} = -394 \;\; \mathrm{psi}$$

$$S_p = \frac{P \cdot R}{2 \cdot t} = \frac{2.67 \cdot 64.0625}{2 \cdot 0.25} = 342$$
 psi

Maximum tensile stress  $S_{2t} = S_2 + S_p = -52$  psi Maximum compressive stress (shut down)  $S_{2c} = S_2 = -394$  psi

Tensile stress is acceptable (  $\leq 1.2 \cdot S = 27.840~{
m psi}$ )

Compressive stress is acceptable (  $\leq 1.2 \cdot S_c = 7,027$  psi)

#### Longitudinal stress at the right saddle (Weight, Operating)

$$L_e = \frac{2 \cdot H_l}{3} + L + \frac{2 \cdot H_r}{3} = \frac{2 \cdot 4.5678}{3} + 242 + \frac{2 \cdot 4.5678}{3} = 248.0903 \text{ in}$$
$$w = \frac{W_t}{3} = \frac{79,999}{3} = 322.46 \text{ lb} \epsilon/\text{in}$$

 $L_e$  248.0903 022.10  $M_{f/M}$ 

Bending moment at the right saddle:

$$\begin{split} M_q &= w \cdot \left(\frac{2 \cdot H_r \cdot A_r}{3} + \frac{A_r^2}{2} - \frac{R^2 - H_r^2}{4}\right) \\ &= 322.46 \cdot \left(\frac{2 \cdot 4.5678 \cdot 33}{3} + \frac{33^2}{2} - \frac{64.3125 \cdot 2^2 - 4.5678 \cdot 2}{4}\right) \\ &= -123.765.5 \text{ lb $t$-in} \end{split}$$

$$S_2 \,=\, \pm \frac{M_q \cdot K_1{'}}{\pi \cdot R^2 \cdot t} \,= \frac{-123,765.5 \cdot 8.5944}{\pi \cdot 64.1875^{-2} \cdot 0.25} \,=\, -\, 329 \ \, \mathrm{psi}$$

$$S_p = \frac{P \cdot R}{2 \cdot t} = \frac{2.67 \cdot 64.0625}{2 \cdot 0.25} = 342$$
psi

Maximum tensile stress  $S_{2t} = S_2 + S_p = 14$  psi Maximum compressive stress (shut down)  $S_{2c} = S_2 = -329$  psi

Tensile stress is acceptable (  $\leq S = 23,200$  psi)

Compressive stress is acceptable (  $\leq S_c = 5{,}856~{
m psi})$ 

#### Tangential shear stress in the shell (right saddle, Seismic, Operating)

$$Q_{shear} = Q - w \cdot \left(A_r + \frac{2 \cdot H_r}{3}\right) = 55,442.08 - 386.95 \cdot \left(33 + \frac{2 \cdot 4.5678}{3}\right) = 41,494.36 \ \ \mathrm{lb}_f$$

$$S_3 = \frac{K_{2.2} \cdot Q_{shear}}{R \cdot t} = \frac{1.078 \cdot 41,494.36}{64.1875 \cdot 0.25} = \underline{2.788} \text{ psi}$$

Tangential shear stress is acceptable (  $\leq 0.8 \cdot S = 18,560$  psi)

#### Circumferential stress at the right saddle horns (Seismic, Operating)

$$\begin{split} S_4 &= \frac{-Q}{4 \cdot (t+t_p) \cdot \left(b+1.56 \cdot \sqrt{R_o \cdot t}\right)} - \frac{12 \cdot K_3 \cdot Q \cdot R}{L \cdot \left(t^2 + t_p^2\right)} \\ &= \frac{-55,442.08}{4 \cdot (0.25 + 0.25) \cdot \left(10 + 1.56 \cdot \sqrt{64.3125 \cdot 0.25}\right)} - \frac{12 \cdot 0.0129 \cdot 55,442.08 \cdot 64.1875}{242 \cdot \left(0.25 \cdot ^2 + 0.25 \cdot ^2\right)} \\ &= \frac{-19.916}{9} \text{ psi} \end{split}$$

Circumferential stress at saddle horns is acceptable (  $\leq 1.5 \cdot S_a = 34{,}800$  psi)

#### Circumferential stress at the right saddle wear plate horns (Seismic, Operating)

$$\begin{split} S_4 &= \frac{-Q}{4 \cdot t \cdot \left(b + 1.56 \cdot \sqrt{R_o \cdot t}\right)} - \frac{12 \cdot K_3 \cdot Q \cdot R}{L \cdot t^2} \\ &= \frac{-55,442.08}{4 \cdot 0.25 \cdot \left(10 + 1.56 \cdot \sqrt{64.3125 \cdot 0.25}\right)} - \frac{12 \cdot 0.0106 \cdot 55,442.08 \cdot 64.1875}{242 \cdot 0.25^2} \\ &= \underline{-33,339} \text{ psi} \end{split}$$

Circumferential stress at wear plate horns is acceptable (  $\leq 1.5 \cdot S_a = 34,800~{
m psi}$ )

#### Ring compression in shell over right saddle (Seismic, Operating)

$$S_{5} = \frac{K_{5} \cdot Q}{(t+t_{p}) \cdot (t_{s}+1.56 \cdot \sqrt{R_{o} \cdot t_{c}})}$$
$$= \frac{0.7388 \cdot 55,442.08}{(0.25+0.25) \cdot (0.25+1.56 \cdot \sqrt{64.3125 \cdot 0.5})}$$
$$= 9.006 \text{ psi}$$

Ring compression in shell is acceptable (  $\leq 0.5 \cdot S_y = 18{,}000~{
m psi})$ 

#### Saddle splitting load (right, Seismic, Operating)

Area resisting splitting force = Web area + wear plate area

$$A_e = H_{eff} \cdot t_s + t_p \cdot W_p = 3 \cdot 0.25 + 0.25 \cdot 16.5$$
 = 4.875 in<sup>2</sup>

$$S_6 = rac{K_8 \cdot Q}{A_e} = rac{0.2145 \cdot 55{,}442.08}{4.875} = rac{2.439}{2.439} \; \mathrm{psi}$$

Stress in saddle is acceptable  $\bigg( \leq rac{2}{3} \cdot S_s = 15{,}840 \;\;\mathrm{psi} \bigg)$ 

#### Shear stress in anchor bolting, one end slotted

Maximum seismic or wind base shear = 11,452.71 lb<sub>f</sub>

Thermal expansion base shear =  $W \cdot \mu$  = 40,197\*0.45 = 18,088.65 lb<sub>f</sub>

Corroded root area for a 1" coarse threaded bolt  $\,=0.551\,$  in  $^2$  ( 4 per saddle )

Bolt shear stress =  $\frac{18,088.65}{0.551 \cdot 1 \cdot 4} = 8,207$  psi

Anchor bolt stress is acceptable ( ≤ 10,000 psi)

#### Shear stress in anchor bolting, transverse

Maximum seismic or wind base shear = 11,452.71 lb <sub>f</sub>

Corroded root area for a 1" coarse threaded bolt  $\,= 0.551~{
m in}^2$  ( 4 per saddle )

Bolt shear stress = 
$$\frac{11,452.71}{0.551 \cdot 2 \cdot 4} = 2,598$$
 psi

Anchor bolt stress is acceptable ( ≤ 10,000 psi)

#### Web plate buckling check (Escoe pg 251)

Allowable compressive stress  $S_c = min(23,760, 3,942) = 3,942$  psi

$$S_c = \frac{K_i \cdot \pi^2 \cdot E}{12 \cdot \left(1 - 0.3^2\right) \cdot \left(\frac{d_i}{t_s}\right)^2} = \frac{1.28 \cdot \pi^2 \cdot 29\text{E} + 06}{12 \cdot \left(1 - 0.3^2\right) \cdot \left(\frac{23.0625}{0.25}\right)^2} = 3,942 \text{ psi}$$

Allowable compressive load on the saddle

$$b_e = \frac{d_i \cdot t_s}{(d_i \cdot t_s) + 2 \cdot t_w \cdot (b-1)} = \frac{23.0625 \cdot 0.25}{(23.0625 \cdot 0.25) + 2 \cdot 0.25 \cdot (10-1)} = 0.5616$$

 $F_b = n \cdot (A_s + 2 \cdot b_e \cdot t_s) \cdot S_c = 6 \cdot (2.4375 + 2 \cdot 0.5616 \cdot 0.25) \cdot 3,942 = 64,299.04 \ \text{ lb}_f$ 

Saddle loading of 56,089.08 lb<sub>f</sub> is  $\leq$  F<sub>b</sub>; satisfactory.

Primary bending + axial stress in the saddle due to end loads (assumes one saddle slotted)

$$\sigma_b = \frac{V \cdot (H_s - x_o) \cdot y}{I} + \frac{Q}{A} = \frac{11,452.71 \cdot (68.3125 - 52.1145) \cdot 5.975}{196.32} + \frac{55,442.08}{43.2764} = 6,927 \text{ psi}$$

The primary bending + axial stress in the saddle  $\leq S_s = 23,760$  psi; satisfactory.

Secondary bending + axial stress in the saddle due to end loads (includes thermal expansion, assumes one saddle slotted)

$$\sigma_b = \frac{V \cdot (H_s - x_o) \cdot y}{I} + \frac{Q}{A} = \frac{29,541.36 \cdot (68.3125 - 52.1145) \cdot 5.975}{196.32} + \frac{54,209.85}{43.2764} = 15,816 \text{ psi}$$

The secondary bending + axial stress in the saddle  $\leq 2^{*}S_{v} = 72,000$  psi; satisfactory.

#### Saddle base plate thickness check (Roark sixth edition, Table 26, case 7a)

where a = 23.0625, b = 10.75 in

$$t_b = \sqrt{rac{eta_1 \cdot q \cdot b^2}{1.5 \cdot S_a}} = \sqrt{rac{1.8979 \cdot 44 \cdot 10.75^{-2}}{1.5 \cdot 23,760}} = 0.5189 ~~{
m in}$$

The base plate thickness of 0.75 in is adequate.


#### Foundation bearing check

$$S_f = \frac{Q_{\text{max}}}{F \cdot E} = \frac{56,089.08}{11 \cdot 116.5625} = 44$$
 psi

Concrete bearing stress ≤ 750 psi ; satisfactory.



#### Structural Design Calculations for Generator and Tank Concrete Pad and Anchors



Calculations by Doug Fredericks 10/7/2020 Client: Victorville Fuel Station Project: Generator Concrete Pad Project #: 20BR010100 Date: 10/7/2020 Prepared by: Doug Fredericks

5

PSOMAS


Туре	Value	Description
SS	1.288	MCE <sub>R</sub> ground motion. (for 0.2 second period)
S <sub>1</sub>	0.498	MCE <sub>R</sub> ground motion. (for 1.0s period)
S <sub>MS</sub>	1.545	Site-modified spectral acceleration value
S <sub>M1</sub>	null -See Section 11.4.8	Site-modified spectral acceleration value
S <sub>DS</sub>	1.03	Numeric seismic design value at 0.2 second SA
S <sub>D1</sub>	null -See Section 11.4.8	Numeric seismic design value at 1.0 second SA
Туре	Value	Description
SDC	null -See Section 11.4.8	Seismic design category
Fa	1.2	Site amplification factor at 0.2 second
Fv	null -See Section 11.4.8	Site amplification factor at 1.0 second
PGA	0.5	MCE <sub>G</sub> peak ground acceleration
F <sub>PGA</sub>	1.2	Site amplification factor at PGA
PGAM	0.6	Site modified peak ground acceleration
ΤL	12	Long-period transition period in seconds
SsRT	1.288	Probabilistic risk-targeted ground motion. (0.2 second)
SsUH	1.38	Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration
SsD	1.5	Factored deterministic acceleration value. (0.2 second)
S1RT	0.498	Probabilistic risk-targeted ground motion. (1.0 second)
S1UH	0.544	Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration.
S1D	0.6	Factored deterministic acceleration value. (1.0 second)
PGAd	0.5	Factored deterministic acceleration value. (Peak Ground Acceleration)
C <sub>RS</sub>	0.933	Mapped value of the risk coefficient at short periods
C <sub>R1</sub>	0.915	Mapped value of the risk coefficient at a period of 1 s



Client: Victorville Fuel Station Project: Generator Concrete Pad Project #: 20BR010100 Date: 10/7/2020 Prepared by: Doug Fredericks

# Generator CIP Concrete Pad and Anchors

ASCE 7-16 Section 15 for Rigid Non-Building Structure



## **Seismic Calculations**

ASCE 7-16 Section 15 for Rigid Non-Building Structure; 0.3 x le x Sds

Risk Category	III	
le	1.25	(importance factor)
S <sub>DS</sub>	1.036 g	(design short period spectral acceleration)
V	0.388 x W	(ASCE 15.4-5) (S1 is not > 0.6g)
Vertical: 0.2 x Sds		
Vert	0.207 x W	

## Seismic Overturning Moment about Anchors

Item	W (k)	V (k)	z (ft)	Mmt (k-ft)
Generator Open Set	2.425	0.942	5.375	13.034
Enclosure	0.625	0.243	5.375	3.359
Tank	1.365	0.530	1.792	2.446
Total	4.415	1.714		18.839

## Seismic Vertical Overturning Moment about One Row of Anchors

Item	W (k)	Vert (k)	b/2 (ft)	Mmt (k-ft)
Total	4.415	0.914	1.667	1.372

#### **Resisting Overturning Moment about One Row of Anchors**

Item	W (k)	b/2 (ft)	0.9*Mmt (k-ft)
Total	4.415	1.667	6.623

#### Anchor Tie Down Force

Resisting Mmt	6.623 k-ft
Total Seismic Mmt	20.211 k-ft
Remainder	13.588 k-ft
Tu	4.077 kips per row

#### **Concrete Pad**

W	5.50 ft
L	12.00 ft
t	1.25 ft
А	66.00 ft <sup>2</sup>
I	166.38 ft4
γ	0.15 kcf
Р	82.50 kip

(width) (length) (thickness) (area of pad) (Mmt of Inertia of pad) (unit weight of concrete) (weight of pad)

## **Slab Overturning Moment Check**

Slab OT Mmt	20.02 k-ft
Equipment OT Mmt	9.46 k-ft
OM	29.48 k-ft
Wind OM	7.56 k-ft
RM	239.02 k-ft
OT Factor of Safety	8.11
	ОК

(Slab weight x Seismic factor x thickness/2) (Equip weight x seismic factor x (z+thickness) (overturning moment) (overturning moment) (resisting moment)

## Soil Pressures at Seismic Overturning

P/A	1.3	ksf
Mc/I	0.49	ft
<b>q</b> <sub>max</sub>	1.804	ksf
<b>q</b> <sub>max</sub>	0.830	ksf
Max Allow Soil Pressure	2.000	ksf
	ОК	

Sum of Weight / Area of pad (eccentricity) (maximum soil pressure) (minimum soil pressure) Use 1500 psf for non-seismic allowable and apply 1.333

## **Concrete Pad Capacity**

f' <sub>c</sub>	4 ksi	(compressive strength of concrete)
f <sub>y</sub>	<mark>60</mark> ksi	(yield strength of steel)
b	<b>12</b> in	(effective width for 1' strip)
bar	#6	(bar size)
dbar	0.75 in	(diameter of bar)
clr	<mark>3</mark> in	(clear to rebar)
S	12 in	(rebar spacing)
A <sub>s</sub>	0.44 in <sup>2</sup>	(area of steel)
d	11.25 in	(effective depth)
$ ho_{prov'd}$	0.0033	(reinforcement ratio)
$ ho_{min}$	0.0032	(min reinforcement ratio)
$\phi V_c$	<b>6.40</b> kip/ft	(shear capacity of concrete)
φM <sub>n</sub>	267.3 k-in	(moment capacity)
	22.28 k-ft/ft	(moment capacity)

# **Concrete Slab Loading Demand**

L	<b>2,5</b> ft	(
V <sub>u</sub>	4.51 k	
	OK, No Shear Reinforcement N	leeded
M <sub>u</sub>	5.64 k-ft	(

(Length of slab overhanging equipment base) (qmax applied to overhang)

**OK, Flexural Reinforcement Adequate** 

(qmax applied to overhang)

## **Anchor Bolts Load Demand**

Ти	4.08 k-ft	
# of anchors / row	5	(number of anchors per side)
Tu per anchor	<b>0.815</b> kip	(max tension for bolts to resist)
V of Equipment	1.714 kip	(Seismic shear of equipment)
Sliding Resistance	0.915 kip	(Use 0.3 friction factor)
V Remainder	0.799 kip	
Vu per anchor	<b>0.080</b> kip	

## **Anchor Bolts Resistance**

Type Stainless Steel KB-TZ Hilti anchors

Design Strength per Manufacturer		
f'c	4000 psi	
Anchor diameter	0.50 in	
Nominal Embedment	3.25 in	
Tension	2.735 k	< OK >
Shear	6.880 k	< OK >
Unity check	0.134	< OK >

#### TABLE 4-DESIGN INFORMATION, STAINLESS STEEL KB-TZ


DESIGN INFORMATION	Symbol	Units	Nominal anchor diar					ameter																																																																													
DESIGN INFORMATION	Symbol	Units	3	3/8 1/2			5/8																																																																														
Anchor O.D.	d,	in. (mm)	0.375 (9.5)		0.5 (12.7)		0.625 (15.9)																																																																														
Effective min. embedment <sup>1</sup>	her	in. (mm)		2 51)	200	2 (51)		31/4 (83)		4 (102)																																																																											
Min. member thickness	h <sub>min</sub>	in. (mm)	4 (102)	5 (127)	4 (102)	6 (152)	6 (152)	8 (203)	5 (127)	6 (152)	8 (203)																																																																										
Critical edge distance	Cac	in. (mm)	43/8 (111)	37/8 (98)	51/2 (140)	41/2	71/2 (191)	6 (152)	7 (178)	87/8 (225)	6 (152																																																																										
Min. edge distance	Cmin	in. (mm)	87	4)	2 <sup>7</sup> /e 2 <sup>1</sup> /e (X3) (54)			3 <sup>1/4</sup> (83)		<sup>a</sup> /s 50)																																																																											
wint, euge distance	for s ≥	in. (mm)		5 (7)	1.100	74 16)	37	1/4 33)	5 <sup>1</sup> /2 (140)	1023	1/2 40)																																																																										
	Smin	in. (mm)		2 <sup>1</sup> /4 2 <sup>1</sup> /e (57) (73)		2 <sup>7</sup> /e 2		P	2 <sup>3</sup> /4 (70)	2 <sup>3</sup> /s (60)																																																																											
Min. anchor spacing	for c ≥ in. 3 <sup>1</sup> / <sub>2</sub> 4 <sup>1</sup> / <sub>2</sub> (mm) (89) (114		1.000	31/4		4 <sup>1</sup> / <sub>8</sub> (105)	4 <sup>1</sup> / <sub>4</sub> (108)																																																																														
Min. hole depth in concrete	h	in. (mm)	2 <sup>2</sup> /2 (67)		2 <sup>±</sup> (6	% 7)	4 (102)		3 <sup>3</sup> / <sub>4</sub> (98)	4¾ (121)																																																																											
Min. specified yield strength	Ŧŗ	Ib/in <sup>2</sup> (N/mm <sup>2</sup> )	92,000 92,0		92,000 (634)			92,000 (634)																																																																													
Min. specified ult. Strength	fue	kb/in² (N/mm²)		,000 93)	115,000 (793)		Ĵ		115,000 (793)																																																																												
Effective tensile stress area	Auest	in <sup>2</sup> (mm <sup>2</sup> )	1.000	)52 3.6)	0.101 (65.0)				0.162 (104.6)																																																																												
Steel strength in tension	Nsa	lb (kN)		5,968 11,5		11,554 (51.7)			17,880 (82.9)																																																																												
Steel strength in shear	Vaa	lb (kN)	0.000	4,720 6,84		STATES OF		and the second second				4,720		STATISTICS STATISTICS		ALL PROPERTY AND		6,880		100		100		100		100		100		100		1000		100		100		100				100		100		1000		100		1000		6,8		6,8		6,8		6,8		6,8		6,8		6,8		6,8		6,8		100				1		6,8		6,8		6,880				9,870 (43.9)	
Pullout strength in tension, seismic <sup>2</sup>	N <sub>p,mp</sub>	lb (kN)	2,340 (10.4)		2,735 (12.2)		NA		NA	NA 5,840 (26.0)																																																																											
Steel strength in shear, seismic <sup>2</sup>	V <sub>ae,eq</sub>	Ib (kN)				6,880 (30.6)		0	9,350 (41.6)																																																																												
Pullout strength uncracked concrete <sup>3</sup>	N <sub>p,uncr</sub>	lb (kN)	2,630 NA (11.7) NA		5 760			NA																																																																													
Pullout strength cracked concrete <sup>3</sup>	N <sub>p,cr</sub>	lb (kN)		340	3,180		180 NA		NA	NA 5,840 (26.0)																																																																											



Client: Victorville Fuel Station Project: Generator Concrete Pad Project #: 20BR010100 Date: 10/7/2020 Prepared by: Doug Fredericks

# Above Ground Tank CIP Concrete Pad and Anchors

ASCE 7-16 Section 15 for Rigid Non-Building Structure



## **Seismic Calculations**

ASCE 7-16 Section 15 for Rigid Non-Building Structure; 0.3 x le x Sds

Risk Category	III	
le	1.25	(importance factor)
S <sub>DS</sub>	1.294 g	(design short period spectral acceleration)
V	0.485 x W	(ASCE 15.4-5) (S1 is not > 0.6g)
Vertical: 0.2 x Sds		
Vert	0.259 x W	

## Seismic Overturning Moment about Anchors

Item	W (k)	V (k)	z (ft)	Mmt (k-ft)
Each Tank Shell	45.000	21.844	6.667	145.625
Diesel	66.500	32.280	6.667	215.201
Other	0.000	0.000	0.000	0.000
Total	111.500	54.124		360.825

## Seismic Vertical Overturning Moment about One Row of Anchors

Item	W (k)	Vert (k)	b/2 (ft)	Mmt (k-ft)
Total	111.500	28.866	5.333	138.557

#### **Resisting Overturning Moment about One Row of Anchors**

Item	W (k)	b/2 (ft)	0.9*Mmt (k-ft)
Total	111.500	5.333	535.200

#### Anchor Tie Down Force

Resisting Mmt	535.200 k-ft
Total Seismic Mmt	998.764 k-ft Omega =
Remainder	463.564 k-ft
Tu	43.459 kips per row

#### **Concrete Pad**

W	<b>16.00</b> ft
L	20.00 ft
t	1.00 ft
А	320.00 ft <sup>2</sup>
I	6826.67 ft4
γ	0.15 kcf
Р	320.00 kip

(width) (length) (thickness) (area of pad) (Mmt of Inertia of pad) (unit weight of concrete) (weight of pad)

#### **Slab Overturning Moment Check**

Slab OT Mmt	77.67 k-ft
Equipment OT Mmt	414.95 k-ft
OM	492.62 k-ft
Wind OM	40.22 k-ft
RM	3452.00 k-ft
OT Factor of Safety	7.01
	ОК

(Slab weight x Seismic factor x thickness/2) (Equipment weight x seismic factor x (z+thickness) (overturning moment) (overturning moment) (resisting moment)

#### **Soil Pressures at Seismic Overturning**

P/A	1.3 ksf
Mc/I	0.58 ft
<b>q</b> <sub>max</sub>	1.926 ksf
<b>q</b> <sub>max</sub>	0.771 ksf
Max Allow Soil Pressure	2.000 ksf
	ОК

Sum of Weight / Area of pad (eccentricity) (maximum soil pressure) (minimum soil pressure) Use 1500 psf for non-seismic allowable and apply 1.333

## **Concrete Pad Capacity**

Concrete Pad Capacity		
f'c	4 ksi	(compressive strength of concrete)
f <sub>y</sub>	<mark>60</mark> ksi	(yield strength of steel)
b	12 in	(effective width for 1'strip)
bar	#6	(bar size)
dbar	0.75 in	(diameter of bar)
clr	<mark>3</mark> in	(clear to rebar)
S	12 in	(rebar spacing)
A <sub>s</sub>	0.44 in <sup>2</sup>	(area of steel)
d	8.25 in	(effective depth)
ρ <sub>prov'd</sub>	0.0044	(reinforcement ratio)
$ ho_{min}$	0.0032	(min reinforcement ratio)
φV <sub>c</sub>	<b>4.70</b> kip/ft	(shear capacity of concrete)
φM <sub>n</sub>	196.02 k-in	(moment capacity)
	16.34 k-ft/ft	(moment capacity)

## **Concrete Slab Loading Demand**

L			2 ft
V <sub>u</sub>			3.85 k
	OK	No Shear Rei	oforcomon

(Length of slab overhanging equipment base) (qmax applied to overhang)

#### rcement Needed

 $M_{u}$ 

(qmax applied to overhang)

OK, Flexural Reinforcement Adequate

#### **Anchor Bolts Load Demand**

Tu	43.46 k-ft	
# of anchors / row	8	(number of anchors per side)
Tu per anchor	<b>5.432</b> kip	(max tension for bolts to resist)
V of Equipment	54.124 kip	(Seismic shear of equipment)
Sliding Resistance	33.450 kip	(Use 0.3 friction factor)
V Remainder	20.674 kip	
Vu per anchor	<b>1.292</b> kip	

3.85 k-ft

## **Anchor Bolts Resistance**

Type Stainless Steel KB-TZ Hilti anchors

Design Strength per Manuf	acturer	
f'c	4000 psi	
Anchor diameter	0.75 in	
Nominal Embedment	4.75 in	
Tension	8.11 k	< OK >
Shear	12.890 k	< OK >
Unity check	0.534	< OK >

#### TABLE 4-DESIGN INFORMATION, STAINLESS STEEL KB-TZ

DECICH RECORD TION			Nominal anchor diameter								
DESIGN INFORMATION	Symbol	Units	3	3/8 1/2				3/a			
Anchor O.D.	d,	in. (mm)	197	375	0.000		0.5		0.625 (15.9)		
Effective min. embedment <sup>1</sup>	her	in. (mm)		2 2 (51) (51)				3 <sup>4</sup> / <sub>8</sub> 4 (79) (102)			
Min. member thickness	h <sub>min</sub>	in. (mm)	4 (102)	5 (127)	4 (102)	6 (152)	6 (152)	8 (203)	5 (127)	6 (152)	8 (203)
Critical edge distance	Cac	in. (mm)	43/8 (111)	37/8 (98)	51/2 (140)	415 (114)	71/2 (191)	6 (152)	7 (178)	87/8 (225)	6 (152
Min. edge distance	Cmin	in. (mm)	87	4)	2 <sup>7</sup> /ir (73)			21/e (54)		3 <sup>1</sup> /4 2 <sup>3</sup> /8 (60)	
Mint, euge distance	for s ≥	in. (mm)	5 (127)		5 <sup>3</sup> /4 5 <sup>1</sup> /4 (146) (133)			5 <sup>1</sup> / <sub>2</sub> (140)	5 <sup>1</sup> /2 (140)		
Min. anchor spacing	Simin	in. (mm)	2 <sup>1</sup> /4 (57)		2 <sup>//</sup> /e 2 (73) (5 <sup>/</sup>		B	2 <sup>3</sup> / <sub>4</sub> 2 <sup>3</sup> / <sub>8</sub> (70) (60)			
	for c ≥	in. (mm)	3 <sup>1</sup> /2 (89)		4 <sup>1</sup> / <sub>2</sub> 3 <sup>1</sup> / <sub>4</sub> (114) (83)			4 <sup>1</sup> / <sub>8</sub> (105)	4 <sup>1</sup> / <sub>4</sub> (108)		
Min, hole depth in concrete	h	in. (mm)	2 <sup>6</sup> /± (67)		2 <sup>5</sup> /8 4 (67) (102)		3 <sup>3</sup> / <sub>4</sub> (98)	2.12.23.23.24.3			
Min. specified yield strength	Ŧŗ	Ib/in <sup>2</sup> (N/mm <sup>2</sup> )	92,000 92,0 (634) (634								
Min. specified ult. Strength	fute	ib/in² (N/mm²)		115,000 115,000 (793) (793)				115,000 (793)			
Effective tensile stress area	Acen	in <sup>2</sup> (mm <sup>2</sup> )	1.023	)52 3.6)	0.101 (65.0)				0.162 (104.6)		
Steel strength in tension	Nsa	lb (kN)	5,968 11,		11,554 (51.7)			17,880 (82.9)			
Steel strength in shear	Vaa	lb (kN)	4,720 (21.0)		6,880 (30.6)			9,870 (43.9)			
Pullout strength in tension, seismic <sup>2</sup>	N <sub>p,eq</sub>	lb (kN)	2,340 (10.4)		2,735 (12.2)		NA		NA	5,840 (26.0)	
Steel strength in shear, seismic <sup>2</sup>	V <sub>se,eq</sub>	lb (kN)				6,88				9,350 (41.6)	
Pullout strength uncracked concrete <sup>3</sup>	Np,uncr	lb (kN)	1022	530 1.7)	NA		NA 5,760 (25.6)		NA		
Pullout strength cracked concrete <sup>3</sup>	N <sub>p,cr</sub>	ib (kN)	2,340		3,180 (14,1)		NA		NA 5,840 (26.0)		

